

Monthly Overflow Report

Date Range: June, 2012

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09412014	06/05/12	06/05/12	2 hours	0.0001		Roots	248 Tulip Hill Dr. Cleaned Line
000	14904011CO	06/12/12	06/12/12	2 hours	0.0001		Roots	259 Bell Road Clean out - Cleaned line
000	09515037	06/21/12	06/21/12	1.5 hours	0.0001		Roots	25 Century Blvd. Cleaned manhole and line
000	08116057	06/25/12	06/25/12	1.5 hours	0.0001		Line Break	901 Scovel St. Repaired main
180	Hickory Hollow PS	06/24/12	06/24/12	0.25 hours	0.0001	0.00	Power Related	Blown NES transformer. Evaluate potential emergency generator.

Monthly Overflow Report

Date Range: June, 2012

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04205005	06/07/12	06/07/12	1 hours	0.0001		Grit/Debris	860 Old Hickory Blvd. Cleaned Line

Monthly Overflow Report

Date Range: June, 2012

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	02205018	06/12/12	06/12/12	1.5 hours	0.0001		Grit/Debris	3525 Old Clarksville Hwy. Cleaned Line
000	05914064	06/26/12	06/26/12	1 hours	0.00001		Grit/Debris	3853 Buena Vista Pk. Cleaned Line