

Monthly Overflow Report

Date Range: July, 2012

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	11006014	07/02/12	07/02/12	7.5 hours	0.0001		Line Break	1689 Stewarts Ferry Pk. Repaired Line
000	08603181	07/15/12	07/15/12	0.5 hours	0.00001	2.94	Rainfall	4144 Andrew Jackson Pkwy.
000	09510050	07/20/12	07/20/12	5 hours	0.001	2.64	Rainfall	501 Bismark Dr.
000	08606106	07/20/12	07/20/12	6 hours	0.0001	4.72	Rainfall	5289 Old Hickory Blvd.
000	14909006	07/28/12	07/28/12	0.25 hours	0.00001		Grease	728 Bowfield Ct. Cleaned Line
000	94313003	07/29/12	07/29/12	0.25 hours	0.00001		Grit/Debris	102 Wychewood Cove - Cleaned Line
124	Williamson Ferry PS	07/14/12	07/14/12	0.42 hours	0.001	1.58	Rainfall	Infiltration/Inflow. Station at rated capacity.
124	Williamson Ferry PS	07/20/12	07/21/12	5.25 hours	0.187	3.19	Rainfall	Infiltration/Inflow. Station at rated capacity.
130	Brown's Creek PS / Visco Dr.	07/19/12	07/21/12	12.17 hours	5.055	4.31	Rainfall	Infiltration/Inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	07/20/12	07/20/12	1.25 hours	0.029	3.11	Rainfall	Infiltration/Inflow. Station at rated capacity.
151	Shelby Park PS	07/20/12	07/20/12	1 hours	0.053	4.31	Rainfall	Infiltration/Inflow. Station at rated capacity.
156	Bonnafair PS	07/20/12	07/20/12	0.5 hours	0.01	2.48	Rainfall	Infiltration/Inflow. Station at rated capacity.
158	Farmingham Woods PS	07/14/12	07/14/12	7.5 hours	0.2	2.94	Rainfall	Infiltration/Inflow. Station at rated capacity.
158	Farmingham Woods PS	07/20/12	07/20/12	13 hours	0.5	2.48	Rainfall	Infiltration/Inflow. Station at rated capacity.
184	Munn Rd PS	07/14/12	07/14/12	0.5 hours	0.01	2.94	Rainfall	Infiltration/Inflow. Station at rated capacity.
188	South Oak Hill PS	07/20/12	07/20/12	1 hours	0.01	2.00	Rainfall	Infiltration/Inflow. Station at rated capacity.
189	Langford Farms PS	07/14/12	07/14/12	1.25 hours	0.01	3.37	Rainfall	Infiltration/Inflow. Station at rated capacity.
189	Langford Farms PS	07/20/12	07/20/12	6.5 hours	0.05	3.54	Rainfall	Infiltration/Inflow. Station at rated capacity.
222	Barker Road	07/14/12	07/14/12	9.83 hours	0.534	2.94	Rainfall	149 Barker Rd.
222	Barker Road	07/20/12	07/21/12	26 hours	5.578	2.64	Rainfall	149 Barker Rd.
226	Cowan St. Relief Bleeder	07/20/12	07/21/12	14.75 hours	0.641	3.19	Rainfall	

Monthly Overflow Report

Date Range: July, 2012

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05201012CO	07/14/12	07/14/12	0.25 hours	0.00001	3.18	Rainfall	101 Coventry Woods Dr. Clean out
106	Vandiver PS	07/14/12	07/14/12	5.5 hours	0.26	3.03	Rainfall	Infiltration/Inflow. Station at rated capacity.
106	Vandiver PS	07/19/12	07/20/12	12.42 hours	1.311	3.71	Rainfall	Infiltration/Inflow. Station at rated capacity.
109	Dry Creek PS	07/08/12	07/08/12	0.92 hours	0.16	4.16	Power Related	
109	Dry Creek PS	07/19/12	07/20/12	2.5 hours	0.191	6.00	Rainfall	
110	Loves Branch PS	07/14/12	07/14/12	2.42 hours	0.109	3.18	Rainfall	Infiltration/Inflow. Station at rated capacity.
110	Loves Branch PS	07/20/12	07/21/12	10.5 hours	0.783	6.00	Rainfall	Infiltration/Inflow. Station at rated capacity.
112	Gibson Creek PS	07/14/12	07/14/12	1.33 hours	0.151	3.18	Rainfall	Infiltration/Inflow. Station at rated capacity.
112	Gibson Creek PS	07/20/12	07/20/12	6.83 hours	1.216	6.00	Rainfall	Infiltration/Inflow. Station at rated capacity.
117	Neely's Bend PS	07/20/12	07/20/12	9 hours	0.5	5.10	Rainfall	Infiltration/Inflow. Station at rated capacity.
127	Madison Heights PS	07/14/12	07/14/12	2 hours	0.05	3.18	Rainfall	Infiltration/Inflow. Station at rated capacity.
127	Madison Heights PS	07/20/12	07/20/12	6.5 hours	0.2	5.10	Rainfall	Infiltration/Inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	07/14/12	07/14/12	4 hours	0.01	3.18	Rainfall	Infiltration/Inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	07/20/12	07/20/12	10.5 hours	0.05	5.10	Rainfall	Infiltration/Inflow. Station at rated capacity.
150	Hidden Acres PS	07/14/12	07/14/12	2.25 hours	0.2	3.18	Rainfall	Infiltration/Inflow. Station at rated capacity.
150	Hidden Acres PS	07/20/12	07/20/12	6 hours	0.5	5.10	Rainfall	Infiltration/Inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: July, 2012

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09016024	07/19/12	07/19/12	1 hours	0.001	2.95	Roots	6416 Premier Dr. Cleaned Line
000	06001013	07/20/12	07/20/12	1 hours	0.0001	3.11	Rainfall	3258 Brick Church Pike
000	08007008	07/24/12	07/24/12	1 hours	0.001		Roots	3301 Hospital Ln. Cleaned Line
000	05008008	07/24/12	07/24/12	8.5 hours	0.001		Grit/Debris	3474 Dickerson Pike. Cleaned Line
104	Whites Creek PS	07/20/12	07/21/12	41.59 hours	7.444	3.11	Rainfall	Infiltration/Inflow. Station at rated capacity.
107	West Park PS	07/20/12	07/20/12	2.25 hours	0.122	2.95	Rainfall	Infiltration/Inflow. Station at rated capacity.
114	Davidson Branch PS	07/20/12	07/20/12	9.75 hours	0.852	2.95	Rainfall	Infiltration/Inflow. Station at rated capacity.
126	Cleeces Ferry PS	07/14/12	07/14/12	3 hours	0.05	1.56	Rainfall	Infiltration/Inflow. Station at rated capacity.
138	Sunliner PS	07/20/12	07/20/12	3 hours	0.01	2.28	Rainfall	Infiltration/Inflow. Station at rated capacity.
145	Joelton PS	07/20/12	07/20/12	8.75 hours	0.1	3.20	Rainfall	Infiltration/Inflow. Station at rated capacity.
217	Basswood Ave.	07/20/12	07/20/12	5.67 hours	0.58	2.95	Rainfall	516 Basswood Ave.
346	3428 Briley/Brick Church	07/20/12	07/20/12	1 hours	0.0001	3.11	Rainfall	3438 Briley Park Blvd.
347	3300 Briley/Brick Church	07/20/12	07/20/12	1 hours	0.0001	3.11	Rainfall	3300 Briley Park Blvd.