

Monthly Overflow Report

Date Range: August, 2012

Central WWTP NPDES# TN 0020575

| # | Overflow Name | Start Date | End Date | Duration | Volume (mg) | Rainfall | Overflow Cause | Remarks |
|---------------------------------|---------------|------------|----------|------------|-------------|----------|----------------|--|
| Sanitary Sewer Overflows | | | | | | | | |
| 000 | 16213041 | 08/09/12 | 08/09/12 | 2 hours | 0.001 | 0.28 | Roots | 209 Cedarcreek Dr. - Cleaned Line |
| 000 | 15014028 | 08/21/12 | 08/21/12 | 1 hours | 0.0001 | | Grit/Debris | 4125 Tea Garden Way - Cleaned Line |
| 000 | 09308019 | 08/21/12 | 08/21/12 | 1 hours | 0.0001 | | Grit/Debris | 601 Crutcher St. - Cleaned Line |
| 000 | 09209063 | 08/28/12 | 08/28/12 | 0.75 hours | 0.00001 | | Grit/Debris | 3708 Charlotte Ave. Cleaned Line |
| 000 | 14812012 | 08/28/12 | 08/28/12 | 1 hours | 0.0001 | | Line Break | 860 Richards Rd. - Repaired Line |
| 000 | 13513018 | 08/29/12 | 08/29/12 | 5 hours | 0.001 | | Grease | 460 Franklin Limestone Rd - Cleaned Line |

Monthly Overflow Report

Date Range: August, 2012

Dry Creek WWTP NPDES# TN0020648

| # | Overflow Name | Start Date | End Date | Duration | Volume (mg) | Rainfall | Overflow Cause | Remarks |
|---------------------------------|---------------|------------|----------|------------|-------------|----------|----------------|---|
| Sanitary Sewer Overflows | | | | | | | | |
| 000 | 03405019 | 08/01/12 | 08/01/12 | 1.5 hours | 0.001 | 0.55 | Roots | 554 Thomas Jefferson Cir. - Cleaned Line |
| 106 | Vandiver PS | 08/09/12 | 08/09/12 | 4.5 hours | 0.16 | 2.08 | Rainfall | Inflow/Infiltration. Station at rated capacity. |
| 106 | Vandiver PS | 08/16/12 | 08/17/12 | 1.67 hours | 0.034 | 1.27 | Rainfall | Inflow/Infiltration. Station at rated capacity. |

Monthly Overflow Report

Date Range: August, 2012

Whites Creek WWTP NPDES# TN 0024970

| # | Overflow Name | Start Date | End Date | Duration | Volume (mg) | Rainfall | Overflow Cause | Remarks |
|---------------------------------|---------------|------------|----------|------------|-------------|----------|----------------|---|
| Sanitary Sewer Overflows | | | | | | | | |
| 000 | 10303051 | 08/09/12 | 08/09/12 | 1 hours | 0.0001 | 0.71 | Roots | 5508 Bon Air Cir. - Cleaned Line |
| 000 | 05008008 | 08/13/12 | 08/13/12 | 3.5 hours | 0.001 | 0.47 | Grit/Debris | 3480 Dickerson Rd. - Cleaned Line |
| 000 | 05003011 | 08/16/12 | 08/16/12 | 1.25 hours | 0.00001 | 0.80 | Grease | 1376 Bellshire Terrace Dr. - Cleaned Line |