

# Monthly Overflow Report

Date Range: September, 2012

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	16108035	09/14/12	09/14/12	2 hours	0.001		Grease	5414 Nolensville Pk. - Cleaned Line
000	14811028	09/24/12	09/24/12	0.5 hours	0.00001		Grit/Debris	4501 Packard Dr. - Cleaned Line
000	06205033	09/28/12	09/28/12	4.5 hours	0.00001	0.18	Line Break	2424 Pennington Bend - Repaired Line
165	Birchwood SPS	09/24/12	09/24/12	2 hours	0.001		Mechanical	Grinder pump clogged. PS not on SCADA.

---

# Monthly Overflow Report

Date Range: September, 2012

---

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
127	Madison Heights PS	09/29/12	09/29/12	1.45 hours	0.001		Other/not listed	Direct inflow from damaged fire hydrant.

---

# Monthly Overflow Report

Date Range: September, 2012

---

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	09110102	09/04/12	09/04/12	1.25 hours	0.001		Roots	800 Delray Dr. - Cleaned Line
000	05008005	09/20/12	09/20/12	2.5 hours	0.001		Grit/Debris	3510 Dickerson Pk. - Cleaned Line