

Monthly Overflow Report

Date Range: December, 2012

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	16102025	12/05/12	12/05/12	1 hours	0.001		Roots	5242 Edmondson Pk. - Cleaned Line
000	10705083	12/05/12	12/05/12	2 hours	0.0001		Roots	108 Five Oaks Dr. - Cleaned Line
000	08113005	12/06/12	12/06/12	2 hours	0.001		Grit/Debris	1234 Schrader Ln. - Cleaned Line
000	09211074	12/10/12	12/10/12	1.5 hours	0.001		Grit/Debris	2300 Leslie Ave. - Cleaned Line
000	10505153	12/10/12	12/10/12	2 hours	0.00001		Grit/Debris	1199 Horton Ave. - Cleaned Line
000	10816049	12/11/12	12/11/12	2.5 hours	0.001		Grit/Debris	1410 Timber Valley - Cleaned Line
000	13316047	12/11/12	12/11/12	2.5 hours	0.001		Roots	299 Penfield Dr. - Cleaned Line
000	09306045	12/13/12	12/13/12	0.75 hours	0.0001		Grit/Debris	127 3rd Ave. S. - Cleaned Line
000	07111098CO	12/13/12	12/13/12	3.75 hours	0.00001		Grit/Debris	1549 Luton St. - Cleanout - Cleaned Line
000	08106097CO	12/13/12	12/13/12	2 hours	0.001		Grit/Debris	2015 26th Ave. N. - Cleanout - Cleaned Line
000	16216020	12/16/12	12/17/12	15 hours	0.001		Grit/Debris	14 Hickory Ct. - Cleaned Line
000	16206093	12/17/12	12/18/12	3 hours	0.00001		Roots	173 Tusculum Rd. Cleaned Line
000	09613013	12/18/12	12/18/12	4.5 hours	0.001		Roots	429 Donelson Pk. - Cleaned Line
000	12014027	12/19/12	12/19/12	1 hours	0.00001		Grit/Debris	329 Forrester Dr. - Cleaned Line
000	09510050	12/26/12	12/26/12	1.5 hours	0.001		Rainfall	501 Bismark Dr.
000	08614062CO	12/30/12	12/30/12	1.5 hours	0.001		Grit/Debris	3160 Lake Dr. - Cleanout - Cleaned Line
102	Smith Springs PS	12/26/12	12/26/12	1.42 hours	0.102	1.39	Rainfall	Infiltration/Inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: December, 2012

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
117	Neely's Bend PS	12/26/12	12/26/12	6.75 hours	0.3	1.16	Rainfall	Infiltration/Inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: December, 2012

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	11605016	12/27/12	12/27/12	2.5 hours	0.0001		Grit/Debris	212 Olive Branch Rd. - Cleaned Line
104	Whites Creek PS	12/10/12	12/11/12	29.59 hours	4.271	1.80	Rainfall	Infiltration/Inflow. Station at rated capacity.
104	Whites Creek PS	12/26/12	12/27/12	22.25 hours	3.115	0.92	Rainfall	Infiltration/Inflow. Station at rated capacity.
104	Whites Creek PS	12/29/12	12/30/12	27.17 hours	3.887	0.85	Rainfall	Infiltration/Inflow. Station at rated capacity.
114	Davidson Branch PS	12/10/12	12/10/12	4.75 hours	0.081	1.99	Rainfall	Infiltration/Inflow. Station at rated capacity.
114	Davidson Branch PS	12/26/12	12/26/12	3.17 hours	0.013	0.91	Rainfall	Infiltration/Inflow. Station at rated capacity.
114	Davidson Branch PS	12/29/12	12/29/12	1.75 hours	0.013	0.94	Rainfall	Infiltration/Inflow. Station at rated capacity.
145	Joelton PS	12/09/12	12/10/12	16 hours	0.1	3.15	Rainfall	Infiltration/Inflow. Station at rated capacity.
145	Joelton PS	12/28/12	12/29/12	10 hours	0.1	1.38	Rainfall	Infiltration/Inflow. Station at rated capacity.