

# Monthly Overflow Report

Date Range: January, 2013

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	14702048	01/13/13	01/13/13	3 hours	0.0001	1.59	Rainfall	420 Coventry Dr.
000	08602058	01/13/13	01/13/13	6 hours	0.001	2.63	Rainfall	428 Old Lebanon Dirt Rd.
000	11706061CO	01/13/13	01/13/13	0.5 hours	0.001	1.42	Rainfall	2857 Wellesley Dr. - Clean out
000	08312050	01/13/13	01/13/13	3.5 hours	0.0001	2.56	Rainfall	2600 Brittany Dr. - Basement
000	07309066	01/13/13	01/14/13	28 hours	0.1	2.56	Rainfall	2301 Cooper Ter.
000	09510050	01/13/13	01/14/13	38 hours	0.1	2.66	Rainfall	501 Bismark Dr.
000	08606106	01/14/13	01/14/12	3 hours	0.001	2.66	Rainfall	5289 Old Hickory Blvd.
000	10616031	01/16/13	01/16/13	3.5 hours	0.001	1.02	Rainfall	416 Hollydale Dr.
000	09510050	01/16/13	01/16/13	22 hours	0.1	1.03	Rainfall	501 Bismark Dr.
000	06304015	01/18/13	01/18/13	11 hours	0.001		Line Break	118 Mt. Vernon Dr. - Repaired Line
000	17308018CO	01/20/13	01/20/13	6.5 hours	0.001		Grit/Debris	1153 Streamdale Pointe - Clean out - Cleaned Line
000	08313015	01/25/13	01/25/13	1 hours	0.001	0.42	Grit/Debris	3400 John Merritt Blvd. - Cleaned Line
000	WMN030E004	01/29/13	01/29/13	1 hours	0.001		Grit/Debris	502 N. Woods Ct. - Cleaned Line
000	08401060	01/30/13	01/30/13	1.25 hours	0.0001	0.99	Grit/Debris	1218 Rosebank Ave. (building backup) Cleaned
102	Smith Springs PS	01/13/13	01/14/13	17.5 hours	1.866	1.79	Rainfall	Infiltration/Inflow. Station at rated capacity.
102	Smith Springs PS	01/16/13	01/16/13	12.5 hours	1.069	1.06	Rainfall	Infiltration/Inflow. Station at rated capacity.
103	McCrary Creek PS	01/13/13	01/14/13	9.5 hours	0.213	2.66	Rainfall	Infiltration/Inflow. Station at rated capacity.
103	McCrary Creek PS	01/16/13	01/16/13	0.75 hours	0.002	0.37	Rainfall	Infiltration/Inflow. Station at rated capacity.
103	McCrary Creek PS	01/29/13	01/29/13	0.1 hours	0.000005	0.00	Mechanical	Station shutdown replaced faulty discharge header valve.
103	McCrary Creek PS	01/30/13	01/30/13	0.5 hours	0.0003	1.51	Rainfall	Infiltration/Inflow. Station at rated capacity.
124	Williamson Ferry PS	01/13/13	01/13/13	9 hours	0.583	2.56	Rainfall	Infiltration/Inflow. Station at rated capacity.
130	Brown's Creek PS / Visco Dr.	01/13/13	01/15/13	35.08 hours	5.073	3.25	Rainfall	Infiltration/Inflow. Station at rated capacity.
131	Hurricane Creek PS	01/13/13	01/13/13	1 hours	0.5	1.28	Rainfall	Infiltration/Inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	01/13/13	01/13/13	8.83 hours	1.239	2.76	Rainfall	Infiltration/Inflow. Station at rated capacity.
158	Farmingham Woods PS	01/12/13	01/14/13	20.75 hours	0.6	4.76	Rainfall	Infiltration/Inflow. Station at rated capacity.
176	Dodson Chapel PS	01/13/13	01/13/13	1.58 hours	0.005	2.63	Rainfall	Infiltration/Inflow. Station at rated capacity. EQ basin full.

# Monthly Overflow Report

Date Range: January, 2013

178	East Lakemont PS	01/13/13	01/14/13	7 hours	0.1	1.97	Rainfall	Infiltration/Inflow. Station at rated capacity.
179	Fairway Center PS	01/13/13	01/14/13	10.25 hours	0.25	2.84	Rainfall	Infiltration/Inflow. Station at rated capacity.
183	Mill Creek PS	01/13/13	01/14/13	11 hours	0.1	2.34	Rainfall	Infiltration/Inflow. Station at rated capacity.
188	South Oak Hill PS	01/13/13	01/13/13	1.75 hours	0.05	1.97	Rainfall	Infiltration/Inflow. Station at rated capacity.
189	Langford Farms PS	01/13/13	01/13/13	6.25 hours	0.1	1.99	Rainfall	Infiltration/Inflow. Station at rated capacity.
190	Towne Village PS	01/13/13	01/13/13	1 hours	0.005	1.73	Rainfall	Infiltration/Inflow. Station at rated capacity.
222	Barker Road	01/13/13	01/18/13	108.34 hours	47.022	3.69	Rainfall	Infiltration/Inflow. EQ Basin Full.
222	Barker Road	01/30/13	01/30/13	2.42 hours	0.167	1.51	Rainfall	Infiltration/Inflow. EQ Basin Full.
226	Cowan St. Relief Bleeder	01/13/13	01/14/13	16.42 hours	1.42	2.56	Rainfall	Infiltration/Inflow. Station at rated capacity.
309	Omohundro Dr.-under RR br	01/14/13	01/14/13	3 hours	0.001	2.38	Rainfall	1400 Pumping Station Rd.
309	Omohundro Dr.-under RR br	01/16/13	01/16/13	4 hours	0.001	0.87	Rainfall	1400 Pumping Station Rd.
311	Omohundro Dr.-E of RR brg	01/14/13	01/14/13	4 hours	0.001	2.38	Rainfall	0 Cave Rd.
311	Omohundro Dr.-E of RR brg	01/16/13	01/16/13	4 hours	0.001	0.87	Rainfall	0 Cave Rd.
328	Cooper Lane	01/13/13	01/14/13	28 hours	0.01	2.56	Rainfall	3811 Moss Rd. (Also known as Cooper Lane)
371	Apex Ave.	01/13/13	01/15/13	47 hours	0.001	2.56	Rainfall	Apex Ave. - drains to Washington CSS basin

# Monthly Overflow Report

Date Range: January, 2013

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	04315003	01/05/13	01/05/13	1.5 hours	0.00001		Grit/Debris	102 Wychewood Cv. - Cleaned Line
000	04312001	01/28/13	01/28/13	0.5 hours	0.0001		Line Problem	300 Rio Vista Dr. - Cleaned Line
106	Vandiver PS	01/13/13	01/14/13	16.67 hours	1.76	2.81	Rainfall	Infiltration/Inflow. Station at rated capacity.
109	Dry Creek PS	01/13/13	01/15/13	5.75 hours	1.396	5.24	Rainfall	1.18" rain on the 12th
110	Loves Branch PS	01/13/13	01/14/13	14 hours	1.749	5.24	Rainfall	Infiltration/Inflow. Station at rated capacity.
112	Gibson Creek PS	01/13/13	01/14/13	5.17 hours	0.698	5.24	Rainfall	Infiltration/Inflow. Station at rated capacity.
117	Neely's Bend PS	01/13/13	01/14/13	26 hours	1	4.44	Rainfall	Infiltration/Inflow. Station at rated capacity.
127	Madison Heights PS	01/13/13	01/13/13	11 hours	0.2	4.44	Rainfall	Infiltration/Inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	01/13/13	01/13/13	14 hours	0.2	4.44	Rainfall	Infiltration/Inflow. Station at rated capacity.
150	Hidden Acres PS	01/13/13	01/13/13	9.5 hours	0.8	4.44	Rainfall	Infiltration/Inflow. Station at rated capacity.
303	N. Dupont Avenue	01/13/13	01/14/13	15 hours	0.001	5.24	Rainfall	600 Delaware Ave. (AKA N. DuPont Ave)

# Monthly Overflow Report

Date Range: January, 2013

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	13007024	01/13/13	01/14/13	7 hours	0.001	1.42	Rainfall	4302 Harding Rd.
000	06001013	01/13/13	01/14/13	23 hours	0.1	2.56	Rainfall	3258 Brick Church Pk.
000	05911027	01/13/13	01/13/13	7 hours	0.001	2.55	Rainfall	700 Rowan Dr. - also manhole 05911036
000	09012110	01/13/13	01/14/13	29 hours	0.01	3.28	Rainfall	6303 Henry Ford Dr.
000	06008011CO	01/30/13	01/30/13	1 hours	0.001	0.99	Grit/Debris	212 Broadmoor Dr. Clean out - Cleaned Line
000	13007002	01/30/13	01/31/13	25 hours	0.1	1.27	Rainfall	803 Lynnwood Blvd.
101	Bordeaux Hospital PS	01/13/13	01/13/13	9 hours	0.1	2.76	Rainfall	Infiltration/Inflow. Station at rated capacity.
104	Whites Creek PS	01/10/13	01/11/13	40.5 hours	3.735	0.66	Rainfall	Infiltration/Inflow. Station at rated capacity.
104	Whites Creek PS	01/12/13	01/18/13	135.33 hours	17.176	4.14	Rainfall	Infiltration/Inflow. Station at rated capacity.
104	Whites Creek PS	01/30/13	01/31/13	24.09 hours	2.966	1.09	Rainfall	Infiltration/Inflow. Station at rated capacity.
107	West Park PS	01/13/13	01/14/13	13.42 hours	3.358	3.28	Rainfall	Infiltration/Inflow. Station at rated capacity.
114	Davidson Branch PS	01/10/13	01/10/13	3.92 hours	0.052	0.67	Rainfall	Infiltration/Inflow. Station at rated capacity.
114	Davidson Branch PS	01/13/13	01/14/13	14.92 hours	0.227	3.28	Rainfall	Infiltration/Inflow. Station at rated capacity.
114	Davidson Branch PS	01/15/13	01/16/13	9.91 hours	0.029	0.73	Rainfall	Infiltration/Inflow. Station at rated capacity.
114	Davidson Branch PS	01/30/13	01/30/13	3.17 hours	0.03	1.13	Rainfall	Infiltration/Inflow. Station at rated capacity.
126	Cleeces Ferry PS	01/13/13	01/13/13	10.5 hours	0.2	3.27	Rainfall	Infiltration/Inflow. Station at rated capacity.
136	River Drive PS	01/13/13	01/13/13	3.42 hours	0.02	2.76	Rainfall	Infiltration/Inflow. Station at rated capacity.
138	Sunliner PS	01/13/13	01/13/13	5.5 hours	0.2	3.27	Rainfall	Infiltration/Inflow. Station at rated capacity.
145	Joelton PS	01/13/13	01/14/13	22 hours	0.2	1.97	Rainfall	Infiltration/Inflow. Station at rated capacity.
145	Joelton PS	01/30/13	01/30/13	12 hours	0.1	1.55	Rainfall	Infiltration/Inflow. Station at rated capacity.
206	Brookwood Terrace	01/13/13	01/13/13	6 hours	0.001	3.28	Rainfall	47 Brookwood Ter.
217	Basswood Ave.	01/13/13	01/14/13	28.33 hours	2.042	3.28	Rainfall	516 Basswood Ave.
346	3428 Briley/Brick Church	01/13/13	01/13/13	10 hours	0.001	2.56	Rainfall	Briley Park Blvd. N @ Brick Church Ln.
347	3300 Briley/Brick Church	01/13/13	01/13/13	10 hours	0.001	2.56	Rainfall	3300 Briley Park Blvd. S
379	622 Davidson	01/13/13	01/14/13	25 hours	0.001	3.28	Rainfall	also manhole 11507055