

Monthly Overflow Report

Date Range: February, 2013

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	13413084	02/03/13	02/03/13	2 hours	0.00001	0.01	Grit/Debris	271 Garry Dr. - Cleaned Line
000	08303022	02/06/13	02/06/13	1 hours	0.001		Grit/Debris	1301 Porter Rd. - Cleaned Line
000	18305032CO	02/14/13	02/14/13	4 hours	0.00001		Grit/Debris	804 Colo Place (CO)- Removed rock in outlet pipe
143	Heartland Drive SPS	02/18/13	02/18/13	1 hours	0.001	0.00	Controller	Pump relay failed.
176	Dodson Chapel PS	02/01/13	02/01/13	0.92 hours	0.078	0.00	Other/not listed	Blown control fuse

Monthly Overflow Report

Date Range: February, 2013

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
108	River Retreat	02/25/13	02/25/13	2 hours	0.0005	0.00	Air Relief Valve	Broken air relief valve float stem.

Monthly Overflow Report

Date Range: February, 2013

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05904094	02/18/13	02/18/13	1 hours	0.0001	0.31	Grit/Debris	3172 Bridgepoint Dr. - Cleaned line
000	12910024	02/21/13	02/21/13	1 hours	0.001	0.70	Line Break	6607 Ellesmere Rd. - NES Power pole removed
000	05809085	02/24/13	02/24/13	1.25 hours	0.00001		Grit/Debris	2600 Jordon Ridge Dr. - Cleaned Line