

Monthly Overflow Report

Date Range: April, 2013

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	14805012	04/01/13	04/01/13	1.5 hours	0.00001		Roots	3735 Turley Dr. - Cleaned Line
000	13413029	04/03/13	04/03/13	1.5 hours	0.001		Grit/Debris	200 Paragon Mills Rd. - Cleaned Line
000	09204004CO	04/05/13	04/05/13	1.5 hours	0.0001		Line Break	1026 Herman St. - Cleaned Line
000	09510050	04/12/13	04/12/13	0.75 hours	0.001	1.89	Rainfall	501 Bismark Dr.
000	08309091CO	04/14/13	04/14/13	2 hours	0.00001		Grit/Debris	1214 Calvin Ave.(Clean out) Cleaned Line
000	14814009	04/18/13	04/18/13	1.5 hours	0.001	0.07	Roots	3963 Keeley Dr. - Cleaned line
000	06411083	04/20/13	04/20/13	1.5 hours	0.0001		Line Break	914 Chase Blvd. Repaired Line
000	10405016	04/27/13	04/28/13	15 hours	0.001	3.57	Rainfall	3704 Murphy Rd.
000	13607014	04/27/13	04/28/13	21 hours	0.01	2.96	Rainfall	3744 Anderson Rd.
000	09510050	04/27/13	04/29/13	52 hours	10	2.95	Rainfall	501 Bismark Dr.
000	08204034	04/28/13	04/28/13	1 hours	0.0001	3.34	Rainfall	820 Seymour Ave
000	11913092	04/28/13	04/28/13	0.5 hours	0.001	3.65	Rainfall	2932 Louise Dr.
000	11903088	04/28/13	04/29/13	21 hours	0.1	3.65	Rainfall	351 Wimpole Dr.
000	08602062	04/28/13	04/28/13	4 hours	0.1	2.95	Rainfall	Old Lebanon Dirt Rd.
000	08606106	04/28/13	04/28/13	4 hours	0.1	2.95	Rainfall	5289 Old Hickory Blvd.
000	07309066	04/28/13	04/29/13	28.5 hours	0.1	3.34	Rainfall	2301 Cooper Tr.
000	07204026	04/28/13	04/28/13	14 hours	0.001	3.34	Rainfall	1434 Ardee Ave.
000	10616031	04/28/13	04/29/13	21 hours	0.1	3.65	Rainfall	416 Hollydale Dr.
000	13413033	04/29/13	04/29/13	0.5 hours	0.0001		Grit/Debris	220 Paragon Mills Rd.
102	Smith Springs PS	04/27/13	04/28/13	35.58 hours	3.588	2.96	Rainfall	Inflow/Infiltration. Station at rated capacity. EQ basins full.
103	McCrary Creek PS	04/27/13	04/28/13	32 hours	1.918	2.95	Rainfall	Inflow/Infiltration. Station at rated capacity.
124	Williamson Ferry PS	04/27/13	04/28/13	22 hours	0.649	3.34	Rainfall	Inflow/Infiltration. Station at rated capacity.
130	Brown's Creek PS	04/28/13	04/29/13	13.5 hours	0.915	3.72	Rainfall	Inflow/Infiltration. Station at rated capacity.
131	Hurricane Creek PS	04/27/13	04/28/13	24 hours	1	4.04	Rainfall	Inflow/Infiltration. Station at rated capacity.
139	The Lakes PS	04/28/13	04/28/13	5.25 hours	0.001	0.00	Force Main	3200 Lincoya Bay Dr. - repaired broken force main
140	28th Avenue PS / Centennial	04/28/13	04/28/13	3.92 hours	0.189	3.71	Rainfall	Infiltration/Inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: April, 2013

158	Farmingham Woods PS	04/27/13	04/28/13	34.25 hours	1	2.95	Rainfall	Inflow/Infiltration. Station at rated capacity.
160	Banbury Crossing SPS	04/10/13	04/10/13	0.1 hours	0.000005	0.00	Mechanical	Overflow recovered.
176	Dodson Chapel PS	04/28/13	04/28/13	3.5 hours	0.121	2.95	Rainfall	Inflow/Infiltration. Station at rated capacity.
178	East Lakemont PS	04/27/13	04/28/13	9 hours	0.1	3.15	Rainfall	Inflow/Infiltration. Station at rated capacity.
183	Mill Creek PS	04/28/13	04/29/13	32 hours	0.3	2.83	Rainfall	Inflow/Infiltration. Station at rated capacity.
184	Munn Rd PS	04/28/13	04/28/13	1.5 hours	0.04	2.83	Rainfall	Inflow/Infiltration. Station at rated capacity.
189	Langford Farms PS	04/28/13	04/28/13	5 hours	0.1	4.42	Rainfall	Inflow/Infiltration. Station at rated capacity.
222	Barker Road	04/11/13	04/13/13	21.66 hours	0.855	1.89	Rainfall	Inflow/Infiltration. Station at rated capacity. EQ basin full.
222	Barker Road	04/27/13	05/01/13	35.51 hours	11.338	2.95	Rainfall	Infiltration/Inflow. EQ basin full. High River Hold
226	Cowan St. Relief Bleeder	04/11/13	04/12/13	17.42 hours	0.756	2.12	Rainfall	Inflow/Infiltration. Station at rated capacity.
226	Cowan St. Relief Bleeder	04/27/13	04/28/13	20.42 hours	1.535	3.34	Rainfall	Inflow/Infiltration. Station at rated capacity.
309	Omohundro Dr.-under RR br	04/28/13	04/28/13	2 hours	0.001	3.72	Rainfall	1400 Pumping Station Rd.
328	Cooper Lane	04/28/13	04/29/13	28.5 hours	0.1	3.34	Rainfall	2800 Cooper Ln.
371	Apex Ave.	04/28/13	04/29/13	24 hours	0.001	3.34	Rainfall	889 Granada Ave,
374	Foster Ave	04/28/13	04/28/13	0.5 hours	0.00001	3.65	Rainfall	2803 Foster Ave

Monthly Overflow Report

Date Range: April, 2013

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04414025CO	04/12/13	04/12/13	2 hours	0.00001		Grease	238 Martingale Dr. (Clean out) - Cleaned Line
000	03314052	04/26/13	04/26/13	2.5 hours	0.0001		Grit/Debris	204 Fonnice Dr.
000	03413034	04/27/13	04/28/13	2 hours	0.001	4.28	Rainfall	1442 Gallatin Rd.
106	Vandiver PS	04/11/13	04/11/13	4.33 hours	0.03	2.18	Rainfall	Inflow/Infiltration. Station at rated capacity.
106	Vandiver PS	04/27/13	04/28/13	25.84 hours	2.227	4.54	Rainfall	Inflow/Infiltration. Station at rated capacity.
109	Dry Creek PS	04/27/13	04/28/13	4.5 hours	5.132	4.28	Rainfall	Infiltration/Inflow. Station at rated capacity.
110	Loves Branch PS	04/11/13	04/11/13	2.67 hours	0.097	2.10	Rainfall	Inflow/Infiltration. Station at rated capacity.
110	Loves Branch PS	04/27/13	04/28/13	19.92 hours	1.618	4.28	Rainfall	Inflow/Infiltration. Station at rated capacity.
112	Gibson Creek PS	04/11/13	04/11/13	4 hours	0.526	2.10	Rainfall	Inflow/Infiltration. Station at rated capacity.
112	Gibson Creek PS	04/27/13	04/28/13	9.16 hours	1.327	4.28	Rainfall	Inflow/Infiltration. Station at rated capacity.
117	Neely's Bend PS	04/11/13	04/11/13	4.5 hours	0.2	2.10	Rainfall	Inflow/Infiltration. Station at rated capacity.
117	Neely's Bend PS	04/27/13	04/28/13	12.5 hours	0.5	4.28	Rainfall	Inflow/Infiltration. Station at rated capacity.
127	Madison Heights PS	04/11/13	04/11/13	5 hours	0.1	2.10	Rainfall	Inflow/Infiltration. Station at rated capacity.
127	Madison Heights PS	04/27/13	04/28/13	14 hours	0.5	4.28	Rainfall	Inflow/Infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	04/11/13	04/11/13	4 hours	0.1	2.10	Rainfall	Inflow/Infiltration. Station at rated capacity.
132	Berwick Trail PS / Center St.	04/27/13	04/28/13	18 hours	0.5	4.28	Rainfall	Inflow/Infiltration. Station at rated capacity.
150	Hidden Acres PS	04/27/13	04/29/13	12 hours	1	4.16	Rainfall	Inflow/Infiltration. Station at rated capacity.
169	Lakemeade PS #2	04/28/13	04/28/13	0.5 hours	0.01	4.42	Rainfall	Inflow/Infiltration. Station at rated capacity.
303	N. Dupont Avenue	04/27/13	04/27/13	1 hours	0.0001	4.28	Rainfall	600 Delaware Ave.

Monthly Overflow Report

Date Range: April, 2013

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05816022	04/08/13	04/08/13	1 hours	0.001		Grit/Debris	3810 Kings Lane - Cleaned Line
000	06007003	04/15/13	04/15/13	1.5 hours	0.001		Grit/Debris	0 Ewing Dr. - Cleaned Line
000	11507005	04/27/13	04/27/13	3 hours	0.001	3.48	Rainfall	615 Georgetown
000	13007002	04/27/13	04/28/13	2 hours	0.001	3.15	Rainfall	4303 Harding Pl.
000	13007005	04/27/13	04/28/13	2 hours	0.001	3.15	Rainfall	4013 Harding Pl.
000	06001011	04/28/13	04/28/13	12 hours	0.001	3.48	Rainfall	3258 Brick Church Pk.
000	05910048	04/28/13	04/28/13	2 hours	0.001	3.71	Rainfall	751 Rowan Dr.
000	09012110	04/28/13	04/28/13	3 hours	0.001	3.71	Rainfall	6303 Henry Ford Dr.
101	Bordeaux Hospital PS	04/27/13	04/28/13	2.5 hours	0.05	3.71	Rainfall	Inflow/Infiltration. Station at rated capacity.
104	Whites Creek PS	04/11/13	04/13/13	47.25 hours	6.806	2.16	Rainfall	Inflow/Infiltration. Station at rated capacity.
104	Whites Creek PS	04/19/13	04/19/13	2.08 hours	0.007	1.12	Rainfall	Inflow/Infiltration. Station at rated capacity.
104	Whites Creek PS	04/27/13	04/28/13	28.59 hours	3.221	3.71	Rainfall	Inflow/Infiltration. Station at rated capacity.
107	West Park PS	04/27/13	04/28/13	7.16 hours	1.233	3.71	Rainfall	Inflow/Infiltration. Station at rated capacity. EQ Basin full.
114	Davidson Branch PS	04/11/13	04/12/13	7.58 hours	0.047	2.37	Rainfall	Inflow/Infiltration. Station at rated capacity.
114	Davidson Branch PS	04/27/13	04/29/13	5.42 hours	0.043	3.71	Rainfall	Inflow/Infiltration. Station at rated capacity.
126	Cleeces Ferry PS	04/11/13	04/11/13	3.5 hours	0.1	2.37	Rainfall	Inflow/Infiltration. Station at rated capacity.
126	Cleeces Ferry PS	04/27/13	04/28/13	7 hours	0.2	3.71	Rainfall	Inflow/Infiltration. Station at rated capacity.
138	Sunliner PS	04/11/13	04/11/13	30 hours	0.01	2.37	Rainfall	Inflow/Infiltration. Station at rated capacity.
138	Sunliner PS	04/27/13	04/28/13	1 hours	0.05	3.55	Rainfall	Inflow/Infiltration. Station at rated capacity.
145	Joelton PS	04/11/13	04/12/13	17 hours	0.1	2.74	Rainfall	Inflow/Infiltration. Station at rated capacity.
145	Joelton PS	04/27/13	04/28/13	35 hours	0.3	5.21	Rainfall	Inflow/Infiltration. Station at rated capacity.
206	Brookwood Terrace	04/27/13	04/28/13	2 hours	0.001	3.71	Rainfall	47 Brookwood Ter.
217	Basswood Ave.	04/11/13	04/11/13	5 hours	0.103	2.37	Rainfall	516 Basswood Dr.
217	Basswood Ave.	04/27/13	04/28/13	29.5 hours	1.36	3.71	Rainfall	516 Basswood Rd.
337	Richland Creek (TDOT)	04/28/13	04/29/13	30 hours	0.5	3.71	Rainfall	6601 Centennial Blvd. (TDOT)
340	Lynnwood Boulevard	04/11/13	04/11/13	1 hours	0.0001	2.37	Rainfall	718 Lynnwood Blvd.

Monthly Overflow Report

Date Range: April, 2013

340	Lynnwood Boulevard	04/27/13	04/27/13	2 hours	0.001	3.15	Rainfall	718 Lynnwood Blvd.
346	3428 Briley/Brick Church	04/27/13	04/28/13	12 hours	0.001	3.48	Rainfall	3438 Briley Park Blvd. N.
347	3300 Briley/Brick Church	04/27/13	04/28/13	12 hours	0.001	3.48	Rainfall	3300 Briley Park Blvd. S
379	622 Davidson	04/11/13	04/11/13	1 hours	0.0001	2.37	Rainfall	622 Davidson Rd.
379	622 Davidson	04/27/13	04/27/13	3 hours	0.001	3.48	Rainfall	622 Davidson Rd.