

# Monthly Overflow Report

Date Range: May, 2013

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	12009007	05/05/13	05/05/13	1.5 hours	0.0001	0.08	Grit/Debris	601 McDonald Ct - Cleaned Line
000	14712013	05/08/13	05/09/13	3.75 hours	0.001	0.07	Grit/Debris	4750 Nolensville Pike - Cleaned Line
000	13409048	05/08/13	05/08/13	3 hours	0.0001	0.05	Grit/Debris	3521 Paragon Drive - Cleaned Line
000	11902062	05/11/13	05/11/13	2 hours	0.0001	0.02	Grit/Debris	84 Peachtree Street - Cleaned Line
000	13215002CO	05/11/13	05/11/13	4 hours	0.0001	0.02	Grit/Debris	4280 Sidco Drive (Clean out) - Cleaned Line
000	14803038CO	05/16/13	05/16/13	1.25 hours	0.0001		Roots	3326 Ezell Road (Clean Out) - Cleaned Line
000	16307016	05/21/13	05/21/13	2.5 hours	0.001	0.27	Grit/Debris	O Bell Rd. - Cleaned Line
000	10408139	05/26/13	05/26/13	1.25 hours	0.0001		Grit/Debris	1211 Medical Center Drive - Cleaned Line
000	18105008	05/31/13	05/31/13	0.5 hours	0.001		Grit/Debris	6444 Nolensville Pike - Cleaned Line
222	Barker Road	05/04/13	05/05/13	26.75 hours	6.41	1.70	Controller	Ultrasonic level detector failed.

---

# Monthly Overflow Report

Date Range: May, 2013

---

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
112	Gibson Creek PS	05/05/13	05/05/13	0.58 hours	0.035	1.63	Rainfall	Infiltration/Inflow. Station at rated capacity.

# Monthly Overflow Report

Date Range: May, 2013

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	03113036	05/27/13	05/27/13	3.5 hours	0.001		Grit/Debris	4375 Summertime Dr. - Cleaned Line
000	07009014	05/30/13	05/30/13	1 hours	0.001		Grit/Debris	3217 Lincoln Ave. - Cleaned Line
104	Whites Creek PS	05/05/13	05/05/13	12 hours	0.471	1.53	Rainfall	Infiltration/Inflow. Station at rated capacity.
114	Davidson Branch PS	05/04/13	05/04/13	2.67 hours	0.027	1.54	Rainfall	Infiltration/Inflow. Station at rated capacity.
145	Joelton PS	05/04/13	05/04/13	1 hours	0.01	1.24	Rainfall	Infiltration/Inflow. Station at rated capacity.