

Monthly Overflow Report

Date Range: July, 2013

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	13607014	07/06/13	07/06/13	8.5 hours	0.001	4.02	Rainfall	117 Timber Ridge Dr.
000	11907145	07/06/13	07/06/13	1 hours	0.001	4.23	Rainfall	747 Old Glenrose Ave.
000	11911101	07/08/13	07/08/13	1.25 hours	0.0001	0.08	Roots	32 E. Thompson Ln. - Cleaned Line
000	10807019	07/22/13	07/22/13	3 hours	0.001	0.47	Grit/Debris	3108 Elm Hill Pk. - Cleaned Line
102	Smith Springs PS	07/06/13	07/07/13	14.66 hours	0.732	3.83	Rainfall	Infiltration/Inflow. Station at rated capacity. EQ full.
222	Barker Road	07/07/13	07/07/13	0.67 hours	0.003	3.49	Rainfall	EQ full.

Monthly Overflow Report

Date Range: July, 2013

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume		Rainfall	Overflow Cause	Remarks
					(mg)				
Sanitary Sewer Overflows									
106	Vandiver PS	07/06/13	07/06/13	3.33 hours	0.008	3.88	Rainfall	Infiltration/Inflow.	Station at rated capacity.
109	Dry Creek PS	07/05/13	07/06/13	4.33 hours	0.161	4.32	Rainfall	Infiltration/Inflow.	Station at rated capacity.
117	Neely's Bend PS	07/06/13	07/06/13	0.5 hours	0.05	2.31	Rainfall	Infiltration/Inflow.	Station at rated capacity.

Monthly Overflow Report

Date Range: July, 2013

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05010033	07/05/13	07/06/13	12 hours	0.01	5.85	Rainfall	3414 Brick Church Pk.
000	05911028	07/06/13	07/06/13	12 hours	0.001	4.97	Rainfall	709 Rowan Dr.
000	09004030	07/06/13	07/07/13	7 hours	0.1	4.68	Rainfall	6514 Robertson Rd.
000	06001013	07/06/13	07/07/13	11 hours	0.01	5.85	Rainfall	3258 Brick Church Pk.
000	05911027	07/06/13	07/06/13	12 hours	0.001	4.97	Rainfall	701 Rowan Dr.
000	05910048	07/06/13	07/06/13	12 hours	0.001	4.97	Rainfall	751 Rowan Dr.
104	Whites Creek PS	07/05/13	07/08/13	60.75 hours	6.797	5.04	Rainfall	Infiltration/Inflow. Station at rated capacity.
104	Whites Creek PS	07/11/13	07/12/13	16.42 hours	0.939	1.09	Rainfall	Infiltration/Inflow. Station at rated capacity.
104	Whites Creek PS	07/22/13	07/23/13	10.17 hours	0.52	0.70	Rainfall	Infiltration/Inflow. Station at rated capacity.
104	Whites Creek PS	07/31/13	07/31/13	4.42 hours	0.034	1.26	Rainfall	Infiltration/Inflow. Station at rated capacity.
107	West Park PS	07/06/13	07/06/13	1.42 hours	0.155	4.68	Rainfall	Infiltration/Inflow. Station at rated capacity. EQ full.
114	Davidson Branch PS	07/05/13	07/05/13	4.17 hours	0.105	4.68	Rainfall	Infiltration/Inflow. Station at rated capacity.
114	Davidson Branch PS	07/10/13	07/10/13	2.58 hours	0.046	1.62	Rainfall	Infiltration/Inflow. Station at rated capacity.
126	Cleeces Ferry PS	07/05/13	07/05/13	1 hours	0.1	2.52	Rainfall	Infiltration/Inflow. Station at rated capacity.
138	Sunliner PS	07/20/13	07/20/13	1 hours	0.01	2.69	Rainfall	Infiltration/Inflow. Station at rated capacity.
145	Joelton PS	07/05/13	07/06/13	28 hours	0.1	3.35	Rainfall	Infiltration/Inflow. Station at rated capacity.
217	Basswood Ave.	07/05/13	07/06/13	5.33 hours	0.115	4.68	Rainfall	516 Basswood Dr.
337	Richland Creek (TDOT)	07/06/13	07/07/13	7 hours	0.1	4.68	Rainfall	6601 Centennial Blvd.
346	3428 Briley/Brick Church	07/05/13	07/06/13	12 hours	0.01	5.85	Rainfall	3428 Briley Park Blvd. N
347	3300 Briley/Brick Church	07/05/13	07/07/13	12 hours	0.01	5.85	Rainfall	3300 Briley Park Blvd.