

Monthly Overflow Report

Date Range: August, 2013

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	14703015	08/02/13	08/02/13	1.2 hours	0.0001		Grit/Debris	308 Wallace Rd. - Cleaned Line
000	08311050	08/08/13	08/09/13	1.5 hours	0.000001	5.25	Grease	704 Newhall Dr. - Building backup
000	07309066	08/08/13	08/09/13	12 hours	0.001	5.25	Rainfall	2301 Cooper Ter.
000	08603180	08/08/13	08/09/13	19 hours	0.001	7.80	Rainfall	4120 Andrew Jackson Pkwy
000	08301017	08/08/13	08/09/13	13 hours	0.001	7.80	Rainfall	913 Sharpe Ave.
000	08602060	08/08/13	08/09/13	19 hours	0.1	7.80	Rainfall	428 Old Lebanon Dirt Rd.
000	07210029	08/08/13	08/09/13	21 hours	0.001	5.25	Grit/Debris	2624 Gallatin Pk. - Cleaned Line
000	08311078	08/08/13	08/08/13	1.1 hours	0.001	5.25	Grease	2412 Brittany Dr. - Cleaned Line
000	13413063	08/16/13	08/16/13	4.5 hours	0.00001		Line Break	4818 Jeffery Dr. - Repaired line
000	14810009	08/26/13	08/26/13	1 hours	0.001		Grit/Debris	3904 Apache Tr.- Cleaned line - (Dip in pipe)
000	14909015	08/30/13	08/30/13	4 hours	0.00001		Grease	216 Manatee Ct.
103	McCroy Creek PS	08/08/13	08/08/13	6 hours	0.178	2.93	Rainfall	Infiltration/Inflow. Station at rated capacity.
124	Williamson Ferry PS	08/08/13	08/08/13	11.33 hours	0.945	5.25	Rainfall	Infiltration/Inflow. Station at rated capacity.
130	Brown's Creek PS	08/17/13	08/17/13	0.5 hours	0.105	0.03	VFD or Soft Start	Power outage caused fuses to blow in VFDs.
140	28th Avenue PS / Centennial	08/08/13	08/08/13	1.83 hours	0.148	4.24	Rainfall	Infiltration/Inflow. Station at rated capacity.
158	Farmingham Woods PS	08/08/13	08/09/13	17 hours	1	2.93	Rainfall	Infiltration/Inflow. Station at rated capacity.
176	Dodson Chapel PS	08/08/13	08/08/13	5.83 hours	0.239	2.93	Rainfall	Infiltration/Inflow. Station at rated capacity. EQ full.
179	Fairway Center PS	08/08/13	08/08/13	10.75 hours	0.3	3.95	Rainfall	Infiltration/Inflow. Station at rated capacity.
184	Munn Rd PS	08/08/13	08/08/13	2 hours	0.05	2.93	Rainfall	Infiltration/Inflow. Station at rated capacity.
189	Langford Farms PS	08/08/13	08/08/13	9 hours	0.5	7.80	Rainfall	Infiltration/Inflow. Station at rated capacity.
222	Barker Road	08/08/13	08/08/13	7.5 hours	0.527	2.93	Rainfall	149 Barker Rd.
226	Cowan St. Relief Bleeder	08/08/13	08/09/13	27.3 hours	1.717	5.25	Rainfall	Infiltration/Inflow. Station at rated capacity.
328	Cooper Lane	08/08/13	08/09/13	12 hours	0.001	5.25	Rainfall	
371	Apex Ave.	08/08/13	08/09/13	13 hours	0.001	5.25	Rainfall	
383	Holiday Travel	08/08/13	08/08/13	3.75 hours	0.01	2.93	Rainfall	

Monthly Overflow Report

Date Range: August, 2013

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	03413034	08/08/13	08/09/13	18.5 hours	0.001	4.68	Rainfall	1450 Gallatin Pk.
000	05208046	08/08/13	08/09/13	4.5 hours	0.000001	7.80	Rainfall	1412 Pelican Pt. - Building Backup
000	03414016CO	08/08/13	08/09/13	23 hours	0.001	7.80	Rainfall	307 Dinwiddie Dr.- overflow at cleanout
000	03414016CO	08/08/13	08/09/13	23 hours	0.001	7.80	Rainfall	309 Dinwiddie Dr. - Overflow at cleanout
000	04316039	08/08/13	08/09/13	4.5 hours	0.000001	7.80	Rainfall	2108 Laguna Bay - Building Backup
000	05311008	08/08/13	08/09/13	6 hours	0.001	7.80	Rainfall	126 Park Cir.
000	04411038	08/08/13	08/09/13	4 hours	0.0001	7.80	Rainfall	42 Jones Cir. - Building Backup (bathtub)
000	04314019	08/08/13	08/09/13	12 hours	0.00001	7.80	Rainfall	538 Maple St. - Building Backup (Bathtub)
000	04216022	08/08/13	08/09/13	4 hours	0.001	7.80	Rainfall	103 Woodruff St.
000	04414044	08/08/13	08/09/13	4 hours	0.0001	7.80	Rainfall	710 Fowle St.- Building Backup (bathtub)
000	04313124	08/09/13	08/09/13	1.5 hours	0.00001	7.80	Rainfall	127 Maple St. - Building Backup (commode)
106	Vandiver PS	08/08/13	08/08/13	17.5 hours	2.379	7.80	Rainfall	Infiltration/Inflow. Station at rated capacity.
108	River Retreat	08/08/13	08/08/13	4.5 hours	0.5	7.80	VFD or Soft Start	Electrical outage caused soft starts to lock up.
109	Dry Creek PS	08/08/13	08/09/13	19.84 hours	26.556	7.80	Rainfall	Infiltration/Inflow. Station at rated capacity.
110	Loves Branch PS	08/08/13	08/09/13	34.33 hours	3.096	7.80	Rainfall	Infiltration/Inflow. Station at rated capacity.
112	Gibson Creek PS	08/08/13	08/08/13	13.75 hours	2.542	7.80	Rainfall	Infiltration/Inflow. Station at rated capacity.
117	Neely's Bend PS	08/08/13	08/09/13	25.5 hours	1	7.80	Rainfall	Infiltration/Inflow. Station at rated capacity.
127	Madison Heights PS	08/08/13	08/08/13	13 hours	0.5	7.80	Rainfall	Infiltration/Inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	08/08/13	08/08/13	11 hours	0.5	7.80	Rainfall	Infiltration/Inflow. Station at rated capacity.
146	Pawnee Trail PS	08/08/13	08/08/13	3.25 hours	0.02	7.80	Rainfall	Inflow/Infiltration. Station at rated capacity.
150	Hidden Acres PS	08/08/13	08/08/13	1 hours	0.1	7.80	Rainfall	Infiltration/Inflow. Station at rated capacity.
169	Lakemeade PS #2	08/08/13	08/09/13	4.75 hours	0.1	7.80	Rainfall	Infiltration/Inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: August, 2013

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	02916003	08/06/13	08/06/13	1.5 hours	0.001	0.05	Grit/Debris	5568 Clarksville Pk. - Cleaned Line
000	06001013	08/08/13	08/09/13	25.5 hours	0.001	6.00	Rainfall	3258 Brick Church Pk.
000	05911058	08/08/13	08/09/13	6 hours	0.001	6.00	Rainfall	706 Rowan Dr.
000	06001011	08/08/13	08/09/13	25.5 hours	0.001	6.00	Rainfall	3414 Brick Church Pk.
000	05910048	08/08/13	08/09/13	6 hours	0.001	6.00	Rainfall	748 Rowan Dr.
000	05911027	08/08/13	08/09/13	6 hours	0.001	6.00	Rainfall	701 Rowan Dr.
000	05910032	08/08/13	08/09/13	6 hours	0.000001	6.00	Rainfall	3899 Crouch Dr.- Building Backup
000	06003022CO	08/08/13	08/09/13	23 hours	0.0001	6.00	Grit/Debris	120 Oak Valley Dr. at Clean out.
101	Bordeaux Hospital PS	08/08/13	08/08/13	4 hours	0.05	4.24	Rainfall	Infiltration/Inflow. Station at rated capacity.
104	Whites Creek PS	08/08/13	08/13/13	94.08 hours	14.452	4.49	Rainfall	Infiltration/Inflow. Station at rated capacity.
104	Whites Creek PS	08/27/13	08/27/13	1.17 hours	0.048	0.00		Due to contractor tie in taking too much time.
114	Davidson Branch PS	08/08/13	08/08/13	1.92 hours	0.003	2.39	Rainfall	Infiltration/Inflow. Station at rated capacity.
128	Bordeaux Hills PS	08/08/13	08/08/13	3 hours	0.01	4.24	Rainfall	Inflow/Infiltration. Station at rated capacity.
136	River Drive PS	08/08/13	08/08/13	0.073 hours	3.5	4.24	Rainfall	Infiltration/Inflow. Station at rated capacity.
145	Joelton PS	08/08/13	08/09/13	19 hours	0.06	3.92	Rainfall	Infiltration/Inflow. Station at rated capacity.
145	Joelton PS	08/09/13	08/10/13	5.5 hours	0.02	4.06	Rainfall	Infiltration/Inflow. Station at rated capacity.
145	Joelton PS	08/12/13	08/13/13	14.5 hours	0.05	0.55	Rainfall	Infiltration/Inflow. Station at rated capacity.
346	3428 Briley/Brick Church	08/08/13	08/09/13	24 hours	0.001	6.00	Rainfall	3428 Briley Park Blvd. N.