

Monthly Overflow Report

Date Range: September, 2013

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	08316013	09/02/13	09/02/13	4 hours	0.001	0.21	Grit/Debris	2708 Fortland Dr. - Cleaned Line
000	14703015	09/04/13	09/04/13	13.5 hours	0.001		Grit/Debris	4190 Nolensville Pk. - Cleaned Line
000	07516126	09/05/13	09/05/13	2 hours	0.0001		Grit/Debris	902 Tulip Grove Rd. - Cleaned Line
000	07112047	09/06/13	09/06/13	4.5 hours	0.00001		Grit/Debris	910 Chickasaw Ave. - Cleaned Line
000	16205029	09/10/13	09/10/13	0.75 hours	0.00001	0.57	Grit/Debris	404 Ocala Ct. - Cleaned Line
000	16303012	09/10/13	09/10/13	4.75 hours	0.001	0.37	Grit/Debris	2900 Hamilton Church Rd. - Cleaned Line
000	09306045	09/14/13	09/14/13	2 hours	0.0001		Grit/Debris	118 4th Ave. S. - Cleaned Line
000	08307046CO	09/19/13	09/19/13	0.5 hours	0.00001		Grit/Debris	321 Tillman Ln. - Cleaned Line. Overflow at cleanout.
000	07210059	09/23/13	09/23/13	2 hours	0.00001		Grit/Debris	1130 Delmas Ave. Cleaned Line
152	Hickory Hills SPS	09/10/13	09/10/13	2.5 hours	0.0003	0.11	Mechanical	Pump coupling blew off. Coupling reconnected.
152	Hickory Hills SPS	09/12/13	09/13/13	24 hours	0.01	0.00	Other/not listed	Operator error. Station returned to service.

Monthly Overflow Report

Date Range: September, 2013

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
104	Whites Creek PS	09/21/13	09/21/13	7.67 hours	0.226	1.67	Rainfall	Inflow/infiltration. Station at rated capacity.