

Monthly Overflow Report

Date Range: November, 2013

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09310146	11/01/13	11/01/13	1.5 hours	0.0001		Grit/Debris	300 4th Ave. S. - Cleaned Line
000	14801064	11/21/13	11/21/13	6.5 hours	0.001		Roots	285 Comroe Rd. - Cleaned Line
000	09206007	11/21/13	11/21/13	2 hours	0.001		Line Break	945 31st Ave. N. - Repaired Line
000	16202045	11/21/13	11/21/13	2.5 hours	0.001		Grease	148 Bart Dr. - Cleaned Line
000	15005099	11/21/13	11/21/13	2 hours	0.001		Grit/Debris	1121 Twin Circle Dr. - Cleaned Line
000	10412001	11/23/13	11/23/13	5.5 hours	0.00001		Line Break	2117 Belcourt Ave. - Repaired Line

Monthly Overflow Report

Date Range: November, 2013

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05308033	11/20/13	11/20/13	4.5 hours	0.001		Grit/Debris	206 24th St. - Cleaned Line
185	Old Hickory PS	11/06/13	11/06/13	4 hours	0.1	0.00	Air Relief Valve	Air relief valve was clogged with debris.

Monthly Overflow Report

Date Range: November, 2013

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05010077CO	11/10/13	11/10/13	1.45 hours	0.0001		Grit/Debris	201 Fawnwood Ct. at Cleanout - Cleaned Line
000	13111024	11/11/13	11/11/13	1 hours	0.001		Grit/Debris	4608 Granny White Pk. - Cleaned Line
000	05915017	11/15/13	11/15/13	2.5 hours	0.0001	0.11	Grit/Debris	3817 Cravath Dr.- Cleaned Line
000	05006010	11/21/13	11/21/13	2.5 hours	0.001		Grease	3438 Briley Park Blvd. N. - Cleaned Line