

# Monthly Overflow Report

Date Range: December, 2013

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	14604023	12/03/13	12/03/13	0.1 hours	0.000001		Roots	717 Harding Pl. - Building Backup - Cleaned Line
000	11911099	12/04/13	12/04/13	5 hours	0.001		Line Break	104 Glenmont Dr. - Cleaned/repared - NES Pole
000	08303022	12/04/13	12/04/13	0.75 hours	0.00001		Grit/Debris	1298 Porter Rd.- repaired
000	09510050	12/06/13	12/07/13	37 hours	0.1	3.78	Rainfall	501 Bismark Dr.
000	11909113	12/06/13	12/06/13	8.5 hours	0.0001	3.55	Rainfall	2803 Foster Ave.
000	11909017	12/06/13	12/06/13	0.1 hours	0.00001	3.55	Grit/Debris	2714 Grandview Ave. Building Backup from cleaning main
000	07309066	12/06/13	12/07/13	4 hours	0.001	2.67	Rainfall	2301 Cooper Ter.
000	16205069	12/08/13	12/08/13	1 hours	0.001	0.50	Grease	285 Ocala Dr. - Cleaned Line
000	16212014	12/12/13	12/12/13	1 hours	0.001		Roots	1211 Bell Rd. - Cleaned Line
000	15005043	12/14/13	12/14/13	0.25 hours	0.0001	0.50	Grit/Debris	3004 Anderson Rd. - Cleaned Line
000	14816066	12/14/13	12/14/13	0.25 hours	0.00001	0.50	Grit/Debris	308 Carrolton Station Rd. - Cleaned Line
000	16003021	12/20/13	12/20/13	1 hours	0.001		Grit/Debris	5322 Overton Road - Cleaned Line
000	07311033	12/21/13	12/21/13	1.5 hours	0.0001	1.40	Grit/Debris	2256 Cabin Hill Road - Cleaned Line
000	07104090	12/22/13	12/22/13	1.5 hours	0.00001	1.35	Grit/Debris	2432 Paulawood Dr. - Cleaned Line
000	14902023	12/26/13	12/27/13	1.5 hours	0.001		Roots	433 London Ct. - Cleaned Line
000	08605112	12/30/13	12/30/13	1.5 hours	0.0001		Grit/Debris	3522 Central Pl. - Big rock - Cleaned Line
102	Smith Springs PS	12/06/13	12/07/13	12.08 hours	1.073	3.05	Rainfall	Infiltration/Inflow. Station at rated capacity. EQ full.
102	Smith Springs PS	12/22/13	12/23/13	12.33 hours	0.996	1.11	Rainfall	Infiltration/Inflow. Station at rated capacity. EQ full.
131	Hurricane Creek PS	12/06/13	12/06/13	3.75 hours	0.25	3.49	Rainfall	Infiltration/Inflow. Station at rated capacity.
158	Farmingham Woods PS	12/06/13	12/06/13	5 hours	0.2	3.87	Rainfall	Infiltration/Inflow. Station at rated capacity.
188	South Oak Hill PS	12/06/13	12/06/13	1 hours	0.06	4.27	Rainfall	Infiltration/Inflow. Station at rated capacity.
222	Barker Road	12/06/13	12/09/13	62.67 hours	15.656	4.37	Rainfall	149 Barker Rd. - EQ basin full.
222	Barker Road	12/22/13	12/23/13	7.08 hours	0.241	1.40	Rainfall	Barker SPS operating normally. EQ did not completely fill.
226	Cowan St. Relief Bleeder	12/06/13	12/06/13	6.75 hours	0.121	2.67	Rainfall	Infiltration/Inflow. Station at rated capacity.
226	Cowan St. Relief Bleeder	12/08/13	12/08/13	1.67 hours	0.003	0.97	Rainfall	Infiltration/Inflow. Station at rated capacity.

# Monthly Overflow Report

Date Range: December, 2013

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	05303084CO	12/22/13	12/22/13	2.75 hours	0.00001	1.36	Grit/Debris	1404 Riverside Rd. - Cleanout - Cleaned Line
106	Vandiver PS	12/06/13	12/06/13	6.83 hours	0.097	2.85	Rainfall	Infiltration/Inflow. Station at rated capacity.
109	Dry Creek PS	12/03/13	12/03/13	0.17 hours	0.004	0.00	Power Related	Electronic malfunction
109	Dry Creek PS	12/06/13	12/07/13	21.67 hours	5.164	2.53	Rainfall	Infiltration/Inflow. Station at rated capacity.
109	Dry Creek PS	12/08/13	12/09/13	18.67 hours	12.764	0.83	Rainfall	Infiltration/Inflow. Station at rated capacity.
110	Loves Branch PS	12/06/13	12/06/13	7.83 hours	0.193	2.53	Rainfall	Infiltration/Inflow. Station at rated capacity.
110	Loves Branch PS	12/08/13	12/08/13	7.42 hours	0.091	0.83	Rainfall	Infiltration/Inflow. Station at rated capacity.
112	Gibson Creek PS	12/06/13	12/06/13	3.42 hours	0.303	2.53	Rainfall	Infiltration/Inflow. Station at rated capacity.
112	Gibson Creek PS	12/08/13	12/08/13	1.08 hours	0.039	0.83	Rainfall	Infiltration/Inflow. Station at rated capacity.
117	Neely's Bend PS	12/06/13	12/07/13	11 hours	0.5	2.53	Rainfall	Infiltration/Inflow. Station at rated capacity.
117	Neely's Bend PS	12/08/13	12/08/13	9 hours	0.5	0.83	Rainfall	Infiltration/Inflow. Station at rated capacity.
127	Madison Heights PS	12/06/13	12/06/13	5.5 hours	0.1	2.53	Rainfall	Infiltration/Inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	12/06/13	12/06/13	10 hours	0.2	2.53	Rainfall	Infiltration/Inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	12/08/13	12/08/13	2 hours	0.05	0.83	Rainfall	Infiltration/Inflow. Station at rated capacity.

# Monthly Overflow Report

Date Range: December, 2013

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	06001013	12/06/13	12/06/13	7.5 hours	0.001	2.75	Rainfall	3258 Brick Church Pk.
000	13007001	12/06/13	12/07/13	27 hours	0.001	3.39	Rainfall	803 Lynnwood Blvd.
000	05010033	12/06/13	12/07/13	13 hours	0.001	2.75	Rainfall	3414 Brick Church Pk.
000	15712023	12/06/13	12/07/13	4.75 hours	0.05	4.27	Rainfall	Old Hickory Blvd.; Backup from 30" Brentwood trunk
000	06001013	12/08/13	12/08/13	10 hours	0.001	2.75	Rainfall	3258 Brick Church Pk.
107	West Park PS	12/06/13	12/06/13	8.92 hours	2.034	2.51	Rainfall	Infiltration/Inflow. Station at rated capacity. EQ full.
107	West Park PS	12/08/13	12/08/13	0.42 hours	0.01	0.87	Rainfall	Infiltration/Inflow. Station at rated capacity. EQ full
114	Davidson Branch PS	12/06/13	12/07/13	4.58 hours	0.051	2.51	Rainfall	Infiltration/Inflow. Station at rated capacity.
114	Davidson Branch PS	12/08/13	12/08/13	2.67 hours	0.002	0.87	Rainfall	Infiltration/Inflow. Station at rated capacity.
114	Davidson Branch PS	12/22/13	12/22/13	4.5 hours	0.018	1.35	Rainfall	Infiltration/Inflow. Station at rated capacity.
145	Joelton PS	12/05/13	12/07/14	3 hours	0.1	2.54	Rainfall	Infiltration/Inflow. Station at rated capacity.
145	Joelton PS	12/08/13	12/08/13	16.5 hours	0.05	0.76	Rainfall	Infiltration/Inflow. Station at rated capacity.
145	Joelton PS	12/22/13	12/22/13	3 hours	0.01	1.37	Rainfall	Infiltration/Inflow. Station at rated capacity.
217	Basswood Ave.	12/06/13	12/07/13	14.08 hours	0.687	2.51	Rainfall	516 Basswood Dr.
217	Basswood Ave.	12/08/13	12/08/13	9.67 hours	0.212	0.87	Rainfall	516 Basswood Dr.
340	Lynnwood Boulevard	12/06/13	12/07/13	27 hours	0.001	3.39	Rainfall	718 Lynnwood Blvd.
346	3428 Briley/Brick Church	12/06/13	12/07/13	24 hours	0.01	2.75	Rainfall	3438 Briley Park Blvd. N.
347	3300 Briley/Brick Church	12/06/13	12/07/13	24 hours	0.01	2.75	Rainfall	3300 Briley Park Blvd. S.