

Monthly Overflow Report

Date Range: January, 2014

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	16106067	01/04/14	01/04/14	1.5 hours	0.0001		Grit/Debris	509 Tobylynn Dr. - Cleaned Line
000	11709079	01/06/14	01/06/14	2.75 hours	0.0001		Grit/Debris	14 Foxhall Close - Cleaned Line
000	15005001CO	01/11/14	01/11/14	1 hours	0.0001	0.99	Grit/Debris	448 Owendale Dr. (Cleanout) - Cleaned Line
000	11908012	01/12/14	01/12/14	0.75 hours	0.0001		Grit/Debris	429 East Thompson Ln.- Cleaned Line
000	08207120	01/12/14	01/12/14	0.75 hours	0.00001		Grit/Debris	590 Joseph Ave. - Cleaned Line
000	06101025	01/14/14	01/14/14	0.75 hours	0.001		Grit/Debris	575 Joyce Ln.- Cleaned Line
000	13414039	01/15/14	01/16/14	2.75 hours	0.001		Grit/Debris	5000 Harding Pl.. Cleaned Line
000	13414039	01/16/14	01/16/14	2.5 hours	0.001	0.02	Grit/Debris	5000 Harding Pl. - Cleaned Line
000	08102062	01/25/14	01/25/14	1.5 hours	0.001		Grit/Debris	2233 24th Ave. N. - Cleaned Line
000	13312061	01/26/14	01/26/14	1.5 hours	0.0001		Roots	217 Brevard Ct.- Cleaned Line (roots & dip in line)
000	09315058	01/30/14	01/30/14	2.25 hours	0.001		Grit/Debris	76 Lafayette St. - Cleaned Line
000	08505108	01/30/14	01/30/14	0.5 hours	0.001		Grit/Debris	3534 Central Pike - Cleaned Line
222	Barker Road	01/11/14	01/11/14	3.42 hours	0.336	0.97	Controller	Technician error. Controller level settings incorrect.
222	Barker Road	01/13/14	01/14/14	7.75 hours	0.721	0.87	Controller	Technician error. Controller level settings incorrect.
226	Cowan St. Relief Bleeder	01/11/14	01/11/14	0.58 hours	0.019	1.08	Rainfall	Infiltration/Inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: January, 2014

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05303062	01/17/14	01/17/14	3 hours	0.001		Grit/Debris	505 15th St. - Cleaned Line
000	04312001	01/30/14	01/30/14	2 hours	0.001		Grit/Debris	0 Rio Vista Drive
117	Neely's Bend PS	01/11/14	01/11/14	8 hours	0.3	1.09	Rainfall	Infiltration/Inflow. Station at rated capacity.
117	Neely's Bend PS	01/13/14	01/15/14	36.5 hours	1.5	1.17	Rainfall	Inflow/infiltration. PS at rated capacity.

Monthly Overflow Report

Date Range: January, 2014

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	14501026	01/10/14	01/10/14	1.5 hours	0.0001	0.04	Roots	5600 Stanford Ct. South - Cleaned Line
000	04101021	01/22/14	01/22/14	0.75 hours	0.001		Grit/Debris	5001 Cobblestone Creek Dr. - Cleaned Line
114	Davidson Branch PS	01/11/14	01/11/14	3.67 hours	0.016	0.97	Rainfall	Infiltration/Inflow. Station at rated capacity.
126	Cleeces Ferry PS	01/14/14	01/14/14	0.5 hours	0.05	0.65	Other/not listed	Operator error. Station controller locked up.
145	Joelton PS	01/11/14	01/11/14	1.5 hours	0.005	0.91	Rainfall	Infiltration/Inflow. Station at rated capacity.