

Monthly Overflow Report

Date Range: March, 2014

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	07303015	03/03/14	03/03/14	1.5 hours	0.001	2.44	Grit/Debris	1719 Welcome Ln. - Cleaned Line
000	10510005	03/03/14	03/03/14	3.25 hours	0.001	2.50	Grit/Debris	832 Wedgewood Ave. - Cleaned Line
000	07303015	03/05/14	03/05/14	3 hours	0.001		Line Break	1719 Welcome Ln.- Repaired line
000	16102005	03/08/14	03/08/14	2 hours	0.001		Roots	5013 Meta Dr - Cleaned Line
000	16212014	03/10/14	03/10/14	1 hours	0.001		Grit/Debris	1211 Bell Rd. - Cleaned Line
000	10616030	03/10/14	03/10/14	1 hours	0.00001		Grit/Debris	1086 Murfreesboro Pk. - Cleaned - Building Backup
000	14808061	03/13/14	03/13/14	1 hours	0.00001		Grit/Debris	4594 Artelia Dr - Cleaned Line
000	08601125	03/13/14	03/13/14	3.25 hours	0.001		Grit/Debris	3453 Central Pk. - Cleaned Line
000	14815022	03/14/14	03/14/14	2 hours	0.001		Grit/Debris	4832 Cimarron Way - Cleaned Line
000	10507059	03/14/14	03/14/14	1 hours	0.0001		Roots	405 Humphreys St. Cleaned Line
000	10412109	03/18/14	03/18/14	0.85 hours	0.001		Grit/Debris	1708 Portland Ave - Cleaned Line
000	13611005	03/24/14	03/24/14	1.5 hours	0.0001		Grit/Debris	3644 Anderson Rd. - Cleaned Line
000	08302003	03/24/14	03/24/14	0.5 hours	0.0001		Grit/Debris	1606 Douglas Ave. - Cleaned Line
000	08106087	03/26/14	03/26/14	0.5 hours	0.001		Grit/Debris	2105 26th Ave. N.- Cleaned Line
000	06409007	03/28/14	03/28/14	1.5 hours	0.00001		Grease	4252 Brackenwood Dr.- Cleaned Line
102	Smith Springs PS	03/03/14	03/03/14	19.75 hours	2.246	2.63	Rainfall	Infiltration/inflow. Station at rated capacity. EQ full.
124	Williamson Ferry PS	03/02/14	03/03/14	3.66 hours	0.077	2.44	Rainfall	Infiltration/inflow. Station at rated capacity.
131	Hurricane Creek PS	03/03/14	03/03/14	2 hours	0.2	2.55	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	03/03/14	03/03/14	2.67 hours	0.064	2.50	Rainfall	Infiltration/inflow. Station at rated capacity.
158	Farmingham Woods PS	03/02/14	03/03/14	9.25 hours	0.3	2.60	Rainfall	Infiltration/inflow. Station at rated capacity.
161	Longhunter Chase SPS	03/03/14	03/03/14	13 hours	0.5	2.63	Rainfall	Infiltration/inflow. Station at rated capacity.
184	Munn Rd PS	03/14/14	03/14/14	3.5 hours	0.01	0.00	None	Station shutdown for force main valve install and main repair.
190	Towne Village PS	03/03/14	03/03/14	2.5 hours	0.01	2.63	Rainfall	Infiltration/inflow. Station at rated capacity.
222	Barker Road	03/03/14	03/04/14	23 hours	3.842	2.62	Rainfall	Infiltration/Inflow. EQ basin full.
226	Cowan St. Relief Bleeder	03/02/14	03/03/14	16.75 hours	0.525	2.44	Rainfall	Infiltration/inflow. Station at rated capacity.
384	501 Bismark Dr.	03/03/14	03/04/14	16.5 hours	0.001	2.60	Rainfall	501 Bismark Dr.

Monthly Overflow Report

Date Range: March, 2014

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04415039	03/25/14	03/25/14	2 hours	0.00001		Grit/Debris	801 Bryan St. Cleaned Line
000	04202013	03/29/14	03/29/14	0.5 hours	0.0001		Line Problem	832 Fonnice Dr. - Contractor cleaning line - Bldg BU
106	Vandiver PS	03/02/14	03/03/14	7.25 hours	0.233	2.34	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	03/02/14	03/03/14	18.08 hours	1.445	2.13	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	03/03/14	03/03/14	4.58 hours	0.587	2.13	Rainfall	Infiltration/inflow. Station at rated capacity.
117	Neely's Bend PS	03/03/14	03/03/14	15 hours	0.6	2.13	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	03/03/14	03/03/14	7.25 hours	0.2	2.13	Rainfall	Infiltration/inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	03/02/14	03/03/14	8 hours	0.2	2.13	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: March, 2014

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09004030	03/02/14	03/04/14	14 hours	0.001	2.26	Rainfall	6601 Centennial Blvd.
000	15809031	03/09/14	03/09/14	3.75 hours	0.0001		Grit/Debris	2101 Old Hickory Blvd - Cleaned - Building Backup
000	13106116	03/27/14	03/27/14	2 hours	0.0001		Roots	1 Burton Hills Blvd. - Cleaned Line
000	10306075CO	03/30/14	03/30/14	1 hours	0.00001		Grit/Debris	100 Rural Dr. (Cleanout) - Cleaned Line
107	West Park PS	03/02/14	03/03/14	3.75 hours	0.164	2.26	Rainfall	Infiltration/inflow. Station at rated capacity. EQ full.
114	Davidson Branch PS	03/03/14	03/03/14	2.58 hours	0.007	2.26	Rainfall	Infiltration/inflow. Station at rated capacity.
126	Cleeces Ferry PS	03/03/14	03/03/14	2.5 hours	0.05	2.26	Rainfall	Infiltration/inflow. Station at rated capacity.
136	River Drive PS	03/03/14	03/03/14	2.25 hours	0.037	2.50	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	03/02/14	03/03/14	8 hours	0.025	2.32	Rainfall	Infiltration/inflow. Station at rated capacity.
217	Basswood Ave.	03/03/14	03/04/14	16.34 hours	0.719	2.26	Rainfall	
337	Richland Creek (TDOT)	03/02/14	03/04/14	14 hours	0.001	2.26	Rainfall	6601 Centennial Blvd.
379	622 Davidson	03/02/14	03/04/14	3 hours	0.001	2.26	Rainfall	622 Davidson Rd.