

Monthly Overflow Report

Date Range: April, 2014

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	14703095	04/02/14	04/02/14	1 hours	0.001		Grease	370 Wallace Rd. - Cleaned Line
000	12006036	04/07/14	04/07/14	1.5 hours	0.001		Roots	1320 Murfreesboro Pk. - Cleaned Line
000	14815022	04/11/14	04/11/14	8.5 hours	0.0001		Force Main	2509 Hessey Pass - repaired grinder pump valve
000	09806082	04/15/14	04/15/14	0.16 hours	0.00001		Force Main	3196 Earhart Rd. - force main valve leak repair
000	14816066	04/21/14	04/21/14	2.5 hours	0.00001		Grit/Debris	308 Carrolton Station Rd.
000	13511001	04/28/14	04/28/14	3 hours	0.001	2.87	Grease	600 Longhunter Ct. B. - Cleaned Line
000	11907146	04/29/14	04/29/14	24 hours	1	4.09	Rainfall	431 E. Thompson Ln. (near Old Glenrose)
000	11913092	04/29/14	04/29/14	8 hours	0.001	4.09	Rainfall	2932 Louise Dr.
000	09211108	04/29/14	04/29/14	0.5 hours	0.001	3.53	Grit/Debris	1912 Charlotte Ave. Cleaned Line
124	Williamson Ferry PS	04/28/14	04/29/14	5.25 hours	0.35	4.34	Rainfall	Infiltration/inflow. Station at rated capacity.
130	Brown's Creek PS	04/02/14	04/02/14	1.33 hours	0.874	0.00	VFD or Soft Start	Power surge from electric utility caused blown fuses on VFDs.
130	Brown's Creek PS	04/29/14	04/29/14	1.08 hours	0.007	4.07	Rainfall	Infiltration/inflow. Station at rated capacity.
131	Hurricane Creek PS	04/29/14	04/29/14	4 hours	0.25	2.64	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	04/28/14	04/29/14	3.84 hours	0.293	4.55	Rainfall	Infiltration/inflow. Station at rated capacity.
158	Farmingham Woods PS	04/28/14	04/29/14	10 hours	0.3	4.18	Rainfall	Infiltration/inflow. Station at rated capacity.
161	Longhunter Chase SPS	04/29/14	04/29/14	7 hours	0.3	3.83	Rainfall	Infiltration/inflow. Station at rated capacity.
178	East Lakemont PS	04/28/14	04/29/14	15 hours	0.3	4.93	Rainfall	Infiltration/inflow. Station at rated capacity.
179	Fairway Center PS	04/29/14	04/29/14	6.25 hours	0.2	4.11	Rainfall	Infiltration/inflow. Station at rated capacity.
189	Langford Farms PS	04/29/14	04/29/14	6 hours	0.1	4.48	Rainfall	Infiltration/inflow. Station at rated capacity.
222	Barker Road	04/28/14	04/30/14	52.59 hours	12.696	4.18	Rainfall	Infiltration/inflow. EQ Basin full.
226	Cowan St. Relief Bleeder	04/28/14	04/30/14	40.58 hours	4.318	4.34	Rainfall	Infiltration/inflow. Station at rated capacity.
328	Cooper Lane	04/28/14	04/28/14	15 hours	0.001	4.34	Rainfall	2813 Cooper Lane
374	Foster Ave	04/28/14	04/29/14	8 hours	0.001	4.09	Rainfall	2803 Foster Ave.

Monthly Overflow Report

Date Range: April, 2014

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	03413034	04/28/14	04/28/14	1 hours	0.001	4.15	Rainfall	1442 Gallatin Pk.
106	Vandiver PS	04/28/14	04/29/14	11.5 hours	0.912	4.23	Rainfall	Infiltration/inflow. Station at rated capacity.
109	Dry Creek PS	04/29/14	04/29/14	19.5 hours	8.219	4.15	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	04/28/14	04/29/14	13.09 hours	1.142	4.15	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	04/28/14	04/29/14	7.09 hours	1.314	4.15	Rainfall	Infiltration/inflow. Station at rated capacity.
117	Neely's Bend PS	04/28/14	04/29/14	12.5 hours	0.5	4.15	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	04/28/14	04/29/14	14 hours	0.3	4.15	Rainfall	Infiltration/inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	04/28/14	04/29/14	26.5 hours	0.4	4.15	Rainfall	Infiltration/inflow. Station at rated capacity.
150	Hidden Acres PS	04/28/14	04/29/14	5 hours	0.5	4.15	Rainfall	Infiltration/inflow. Station at rated capacity.
303	N. Dupont Avenue	04/29/14	04/29/14	9 hours	0.001	4.15	Rainfall	504 N. DuPont Ave.

Monthly Overflow Report

Date Range: April, 2014

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	11616060	04/06/14	04/06/14	1 hours	0.00001	0.41	Roots	4004 Estes Rd. - Cleaned Line
000	06001013	04/28/14	04/28/14	31 hours	0.001	4.79	Rainfall	3258 Brick Church Pk.
000	05010033	04/28/14	04/29/14	31 hours	0.0001	4.79	Rainfall	3414 Brick Church Pk.
000	06001011	04/28/14	04/29/14	31 hours	0.001	4.79	Rainfall	3258 Brick Church Pk.
000	09015007	04/28/14	04/28/14	0.5 hours	0.00001	4.08	Rainfall	473 Annex Ave. - Building Backup
000	09012057	04/28/14	04/28/14	12.5 hours	0.001	4.08	Rainfall	6303 Henry Ford Dr.
000	13007005	04/28/14	04/29/14	3 hours	0.001	4.36	Rainfall	4302 Harding Pl.
000	13104131	04/28/14	04/29/14	45 hours	0.001	4.36	Rainfall	4112 Rockdale Ave.
000	08013031	04/29/14	04/30/14	20.5 hours	0.001	4.08	Grease	6600 Briley Pkwy.
107	West Park PS	04/28/14	04/29/14	10.66 hours	1.118	4.08	Rainfall	Infiltration/inflow. Station at rated capacity. EQ full.
114	Davidson Branch PS	04/04/14	04/04/14	1.42 hours	0.002	0.96	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	04/28/14	04/29/14	30.16 hours	0.718	4.08	Rainfall	Infiltration/inflow. Station at rated capacity.
126	Cleeces Ferry PS	04/28/14	04/29/14	16.5 hours	0.3	4.08	Rainfall	Infiltration/inflow. Station at rated capacity.
136	River Drive PS	04/28/14	04/29/14	2.67 hours	0.033	4.55	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	04/28/14	04/29/14	21 hours	0.07	4.78	Rainfall	Infiltration/inflow. Station at rated capacity.
194	Germantown PS	04/28/14	04/29/14	0.75 hours	0.002	4.79	Rainfall	Infiltration/inflow. Station at rated capacity.
217	Basswood Ave.	04/28/14	04/29/14	19.75 hours	0.87	4.08	Rainfall	516 Basswood Ave.
340	Lynnwood Boulevard	04/28/14	04/28/14	3 hours	0.001	4.36	Rainfall	718 Lynnwood Blvd.
347	3300 Briley Park Blvd. S.	04/28/14	04/29/14	16 hours	0.001	4.79	Rainfall	3300 Briley Park Blvd. S