

Monthly Overflow Report

Date Range: May, 2014

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	18303015	05/02/14	05/02/14	3 hours	0.001		Roots	1550 Heil Quaker Blvd. - Cleaned Line
000	14702067	05/04/14	05/04/14	2 hours	0.0001		Grease	4811 Abbay Dr. - Cleaned Line
000	15013010	05/07/14	05/07/14	1 hours	0.0001		Line Break	3179 Hamilton Church Rd. - NES pole - Repaired
000	15009036	05/07/14	05/07/14	1 hours	0.001		Grit/Debris	3344 Calais Cr. - Cleaned Line
000	08211038	05/10/14	05/10/14	2 hours	0.0001	0.07	Grease	188 N 6th St. - Cleaned Line
000	14805026	05/20/14	05/20/14	4 hours	0.0001		Grit/Debris	3817 Briarcliff Ct. - Cleaned Line
000	14805016	05/27/14	05/27/14	4 hours	0.001		Roots	3756 Turley Dr - Cleaned Line
000	10709028	05/30/14	05/30/14	1.5 hours	0.00001		Grit/Debris	1001 Harold Drive - Cleaned Line

Monthly Overflow Report

Date Range: May, 2014

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04410020	05/01/14	05/01/14	2 hours	0.001		Grit/Debris	607 Fowler St. - Cleaned Line
106	Vandiver PS	05/02/14	05/02/14	2.33 hours	0.039	0.00	Power Related	Power failed and backup power did not transfer correctly.
132	Berwick Trail PS / Center St.	05/15/14	05/15/14	1 hours	0.01	1.26	Mechanical	Clogged pump. Backup pump out of service being repaired.

Monthly Overflow Report

Date Range: May, 2014

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<i>Sanitary Sewer Overflows</i>								
000	08013001	05/01/14	05/02/14	7 hours	0.00001		Grease	0 Centennial Blvd. - Cleaned Line
000	04901020	05/30/14	05/30/14	4 hours	0.00001		Line Break	3932 Lloyd Rd - Repaired Line