

Monthly Overflow Report

Date Range: August, 2014

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	08107083CO	08/13/14	08/13/14	1 hours	0.00001		Grit/Debris	1906 Cephas St (cleanout) - Cleaned Line
000	14803039CO	08/28/14	08/28/14	0.5 hours	0.00001		Grease	3328 Ezell Rd (cleanout) - Cleaned Line
130	Brown's Creek PS	08/31/14	08/31/14	0.92 hours	0.324	2.54	VFD or Soft Start	#1 and #3 VFD/pump failure
226	Cowan St. Relief Bleeder	08/30/14	08/30/14	0.83 hours	0.002	2.80	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: August, 2014

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
110	Loves Branch PS	08/09/14	08/09/14	0.5 hours	0.019	2.52	Rainfall	Inflow/Infiltration. Station at rated capacity.
110	Loves Branch PS	08/30/14	08/30/14	1.25 hours	0.033	3.13	Rainfall	Inflow/Infiltration. Station at rated capacity.
112	Gibson Creek PS	08/30/14	08/30/14	2.33 hours	0.272	3.13	Rainfall	Inflow/Infiltration. Station at rated capacity.
127	Madison Heights PS	08/30/14	08/30/14	1.5 hours	0.03	2.73	Rainfall	Inflow/Infiltration. Station at rated capacity.

Monthly Overflow Report

Date Range: August, 2014

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05004015	08/26/14	08/26/14	2 hours	0.001		Grit/Debris	3556 Dickerson Pk - Cleaned Line
000	05910048	08/28/14	08/28/14	0.5 hours	0.001	2.29	Rainfall	748 Rowan Dr
114	Davidson Branch PS	08/30/14	08/31/14	3.58 hours	0.095	2.80	Rainfall	Inflow/Infiltration. Station at rated capacity.