

# Monthly Overflow Report

Date Range: October, 2014

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	WLS052K061	10/01/14	10/01/14	1 hours	0.0001		Grit/Debris	317 Matterhorn Dr -Cleaned Line
000	14808058	10/05/14	10/05/14	2 hours	0.001		Roots	32 Waikiki Blvd - Cleaned Line
000	13308082	10/05/14	10/05/14	3 hours	0.001		Roots	829 Reischa Ct - Cleaned Line
000	09310147	10/12/14	10/12/14	1 hours	0.001	0.03	Grease	301 3rd Ave S - Cleaned Line
000	11907146	10/14/14	10/14/14	15 hours	0.1	2.52	Rainfall	431 E Thompson Ln
000	10616031	10/14/14	10/14/14	17 hours	0.001	2.52	Rainfall	416 Hollydale Dr
000	10705024	10/29/14	10/29/14	3 hours	0.0001		Roots	808 Patricia Dr - Cleaned Line
102	Smith Springs PS	10/14/14	10/14/14	19.42 hours	1.495	2.70	Rainfall	Infiltration/inflow. Station at rated capacity. EQ full.
131	Hurricane Creek PS	10/14/14	10/14/14	4 hours	0.25	2.90	Rainfall	Infiltration/inflow. Station at rated capacity.
134	Riverside Drive PS	10/14/14	10/14/14	13 hours	0.1	2.90	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	10/13/14	10/14/14	3.75 hours	0.318	3.11	Rainfall	Infiltration/inflow. Station at rated capacity.
158	Farmingham Woods PS	10/11/14	10/11/14	3 hours	0.15	1.83	Power Related	Electrical storm destroyed incoming power.
161	Longhunter Chase SPS	10/14/14	10/14/14	13 hours	0.5	2.52	Rainfall	Infiltration/inflow. Station at rated capacity.
222	Barker Road	10/14/14	10/15/14	26.17 hours	2.317	2.81	Rainfall	Infiltration/inflow. Station at rated capacity. EQ full.
330	Anderson Road	10/14/14	10/14/14	10 hours	0.001	2.70	Rainfall	177 Timber Ridge Dr
374	Foster Ave	10/14/14	10/14/14	15 hours	0.001	2.52	Rainfall	2803 Foster Ave
384	501 Bismark Dr.	10/14/14	10/15/14	34 hours	0.1	2.81	Rainfall	501 Bismark Dr

# Monthly Overflow Report

Date Range: October, 2014

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	03413034	10/14/14	10/14/14	5 hours	0.001	2.70	Rainfall	1442 Gallatin Rd
106	Vandiver PS	10/13/14	10/14/14	12.59 hours	0.625	3.02	Rainfall	Infiltration/inflow. Station at rated capacity.
109	Dry Creek PS	10/14/14	10/14/14	3.33 hours	0.307	2.70	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	10/13/14	10/14/14	11.16 hours	0.26	2.70	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	10/14/14	10/14/14	9 hours	0.2	2.41	Rainfall	Infiltration/inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	10/14/14	10/14/14	8.5 hours	0.15	2.41	Rainfall	Infiltration/inflow. Station at rated capacity.
303	N. Dupont Avenue	10/14/14	10/14/14	9.5 hours	0.001	2.70	Rainfall	303 N Dupont Ave

# Monthly Overflow Report

Date Range: October, 2014

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	05010033	10/13/14	10/14/14	27 hours	0.001	3.45	Rainfall	3414 Brick Church Pk
000	09012057	10/14/14	10/14/14	13 hours	0.001	2.82	Rainfall	6303 Henry Ford Dr
000	09015008	10/14/14	10/14/14	3 hours	0.0001	2.82	Rainfall	471 Annex Ave
000	11507055	10/14/14	10/15/14	24 hours	0.001	2.82	Rainfall	615 Georgetown Dr
000	06001011	10/14/14	10/15/14	22 hours	0.001	3.43	Rainfall	3258 Brick Church Pk
000	06001013	10/14/14	10/15/14	22 hours	0.001	3.43	Rainfall	3258 Brick Church Pk
114	Davidson Branch PS	10/13/14	10/14/14	16.5 hours	1.806	2.82	Rainfall	Infiltration/inflow. Station at rated capacity.
138	Sunliner PS	10/13/14	10/14/14	4.5 hours	0.2	2.67	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	10/13/14	10/14/14	10 hours	0.03	4.02	Rainfall	Infiltration/inflow. Station at rated capacity.
217	Basswood Ave.	10/13/14	10/14/14	13.92 hours	0.679	2.82	Rainfall	516 Basswood Ave.
340	Lynnwood Boulevard	10/14/14	10/14/14	12 hours	0.001	2.93	Rainfall	4302 Harding Pl
347	3300 Briley Park Blvd. S.	10/14/14	10/15/14	22 hours	0.001	3.43	Rainfall	3300 Briley Park Blvd S
379	622 Davidson	10/14/14	10/15/14	24 hours	0.001	2.82	Rainfall	622 Davidson Rd