

# Monthly Overflow Report

Date Range: December, 2014

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	11706063	12/06/14	12/06/14	3 hours	0.001	1.45	Roots	2164 Golf Club Ln - Cleaned Line
000	13316098	12/22/14	12/22/14	2 hours	0.001	0.03	Grease	700 Whispering Oaks Pl - Cleaned Line
000	10401121	12/22/14	12/22/14	1.5 hours	0.001	0.10	Grit/Debris	3510 Wrenwood Dr - Cleaned Line
000	18105008	12/24/14	12/24/14	2.5 hours	0.001	1.05	Grease	6448 Nolensville Pk - Cleaned Line
000	06115005	12/26/14	12/26/14	0.75 hours	0.001		Grit/Debris	3918 Burrus St - Cleaned Line
000	16206025CO	12/27/14	12/27/14	0.75 hours	0.0001	0.41	Grit/Debris	116 Valley Way - Cleaned Line
134	Riverside Drive PS	12/05/14	12/06/14	19 hours	0.3	2.08	Rainfall	Infiltration/inflow. Station at rated capacity.
222	Barker Road	12/06/14	12/06/14	10.42 hours	0.187	1.40	Rainfall	Infiltration/inflow. EQ basin full.
226	Cowan St. Relief Bleeder	12/05/14	12/06/14	9.34 hours	0.34	2.01	Rainfall	Infiltration/inflow. Station at rated capacity.

# Monthly Overflow Report

Date Range: December, 2014

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	04307042	12/03/14	12/03/14	3 hours	0.001		Force Main	747 River Landing Way - Force Main Fixed
106	Vandiver PS	12/05/14	12/06/14	12.33 hours	0.477	2.32	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	12/05/14	12/06/14	16.66 hours	0.771	2.47	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	12/05/14	12/06/14	10.75 hours	2.192	2.47	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	12/05/14	12/05/14	1 hours	0.02	1.83	Rainfall	Infiltration/inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	12/06/14	12/06/14	3 hours	0.05	2.47	Rainfall	Infiltration/inflow. Station at rated capacity.

# Monthly Overflow Report

Date Range: December, 2014

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	05010033	12/06/14	12/07/14	24 hours	0.0001	2.63	Rainfall	3414 Brick Church Pk
000	05911027	12/06/14	12/07/14	28.5 hours	0.0001	2.01	Rainfall	701 Rowan Dr
000	06001013	12/06/14	12/07/14	24 hours	0.001	2.63	Rainfall	3258 Brick Church Pk
000	05911028	12/06/14	12/07/14	29 hours	0.001	2.01	Rainfall	709 Rowan Dr
000	05914081	12/06/14	12/07/14	24 hours	0.001	2.01	Rainfall	740 Moormans Arm Rd
000	06001011	12/06/14	12/07/14	24 hours	0.001	2.63	Rainfall	3258 Brick Church Pk
000	05013010	12/06/14	12/07/14	24 hours	0.001	2.63	Rainfall	3300 Briley Park Blvd S
000	05915182	12/06/14	12/07/14	29 hours	0.001	2.01	Rainfall	3812 Cravath Dr
000	05914031	12/19/14	12/19/14	2 hours	0.00001		Roots	740 Moormans Arm Rd - Cleaned Line
114	Davidson Branch PS	12/05/14	12/06/14	16.59 hours	1.221	1.82	Rainfall	Infiltration/inflow. Station at rated capacity.