

Monthly Overflow Report

Date Range: February, 2015

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	10616016CO	02/03/15	02/04/15	5.5 hours	0.001		Grit/Debris	145 Philfre Ct (CO) - Cleaned Line
000	14812012	02/04/15	02/04/15	2 hours	0.001		Roots	143 Waikiki Blvd - Cleaned Line
000	10411062	02/06/15	02/06/15	6 hours	0.0001		Roots	2405 Barton Ave - Cleaned Line
000	13312067	02/06/15	02/06/15	1 hours	0.00001		Grit/Debris	616 Kay Ct - Cleaned Line
000	08212032	02/08/15	02/08/15	1.5 hours	0.0001		Grit/Debris	314 N 9th St - Cleaned Line
000	08602062	02/21/15	02/23/15	25 hours	0.001	2.93	Rainfall	0 Dodson Chapel
000	13607014	02/21/15	02/21/15	2 hours	0.001	2.33	Rainfall	177 Timber Ridge
000	08602058	02/21/15	02/23/15	25 hours	0.001	2.93	Rainfall	Old Lebanon Dirt Rd
000	10616031	02/21/15	02/22/15	5 hours	0.001	3.11	Rainfall	416 Hollydale Dr
000	11907144	02/21/15	02/22/15	36 hours	0.1	3.11	Rainfall	0 Old Glenrose Dr
000	11907051	02/21/15	02/22/15	36 hours	0.1	3.11	Rainfall	2640 Old Glenrose Dr
000	11903088	02/22/15	02/22/15	5 hours	0.001	3.11	Rainfall	351 Wimpole Dr
000	11907047	02/22/15	02/22/15	5 hours	0.001	3.11	Rainfall	381 Wimpole Dr
000	07108082	02/22/15	02/22/15	1 hours	0.00001	3.00	Grit/Debris	502 Norton Ave - Cleaned Line
000	11904005	02/22/15	02/22/15	5 hours	0.001	3.11	Rainfall	321 Wimpole Dr
000	09203091	02/23/15	02/23/15	1.5 hours	0.001		Grease	915 19th Ave N - Cleaned Line
000	08606097	02/23/15	02/23/15	20 hours	0.001	2.93	Rainfall	0 Dodson Chapel
000	13405014	02/25/15	02/25/15	1.5 hours	0.0001		Grit/Debris	3436 Donna Kay Dr - Cleaned Line
000	09407018	02/25/15	02/25/15	0.25 hours	0.01	0.00	Controller	1140 Visco Dr. Level control failed.
102	Smith Springs PS	02/21/15	02/22/15	35.25 hours	4.245	2.33	Rainfall	Infiltration/inflow. Station at rated capacity. EQ Full.
124	Williamson Ferry PS	02/21/15	02/21/15	12.67 hours	0.812	3.00	Rainfall	Infiltration/inflow. Station at rated capacity.
134	Riverside Drive PS	02/21/15	02/22/15	20 hours	0.4	3.23	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	02/21/15	02/21/15	9.83 hours	0.937	3.23	Rainfall	Infiltration/inflow. Station at rated capacity.
159	Summerfield SPS	02/21/15	02/21/15	0.5 hours	0.02	2.33	Rainfall	Infiltration/inflow. Station at rated capacity.
161	Longhunter Chase SPS	02/21/15	02/22/15	21 hours	0.8	2.33	Rainfall	Infiltration/inflow. Station at rated capacity.
176	Dodson Chapel PS	02/22/15	02/24/15	41 hours	10	2.93	Rainfall	Infiltration/inflow. Station at rated capacity. EQ full.

Monthly Overflow Report

Date Range: February, 2015

178	East Lakemont PS	02/21/15	02/23/15	36.75 hours	0.6	3.03	Rainfall	Infiltration/inflow. Station at rated capacity.
179	Fairway Center PS	02/21/15	02/22/15	14 hours	0.3	2.86	Rainfall	Infiltration/inflow. Station at rated capacity.
183	Mill Creek PS	02/22/15	02/22/15	11 hours	0.1	2.93	Rainfall	Infiltration/inflow. Station at rated capacity.
188	South Oak Hill PS	02/21/15	02/21/15	6 hours	0.4	3.03	Rainfall	Infiltration/inflow. Station at rated capacity.
189	Langford Farms PS	02/21/15	02/22/15	13 hours	0.2	1.70	Rainfall	Infiltration/inflow. Station at rated capacity.
190	Towne Village PS	02/21/15	02/21/15	7 hours	0.05	2.33	Rainfall	Infiltration/inflow. Station at rated capacity.
222	Barker Road	02/21/15	02/24/15	69.58 hours	11.522	2.93	Rainfall	Infiltration/inflow. EQ tanks full.
226	Cowan St. Relief Bleeder	02/21/15	02/22/15	39.08 hours	7.683	3.00	Rainfall	Infiltration/inflow. Station at rated capacity.
370	Lisa Lane Overflow	02/23/15	02/23/15	20 hours	0.001	2.33	Rainfall	Lisa Ln
384	501 Bismark Dr.	02/21/15	02/23/15	30 hours	0.1	2.93	Rainfall	501 Bismark Dr

Monthly Overflow Report

Date Range: February, 2015

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04312007CO	02/21/15	02/22/15	14 hours	0.0001	2.03	Rainfall	140 Vandiver Dr - clean out
000	03413034	02/21/15	02/21/15	2 hours	0.001	3.21	Rainfall	1442 Gallatin Pk
106	Vandiver PS	02/21/15	02/21/15	5.33 hours	0.628	2.03	Rainfall	Infiltration/inflow. Station at rated capacity.
109	Dry Creek PS	02/21/15	02/23/15	14.24 hours	1.326	3.21	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	02/21/15	02/22/15	17.17 hours	2.494	2.48	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	02/21/15	02/22/15	14.83 hours	2.143	2.48	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	02/21/15	02/22/15	15 hours	0.3	2.48	Rainfall	Infiltration/inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	02/21/15	02/21/15	14 hours	0.2	2.48	Rainfall	Infiltration/inflow. Station at rated capacity.
150	Hidden Acres PS	02/21/15	02/21/15	13 hours	1	2.48	Rainfall	Infiltration/inflow. Station at rated capacity.
303	N. Dupont Avenue	02/21/15	02/21/15	3 hours	0.001	2.48	Rainfall	303 N Dupont Ave
327	Norman Dr & Vantrease	02/21/15	02/21/15	9 hours	0.001	2.48	Rainfall	Norman Dr

Monthly Overflow Report

Date Range: February, 2015

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	02201018	02/11/15	02/11/15	1 hours	0.001		Grease	7201 Whites Creek Pk - Cleaned Line
000	05911028	02/21/15	02/22/15	24 hours	0.001	2.72	Rainfall	709 Rowan Dr
000	11507055	02/21/15	02/22/15	24 hours	0.001	2.44	Rainfall	615 Georgetown
000	14405017	02/21/15	02/22/15	24 hours	0.001	3.03	Rainfall	1318 Chickering Rd
000	05911027	02/21/15	02/22/15	24 hours	0.001	2.72	Rainfall	701 Rowan Dr
000	13007002	02/21/15	02/21/15	5 hours	0.001	3.03	Rainfall	803 Lynnwood Blvd
000	06001011	02/21/15	02/22/15	18 hours	0.001	2.72	Rainfall	3258 Brick Church Pk
000	05010029	02/21/15	02/22/15	40 hours	0.001	2.72	Rainfall	3438 Brick Church Pk
000	06001013	02/21/15	02/22/15	18 hours	0.001	2.72	Rainfall	3258 Brick Church Pk
000	09012057	02/21/15	02/21/15	7 hours	0.001	2.44	Rainfall	6303 Henry Ford Dr
000	14405021	02/21/15	02/22/15	24 hours	0.001	3.03	Rainfall	4419 Chickering Ln
000	13007005	02/21/15	02/21/15	5 hours	0.001	3.03	Rainfall	4302 Harding Pl
000	05010033	02/21/15	02/22/15	40 hours	0.001	2.72	Rainfall	3414 Brick Church Pk
000	05910048	02/21/15	02/22/15	24 hours	0.001	2.72	Rainfall	748 Rowan Dr
000	05915017	02/21/15	02/22/15	24 hours	0.001	2.72	Rainfall	3812 Cravath Dr
000	14405014	02/21/15	02/22/15	24 hours	0.001		Rainfall	4419 Chickering Ln
000	05911036	02/22/15	02/23/15	24 hours	0.001	2.72	Rainfall	3818 Cravath Dr
000	09112118	02/22/15	02/22/15	2 hours	0.001		Grit/Debris	0 40th Ave N - Cleaned Line
000	05911034	02/22/15	02/23/15	24 hours	0.001	2.72	Rainfall	3830 Cravath Dr
000	09116013	02/23/15	02/23/15	1.5 hours	0.001		Grease	4310 Nevada Ave - Cleaned Line
000	10301013	02/23/15	02/23/15	2 hours	0.00001		Grit/Debris	6320 Charlotte Pk - Cleaned Line
101	Bordeaux Hospital PS	02/21/15	02/21/15	6 hours	0.07	3.23	Rainfall	Infiltration/inflow. Station at rated capacity.
107	West Park PS	02/21/15	02/22/15	11.58 hours	1.965	2.44	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	02/21/15	02/22/15	33.5 hours	2.375	2.44	Rainfall	Infiltration/inflow. Station at rated capacity.
126	Cleeces Ferry PS	02/21/15	02/21/15	10 hours	0.2	2.44	Rainfall	Infiltration/inflow. Station at rated capacity.
136	River Drive PS	02/21/15	02/21/15	3.25 hours	0.019	3.23	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: February, 2015

138	Sunliner PS	02/21/15	02/21/15	5 hours	0.2	2.44	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	02/21/15	02/21/15	14 hours	0.05	0.05	Rainfall	Infiltration/inflow. Station at rated capacity.
217	Basswood Ave.	02/21/15	02/22/15	26.17 hours	1.574	2.44	Rainfall	
337	Richland Creek (TDOT)	02/21/15	02/22/15	15 hours	0.001	2.44	Rainfall	6601 Centennial Blvd
340	Lynnwood Boulevard	02/21/15	02/21/15	5 hours	0.001	3.03	Rainfall	718 Lynnwood
347	3300 Briley Park Blvd. S.	02/21/15	02/22/15	40 hours	0.001	2.72	Rainfall	3300 Briley Park Blvd S
379	622 Davidson	02/21/15	02/22/15	24 hours	0.001	2.44	Rainfall	622 Davidson