

Monthly Overflow Report

Date Range: March, 2015

Central WWTP NPDES# TN 0020575

| # | Overflow Name | Start Date | End Date | Duration | Volume (mg) | Rainfall | Overflow Cause | Remarks |
|---------------------------------|--------------------------|------------|----------|-------------|-------------|----------|----------------|--|
| Sanitary Sewer Overflows | | | | | | | | |
| 000 | 10616032 | 03/04/15 | 03/05/15 | 3 hours | 0.001 | 2.29 | Rainfall | 408 Hollydale Dr |
| 000 | 11907146 | 03/04/15 | 03/05/15 | 9 hours | 0.03 | 2.29 | Rainfall | 431 E Thompson Ln |
| 000 | 10616031 | 03/04/15 | 03/05/15 | 3 hours | 0.001 | 2.29 | Rainfall | 416 Hollydale Dr |
| 000 | 11908046 | 03/05/15 | 03/05/15 | 9 hours | 0.001 | 2.29 | Rainfall | 0 Old Glenrose |
| 000 | 16106002 | 03/05/15 | 03/05/15 | 1 hours | 0.0001 | 0.08 | Grit/Debris | 400 McMurray - Cleaned Line |
| 000 | 05415060 | 03/06/15 | 03/06/15 | 6 hours | 0.001 | 0.29 | Force Main | 37 Harbor Cove Dr - Repaired Force Main |
| 000 | 16107022 | 03/29/15 | 03/29/15 | 1.5 hours | 0.0001 | | Grease | 5137 Hilson Rd - Cleaned Line |
| 102 | Smith Springs PS | 03/04/15 | 03/05/15 | 20.84 hours | 2.04 | 2.26 | Rainfall | Infiltration/inflow. Station at rated capacity. EQ full. |
| 124 | Williamson Ferry PS | 03/04/15 | 03/04/15 | 4 hours | 0.122 | 2.36 | Rainfall | Infiltration/inflow. Station at rated capacity. |
| 131 | Hurricane Creek PS | 03/04/15 | 03/04/15 | 3 hours | 0.2 | 2.17 | Rainfall | Infiltration/inflow. Station at rated capacity. |
| 134 | Riverside Drive PS | 03/04/15 | 03/05/15 | 20 hours | 0.4 | 2.44 | Rainfall | Infiltration/inflow. Station at rated capacity. |
| 158 | Farmingham Woods PS | 03/04/15 | 03/04/15 | 3.25 hours | 0.1 | 2.04 | Rainfall | Infiltration/inflow. Station at rated capacity. |
| 161 | Longhunter Chase SPS | 03/04/15 | 03/05/15 | 23 hours | 1 | 2.17 | Rainfall | Infiltration/inflow. Station at rated capacity. |
| 178 | East Lakemont PS | 03/04/15 | 03/06/15 | 44 hours | 0.7 | 2.72 | Rainfall | Infiltration/inflow. Station at rated capacity. |
| 188 | South Oak Hill PS | 03/04/15 | 03/04/15 | 6 hours | 0.01 | 2.31 | Rainfall | Infiltration/inflow. Station at rated capacity. |
| 222 | Barker Road | 03/04/15 | 03/07/15 | 82.41 hours | 15.334 | 2.43 | Rainfall | Infiltration/inflow. EQ full. |
| 226 | Cowan St. Relief Bleeder | 03/04/15 | 03/05/15 | 13.58 hours | 1.012 | 2.40 | Rainfall | Infiltration/inflow. Station at rated capacity. |
| 374 | Foster Ave | 03/04/15 | 03/05/15 | 9 hours | 0.001 | 2.29 | Rainfall | 2803 Foster Ave |
| 384 | 501 Bismark Dr. | 03/04/15 | 03/06/15 | 17 hours | 0.3 | 2.43 | Rainfall | 501 Bismark |

Monthly Overflow Report

Date Range: March, 2015

Dry Creek WWTP NPDES# TN0020648

| # | Overflow Name | Start Date | End Date | Duration | Volume (mg) | Rainfall | Overflow Cause | Remarks |
|---------------------------------|-------------------------------|------------|----------|------------|-------------|----------|----------------|---|
| Sanitary Sewer Overflows | | | | | | | | |
| 000 | 05101020 | 03/04/15 | 03/04/15 | 1 hours | 0.001 | 2.26 | Grease | 449 Neelys Bend Rd |
| 000 | 05303062 | 03/10/15 | 03/11/15 | 29 hours | 0.001 | 0.75 | Line Break | 505 15th St - Repaired Line |
| 110 | Loves Branch PS | 03/04/15 | 03/05/15 | 8.08 hours | 0.671 | 2.39 | Rainfall | Infiltration/inflow. Station at rated capacity. |
| 112 | Gibson Creek PS | 03/04/15 | 03/05/15 | 7.84 hours | 1.104 | 2.39 | Rainfall | Infiltration/inflow. Station at rated capacity. |
| 127 | Madison Heights PS | 03/04/15 | 03/05/15 | 9.5 hours | 0.2 | 2.39 | Rainfall | Infiltration/inflow. Station at rated capacity. |
| 132 | Berwick Trail PS / Center St. | 03/08/15 | 03/08/15 | 0.01 hours | 0.00001 | 0.00 | Electrical | Generator failure. |
| 150 | Hidden Acres PS | 03/04/15 | 03/04/15 | 2.25 hours | 0.2 | 2.26 | Rainfall | Infiltration/inflow. Station at rated capacity. |

Monthly Overflow Report

Date Range: March, 2015

Whites Creek WWTP NPDES# TN 0024970

| # | Overflow Name | Start Date | End Date | Duration | Volume (mg) | Rainfall | Overflow Cause | Remarks |
|---------------------------------|---------------------------|------------|----------|-------------|-------------|----------|----------------|--|
| Sanitary Sewer Overflows | | | | | | | | |
| 000 | 06001013 | 03/04/15 | 03/04/15 | 16 hours | 0.15 | 2.36 | Rainfall | 3258 Brick Church Pk |
| 000 | 06001011 | 03/04/15 | 03/04/15 | 16 hours | 0.05 | 2.36 | Rainfall | 3258 Brick Church Pk |
| 000 | 13007005 | 03/04/15 | 03/04/15 | 6 hours | 0.001 | 2.43 | Rainfall | 4302 Harding Pl |
| 000 | 11507055 | 03/04/15 | 03/04/15 | 6 hours | 0.02 | 2.20 | Rainfall | 615 Georgetown |
| 000 | 13007024 | 03/04/15 | 03/04/15 | 6 hours | 0.001 | 2.43 | Rainfall | 4302 Harding Pl |
| 000 | 05010033 | 03/04/15 | 03/04/15 | 16 hours | 0.001 | 2.36 | Rainfall | 3414 Brick Church Pk |
| 000 | 11516065 | 03/13/15 | 03/16/15 | 72 hours | 0.0001 | 0.81 | Rainfall | 6205 Jocelyn Hollow Rd |
| 000 | 11516063 | 03/14/15 | 03/16/15 | 60 hours | 0.001 | 0.81 | Rainfall | 6215 Jocelyn Hollow Rd |
| 000 | 11516064 | 03/14/15 | 03/16/15 | 60 hours | 0.001 | 0.81 | Rainfall | 6211 Jocelyn Hollow Rd |
| 000 | 10303123 | 03/18/15 | 03/18/15 | 1.5 hours | 0.00001 | | Line Break | 4601 Murphy Rd - Repaired Line |
| 000 | 14306002 | 03/23/15 | 03/23/15 | 3 hours | 0.0001 | | Roots | 117 Harpeth Trace Ct - Cleaned Line |
| 107 | West Park PS | 03/04/15 | 03/05/15 | 4.75 hours | 0.411 | 2.20 | Rainfall | Infiltration/inflow. Station at rated capacity. EQ full. |
| 114 | Davidson Branch PS | 03/04/15 | 03/05/15 | 25.92 hours | 1.986 | 2.20 | Rainfall | Infiltration/inflow. Station at rated capacity. |
| 145 | Joelton PS | 03/04/15 | 03/04/15 | 7 hours | 0.02 | 1.83 | Rainfall | Infiltration/inflow. Station at rated capacity. |
| 217 | Basswood Ave. | 03/04/15 | 03/05/15 | 15.58 hours | 0.613 | 2.20 | Rainfall | |
| 346 | 3438 Briley Park Blvd. N. | 03/04/15 | 03/04/15 | 16 hours | 0.001 | 2.36 | Rainfall | 3438 Brick Church Pk |
| 347 | 3300 Briley Park Blvd. S. | 03/04/15 | 03/04/15 | 16 hours | 0.001 | 2.36 | Rainfall | 3300 Briley Park Blvd S |
| 379 | 622 Davidson | 03/04/15 | 03/04/15 | 6 hours | 0.0001 | 2.20 | Rainfall | 612 Davidson Rd |