

# Monthly Overflow Report

Date Range: April, 2015

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	08602062	04/16/15	04/16/15	10 hours	0.001	2.84	Rainfall	0 Dodson Chapel
000	07309066	04/19/15	04/20/15	23 hours	0.001	2.42	Rainfall	2301 Cooper Terrace
000	11907146	04/20/15	04/21/15	22.5 hours	0.001	1.83	Rainfall	0 Old Glenrose Ave
000	18303006	04/23/15	04/26/15	82 hours	0.1	0.20	Line Break	1640 J P Hennessy Dr - Cleaned Line
000	16107019	04/29/15	04/29/15	5 hours	0.001		Grit/Debris	508 Hilson Ct - Cleaned line
102	Smith Springs PS	04/19/15	04/20/15	15.67 hours	1.142	2.11	Rainfall	Infiltration/inflow. Station at rated capacity. EQ full.
124	Williamson Ferry PS	04/19/15	04/19/15	3.17 hours	0.15	2.42	Rainfall	Infiltration/inflow. Station at rated capacity.
130	Brown's Creek PS	04/19/15	04/20/15	27 hours	5.984	2.14	VFD or Soft Start	Internal VFD transformer failure.
134	Riverside Drive PS	04/16/15	04/16/15	8.5 hours	0.15	3.54	Rainfall	Infiltration/inflow. Station at rated capacity.
134	Riverside Drive PS	04/19/15	04/20/15	15 hours	0.25	1.45	Rainfall	Infiltration/inflow. Station at rated capacity.
158	Farmingham Woods PS	04/16/15	04/16/15	2 hours	0.6	2.51	Rainfall	Infiltration/inflow. Station at rated capacity.
162	Rolling Hills SPS #2	04/20/15	04/21/15	29 hours	0.6	1.66	Mechanical	Broken Discharge Main
178	East Lakemont PS	04/16/15	04/17/15	9 hours	0.15	1.35	Rainfall	Infiltration/inflow. Station at rated capacity.
178	East Lakemont PS	04/19/15	04/20/15	34 hours	0.5	1.74	Rainfall	Infiltration/inflow. Station at rated capacity.
222	Barker Road	04/16/15	04/16/15	7.67 hours	0.083	2.84	Rainfall	Infiltration/inflow. Station at rated capacity.
222	Barker Road	04/19/15	04/22/15	52.08 hours	6.046	1.60	Rainfall	Infiltration/inflow. Station at rated capacity. EQ full.
226	Cowan St. Relief Bleeder	04/19/15	04/20/15	9.67 hours	0.399	2.42	Rainfall	Infiltration/inflow. Station at rated capacity.
328	Cooper Lane	04/19/15	04/20/15	23 hours	0.001	2.42	Rainfall	2813 Cooper Ln
374	Foster Ave	04/16/15	04/16/15	8 hours	0.02	2.81	Rainfall	2803 Foster Ave
384	501 Bismark Dr.	04/20/15	04/21/15	23 hours	0.1	1.60	Rainfall	501 Bismark Dr

# Monthly Overflow Report

Date Range: April, 2015

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	05302055	04/17/15	04/17/15	1 hours	0.00001		Grease	1404 Bryan St - Cleaned Line
000	04316007	04/19/15	04/19/15	2 hours	0.00001	2.64	Grease	1223 London Bridge Rd - Cleaned Line
000	04316007	04/26/15	04/26/15	1 hours	0.00001		Grease	1223 London Bridge Rd - Cleaned Line
109	Dry Creek PS	04/14/15	04/14/15	2.5 hours	0.925	2.35	Power Related	Power outage.
110	Loves Branch PS	04/19/15	04/19/15	5.92 hours	0.47	2.37	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	04/19/15	04/19/15	9.75 hours	1.088	2.37	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	04/19/15	04/19/15	9 hours	0.2	2.37	Rainfall	Infiltration/inflow. Station at rated capacity.

# Monthly Overflow Report

Date Range: April, 2015

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	14307002	04/03/15	04/03/15	3 hours	0.001	0.83	Roots	117 Harpeth Trace Ct - Cleaned Line
000	14303027	04/13/15	04/13/15	3.5 hours	0.001	0.92	Roots	11 Vaughns Gap Rd - Cleaned Line
000	05010033	04/16/15	04/17/15	21 hours	0.3	3.22	Rainfall	3414 Brick Church Pk
000	06001013	04/16/15	04/16/15	17 hours	0.1	3.22	Rainfall	3258 Brick Church Pk
000	11516063	04/19/15	04/22/15	61 hours	0.001	1.99	Rainfall	6215 Jocelyn Hollow Rd
000	06001013	04/19/15	04/20/15	25 hours	0.001	2.19	Rainfall	3258 Brick Church Pk
000	05010033	04/19/15	04/20/15	39 hours	0.1	2.19	Rainfall	3414 Brick Church Pk
000	05010094	04/20/15	04/20/15	21 hours	0.001	2.19	Rainfall	3438 Briley Park Blvd N
000	05010093	04/20/15	04/20/15	21 hours	0.001	2.19	Rainfall	3438 Briley Park Blvd N
000	05010027	04/20/15	04/20/15	21 hours	0.001	2.19	Rainfall	3438 Briley Park Blvd N
000	05809006	04/30/15	04/30/15	3.5 hours	0.0001		Grease	4345 Eatons Creek Rd - Cleaned line
114	Davidson Branch PS	04/14/15	04/16/15	23.84 hours	1.102	3.15	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	04/19/15	04/20/15	18.16 hours	0.538	1.86	Rainfall	Infiltration/inflow. Station at rated capacity.
346	3438 Briley Park Blvd. N.	04/16/15	04/16/15	17 hours	0.07	3.22	Rainfall	3438 Briley Park Blvd
346	3438 Briley Park Blvd. N.	04/19/15	04/20/15	39 hours	0.001	2.19	Rainfall	3438 Briley Park Blvd
347	3300 Briley Park Blvd. S.	04/16/15	04/16/15	20.5 hours	0.001	3.22	Rainfall	3300 Briley Park Blvd S
347	3300 Briley Park Blvd. S.	04/19/15	04/20/15	39 hours	0.001	2.19	Rainfall	3300 Briley Park Blvd S