

# Monthly Overflow Report

Date Range: June, 2015

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	09403048	06/03/15	06/03/15	1 hours	0.0001		Roots	2821 Hody Dr - Cleaned Line
000	09216103	06/03/15	06/03/15	1.5 hours	0.00001		Grease	106 19th Ave S - Cleaned Line
000	13607032	06/11/15	06/11/15	4 hours	0.001		Grease	112 Coastal Ct W - Cleaned Line
000	16203068	06/29/15	06/29/15	1 hours	0.00001	0.09	Roots	503 Santee Ct - Cleaned Line
165	Birchwood SPS	06/28/15	06/28/15	2 hours	0.001	0.00	Mechanical	Pump failure
226	Cowan St. Relief Bleeder	06/08/15	06/09/15	11.58 hours	1.493	2.04	Rainfall	Infiltration/inflow. Station at rated capacity.

---

# Monthly Overflow Report

Date Range: June, 2015

---

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
114	Davidson Branch PS	06/08/15	06/08/15	1.75 hours	0.046	1.74	Rainfall	Infiltration/inflow. Station at rated capacity.