

Monthly Overflow Report

Date Range: July, 2015

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	07513060	07/15/15	07/15/15	2.5 hours	0.0001	0.34	Grit/Debris	202 Bonnabrook Dr - Cleaned Line
000	07115078	07/18/15	07/18/15	0.5 hours	0.00001		Grit/Debris	108 Douglas Ave - Cleaned Line
130	Brown's Creek PS	07/18/15	07/18/15	0.58 hours	0.171	0.00	Controller	Controller problem.
189	Langford Farms PS	07/27/15	07/27/15	12 hours	0.001	0.00	Force Main	5540 W Shady Tr - Repaired force main