

Monthly Overflow Report

Date Range: January, 2016

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	13312073	01/03/16	01/03/16	1.5 hours	0.0001		Roots	3850 Scotwood Dr - Cleaned Line
000	16407029	01/04/16	01/04/16	1 hours	0.00001		Grit/Debris	1417 Rockglade Run - Cleaned Line
000	10411103	01/10/16	01/11/16	4 hours	0.001	0.29	Grit/Debris	2512 Essex Pl - Cleaned Line
000	01203028	01/11/16	01/11/16	4 hours	0.001		Force Main	1277 Springfield Hwy - Line Repaired
000	16206116	01/16/16	01/16/16	1 hours	0.0001		Grit/Debris	156 Tusculum Rd - Cleaned Line
000	WMN056J012	01/17/16	01/17/16	1 hours	0.001		Grit/Debris	2101 Sister Ct - Cleaned Line
000	06401014	01/18/16	01/18/16	4 hours	0.001		Grit/Debris	601 Brandywine Village Ct - Cleaned Line
000	16206125	01/21/16	01/21/16	12 hours	0.001	0.89	Roots	616 Roxanne Dr / 161 Ocala Dr
000	16206144	01/25/16	01/26/16	11 hours	0.001	0.14	Grit/Debris	561 Brookview Estates Dr - Cleaned Line
000	08303036	01/29/16	01/29/16	0.5 hours	0.0001		Grit/Debris	898 Porter Rd - Cleaned Line
000	10505032	01/30/16	01/30/16	0.5 hours	0.00001		Roots	1713 15th Ave S - Caused by contractor cleaning

Monthly Overflow Report

Date Range: January, 2016

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	06909009	01/08/16	01/08/16	4 hours	0.001	0.15	Grit/Debris	550 Brick Church Park Dr - Cleaned Line
000	09114099	01/17/16	01/17/16	2.5 hours	0.0001		Grit/Debris	242 Orlando Ave - Cleaned Line
114	Davidson Branch PS	01/26/16	01/26/16	0.25 hours	0.005	0.10	VFD or Soft Start	Faulty heater switch. VFDs faulted on overtemperature.