

Monthly Overflow Report

Date Range: February, 2016

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	08709001	02/10/16	02/10/16	14 hours	0.001	0.01	Force Main	4845 Myra Dr - Repaired force main
000	10512035	02/22/16	02/22/16	3 hours	0.00001	0.01	Grit/Debris	342 Herron Dr - MH lid - Cleaned Line
000	09310147	02/24/16	02/24/16	0.5 hours	0.001	1.12	Grease	200 4th Ave S - Cleaned Line
000	WMN030K025	02/27/16	02/27/16	5 hours	0.001		Grit/Debris	1590 Red Oak Ln - Cleaned Line
000	10401121	02/29/16	02/29/16	3 hours	0.001		Grit/Debris	3510 Wrenwood Dr - Cleaned Line
134	Riverside Drive PS	02/02/16	02/03/16	11.75 hours	0.2	2.12	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	02/03/16	02/03/16	4.33 hours	0.404	1.73	Rainfall	Infiltration/inflow. Station at rated capacity.
178	East Lakemont PS	02/03/16	02/03/16	21 hours	0.3	1.65	Rainfall	Infiltration/inflow. Station at rated capacity.
222	Barker Road	02/03/16	02/03/16	5.83 hours	0.058	1.16	Rainfall	Infiltration/inflow. EQ station at rated capacity.
222	Barker Road	02/15/16	02/17/16	31 hours	0.45	2.17	Rainfall	Infiltration/inflow. EQ station at rated capacity.
226	Cowan St. Relief Bleeder	02/02/16	02/03/16	7.17 hours	0.532	1.58	Rainfall	Infiltration/inflow. Station at rated capacity.
226	Cowan St. Relief Bleeder	02/15/16	02/16/16	5.17 hours	0.052	2.21	Rainfall	Infiltration/inflow. Station at rated capacity.
384	501 Bismark Dr.	02/03/16	02/03/16	12 hours	0.05	1.16	Rainfall	501 Bismark Dr

Monthly Overflow Report

Date Range: February, 2016

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04313084CO	02/03/16	02/03/16	1 hours	0.001	1.41	Grit/Debris	335 Forest Park Dr (cleanout) - Cleaned Line
109	Dry Creek PS	02/17/16	02/19/16	45.51 hours	20.498	2.31	Rainfall	Volume includes river intrusion.
110	Loves Branch PS	02/03/16	02/03/16	3.33 hours	0.126	1.41	Rainfall	Volume includes river intrusion.
112	Gibson Creek PS	02/03/16	02/03/16	2.5 hours	0.37	1.41	Rainfall	Volume includes river intrusion.

Monthly Overflow Report

Date Range: February, 2016

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05010033	02/03/16	02/03/16	14 hours	0.01	1.78	Rainfall	3414 Brick Church Pk
000	11516063	02/03/16	02/03/16	17.5 hours	0.001	1.51	Rainfall	6215 Jocelyn Hollow Rd
000	05008005	02/20/16	02/20/16	7 hours	0.001		Grit/Debris	3502 Dickerson Rd - Cleaned Line
000	12911054	02/28/16	02/28/16	1.5 hours	0.00001		Grit/Debris	802 Marquette Dr - Cleaned Line
114	Davidson Branch PS	02/02/16	02/03/16	14.92 hours	1.205	1.75	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	02/15/16	02/16/16	17.08 hours	0.896	1.96	Rainfall	Infiltration/inflow. Station at rated capacity.
126	Cleeces Ferry PS	02/02/16	02/03/16	4 hours	0.08	2.06	Rainfall	Infiltration/inflow. Station at rated capacity.
128	Bordeaux Hills PS	02/02/16	02/03/16	11.75 hours	0.06	2.12	Rainfall	Infiltration/inflow. Station at rated capacity.
138	Sunliner PS	02/02/16	02/03/16	2.5 hours	0.1	2.06	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	02/02/16	02/03/16	6.5 hours	0.02	2.87	Rainfall	Infiltration/inflow. Station at rated capacity.
217	Basswood Ave.	02/03/16	02/03/16	2.58 hours	0.026	1.75	Rainfall	
346	3438 Briley Park Blvd. N.	02/03/16	02/03/16	14 hours	0.02	1.78	Rainfall	3438 Briley Park Blvd
347	3300 Briley Park Blvd. S.	02/03/16	02/03/16	14 hours	0.17	1.78	Rainfall	3300 Briley Park Blvd S