

Monthly Overflow Report

Date Range: March, 2016

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09308057	03/01/16	03/01/16	1 hours	0.001	0.25	Grit/Debris	601 Crutcher St - Cleaned Line
000	WMN033G019	03/05/16	03/05/16	1.5 hours	0.00001		Grit/Debris	108 Ridgewood Pl - Cleaned grinder service line
000	13615007	03/06/16	03/06/16	1.5 hours	0.001		Grit/Debris	2999 Smith Springs Rd - Cleaned Line
000	09615029	03/08/16	03/08/16	1 hours	0.00001		Roots	3119 Laurel Forest Dr - Cleaned Line
000	14907020	03/08/16	03/08/16	1 hours	0.001		Grease	5161 Rice Rd - Cleaned Line
000	WMN033B023	03/10/16	03/11/16	20 hours	0.0001	0.63	Force Main	145 Forest Trail - Repaired Force Main
000	16210004	03/13/16	03/13/16	1 hours	0.001	1.09	Grease	636 Brook Dr - Cleaned Line
000	16102001	03/14/16	03/14/16	3 hours	0.001	0.76	Grit/Debris	5009 Meta Dr - Cleaned Line
000	WMN033B008	03/16/16	03/17/16	24 hours	0.0001		Force Main	101 Forest Trail - Repaired Force Main
000	17415030	03/17/16	03/17/16	2 hours	0.00001		Grit/Debris	1448 O'Hara Dr - Cleaned Line
000	WMN033B028	03/18/16	03/18/16	1 hours	0.0001		Force Main	6718 Quiet Ln - Repaired Line
000	10402099CO	03/18/16	03/18/16	0.5 hours	0.0001		Grit/Debris	113 30th Ave N (cleanout) - Cleaned Line
131	Hurricane Creek PS	03/27/16	03/27/16	0.5 hours	0.1	0.18	Controller	Pressure transducer level control failed.
178	East Lakemont PS	03/13/16	03/14/16	10 hours	0.15	0.99	Rainfall	Infiltration/inflow. Station at rated capacity.
222	Barker Road	03/13/16	03/14/16	8.84 hours	0.246	0.44	Grit/Debris	Station operating normally.
384	501 Bismark Dr.	03/13/16	03/13/16	9 hours	0.08	1.02	Rainfall	501 Bismark Dr - 150 GPM est.

Monthly Overflow Report

Date Range: March, 2016

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05201086	03/21/16	03/21/16	9 hours	0.0001		Line Break	800 Idlewild Dr - MWS unplugged service line

Monthly Overflow Report

Date Range: March, 2016

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	08008046	03/25/16	03/25/16	1.5 hours	0.0001		Grit/Debris	1490 County Hospital Rd - Cleaned Line
128	Bordeaux Hills PS	03/13/16	03/13/16	8 hours	0.04	0.81	Rainfall	Infiltration/inflow. Station at rated capacity.