

Monthly Overflow Report

Date Range: July, 2016

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	13607014	07/07/16	07/07/16	5 hours	0.03	2.31	Rainfall	177 Timber Ridge - Estimated 50 GPM
000	14711004	07/09/16	07/09/16	2.5 hours	0.001		Grit/Debris	4611 Nolensville Pk - Cleaned Line
000	10807019	07/17/16	07/17/16	1.5 hours	0.0001		Grit/Debris	3108 Elm Hill Pk - Cleaned Line
103	McCrary Creek PS	07/07/16	07/07/16	5.5 hours	0.57	3.18	Rainfall	Infiltration/inflow. Station at rated capacity.
124	Williamson Ferry PS	07/07/16	07/07/16	3.25 hours	0.072	4.39	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	07/07/16	07/07/16	3.92 hours	0.453	2.87	Rainfall	Infiltration/inflow. Station at rated capacity.
158	Farmingham Woods PS	07/07/16	07/07/16	7 hours	0.2	3.18	Rainfall	Infiltration/inflow. Station at rated capacity.
189	Langford Farms PS	07/07/16	07/07/16	9 hours	0.2	3.97	Rainfall	Infiltration/inflow. Station at rated capacity.
222	Barker Road	07/07/16	07/07/16	15.67 hours	2.058	3.18	Rainfall	Infiltration/inflow. Station at rated capacity. EQ Full.
226	Cowan St. Relief Bleeder	07/07/16	07/07/16	12 hours	1.598	4.39	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: July, 2016

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	03411000	07/07/16	07/08/16	23 hours	0.015	4.76	Other/not listed	Seal failed in MHs adjacent to WWTP EQ tank. MHs resealed.
106	Vandiver PS	07/07/16	07/07/16	10.25 hours	1.3	4.80	Rainfall	Infiltration/inflow. Station at rated capacity.
109	Dry Creek PS	07/07/16	07/07/16	6.67 hours	3.078	4.76	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	07/07/16	07/07/16	10.08 hours	1.978	4.76	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	07/07/16	07/07/16	11.42 hours	1.336	4.76	Rainfall	Infiltration/inflow. Station at rated capacity.
123	Lakewood PS	07/07/16	07/07/16	1 hours	0.02	4.80	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	07/07/16	07/07/16	10 hours	0.2	4.76	Rainfall	Infiltration/inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	07/07/16	07/07/16	1 hours	0.01	4.76	Rainfall	Infiltration/inflow. Station at rated capacity.
150	Hidden Acres PS	07/07/16	07/07/16	8 hours	1	4.76	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: July, 2016

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	06001011	07/07/16	07/07/16	14 hours	0.1	4.39	Rainfall	3258 Brick Church Pk - Estimated 150 GPM
000	06001010	07/07/16	07/07/16	14 hours	0.1	4.39	Rainfall	3258 Brick Church Pk - Estimated 150 GPM
000	06001013	07/07/16	07/07/16	14 hours	0.2	4.39	Rainfall	3258 Brick Church Pk - Estimated 200 GPM
000	05010033	07/07/16	07/07/16	14 hours	0.04	4.39	Rainfall	3414 Brick Church Pk - Estimated 50 GPM
346	3438 Briley Park Blvd. N.	07/07/16	07/07/16	19 hours	0.2	4.39	Rainfall	3438 Briley Park Blvd - Estimated 200 GPM
347	3300 Briley Park Blvd. S.	07/07/16	07/07/16	19 hours	0.2	4.39	Rainfall	3300 Briley Park Blvd S - Estimated 200 GPM