

# Monthly Overflow Report

Date Range: October, 2016

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<i>Sanitary Sewer Overflows</i>								
000	08303030	10/03/16	10/03/16	2 hours	0.0001		Grease	1201 Porter Rd - Cleaned Line
000	16406025	10/03/16	10/03/16	2.5 hours	0.0001		Grit/Debris	3514 Pin Hook Rd - Cleaned Line
000	06103021	10/04/16	10/04/16	2 hours	0.001		Grit/Debris	5003 Gallatin Pk - Cleaned Line
000	06103021	10/05/16	10/05/16	3 hours	0.001		Grit/Debris	5003 Gallatin Pk - Cleaned Line
000	10402034	10/23/16	10/23/16	1.5 hours	0.0001		Grit/Debris	3108 Belwood St - Cleaned Line
001B	Central WWTP - Biosolids	10/04/16	10/04/16	1.25 hours	0.005	0.00	Power Related	Recycle pumps faulted. Well backed up into building 35 drains.

# Monthly Overflow Report

Date Range: October, 2016

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	10316055	10/15/16	10/15/16	1 hours	0.0001		Grit/Debris	3909 Whitford Ave - Cleaned Line
000	10208049	10/19/16	10/19/16	5 hours	0.001		Grit/Debris	825 Russleo Dr - Cleaned Line
000	10208037	10/23/16	10/23/16	3.5 hours	0.0001		Grit/Debris	825 Russleo Dr - Cleaned Line
000	08012018	10/24/16	10/24/16	1.5 hours	0.001		Grit/Debris	3251 Viking Rd - Cleaned Line