

# Monthly Overflow Report

Date Range: December, 2016

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	10402034	12/07/16	12/07/16	2.5 hours	0.001		Grit/Debris	3119 Long Blvd alley - Cleaned Line
000	16103002	12/13/16	12/13/16	3.5 hours	0.001	0.13	Roots	517 Brewer Dr - Cleaned Line
000	11709010	12/14/16	12/14/16	3.5 hours	0.001		Grit/Debris	3711 Hilldale Dr - Cleaned Line
000	01215005	12/16/16	12/16/16	0.5 hours	0.0005		Force Main	1428 Springfield Hwy - Repaired FM service
000	09613076	12/20/16	12/20/16	2.5 hours	0.0001		Grit/Debris	2750 Elm Hill Pk - Cleaned Line
000	10402035	12/24/16	12/24/16	1.5 hours	0.0001	1.98	Roots	3110 Belwood St - Cleaned Line
102	Smith Springs PS	12/24/16	12/24/16	11 hours	1	2.05	Rainfall	Infiltration/inflow. Station at rated capacity. EQ Full
134	Riverside Drive PS	12/24/16	12/24/16	11 hours	0.2	2.00	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	12/18/16	12/18/16	2.25 hours	0.195	1.67	Rainfall	Infiltration/inflow. Station at rated capacity.
222	Barker Road	12/18/16	12/18/16	2.5 hours	0.012	1.74	Rainfall	Infiltration/inflow. Station at rated capacity.
222	Barker Road	12/24/16	12/24/16	12.17 hours	0.303	2.34	Rainfall	Infiltration/inflow. Station at rated capacity.

# Monthly Overflow Report

Date Range: December, 2016

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
106	Vandiver PS	12/24/16	12/24/16	6.42 hours	0.102	2.27	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	12/18/16	12/18/16	11 hours	1.014	1.30	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	12/24/16	12/24/16	8.33 hours	1.71	2.22	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	12/18/16	12/18/16	3.25 hours	0.1	1.30	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	12/24/16	12/24/16	12 hours	0.25	2.22	Rainfall	Infiltration/inflow. Station at rated capacity.
150	Hidden Acres PS	12/24/16	12/24/16	18 hours	1.5	2.22	Rainfall	Infiltration/inflow. Station at rated capacity.

# Monthly Overflow Report

Date Range: December, 2016

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	06001013	12/24/16	12/24/16	20 hours	0.2	2.18	Rainfall	3258 Brick Church Pk - Estimated 200 GPM
000	06001011	12/24/16	12/24/16	20 hours	0.06	2.18	Rainfall	3258 Brick Church Pk - Estimated 50 GPM
114	Davidson Branch PS	12/18/16	12/18/16	6.83 hours	0.483	1.45	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	12/24/16	12/24/16	18.25 hours	1.842	1.82	Rainfall	Infiltration/inflow. Station at rated capacity
347	3300 Briley Park Blvd. S.	12/24/16	12/25/16	20 hours	0.1	2.18	Rainfall	3300 Briley Park Blvd S - Estimated 100 GPM