

# Monthly Overflow Report

Date Range: January, 2017

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	13306104	01/02/17	01/02/17	4.5 hours	0.001	0.95	Line Break	430 Atlas Dr - Repaired Line
000	08212032	01/04/17	01/04/17	1 hours	0.0001		Roots	404 N 9th St - Cleaned Line
000	10416001	01/05/17	01/06/17	3 hours	0.00001		Grit/Debris	1504 Compton Ave - Cleaned Line
000	16206112	01/09/17	01/09/17	4 hours	0.0001		Roots	213 Sterry Ct - Cleaned Line
000	09208055	01/11/17	01/11/17	2.5 hours	0.001	0.46	Grit/Debris	1401 Charlotte Ave - Cleaned Line
000	10505075	01/11/17	01/11/17	2.5 hours	0.0001	0.46	Grease	1101 Edgehill Ave - Cleaned Line
000	07307033	01/17/17	01/17/17	1.5 hours	0.001	0.65	Grit/Debris	2405 Fairbrook Dr - Cleaned Line
000	08114032	01/20/17	01/20/17	5 hours	0.001	0.01	Roots	2612 Heiman St - Cleaned Line
000	08313057	01/20/17	01/20/17	1.5 hours	0.00001		Grit/Debris	503 Village Ct - Cleaned Line
000	14805026	01/22/17	01/22/17	1.5 hours	0.00001	0.07	Grit/Debris	3817 Briarcliff Ct - Cleaned Line
000	17202011	01/23/17	01/23/17	1.5 hours	0.001		Grit/Debris	5921 Woodland Hills Dr - Cleaned Line
000	09613009	01/27/17	01/27/17	1 hours	0.001		Roots	2725 McKeigh Dr - Cleaned Line
000	06303017	01/28/17	01/28/17	3 hours	0.001		Grit/Debris	1414 Bryan St - Cleaned Line
134	Riverside Drive PS	01/19/17	01/20/17	13.5 hours	0.3	1.47	Rainfall	Infiltration/inflow. Station at rated capacity.
222	Barker Road	01/19/17	01/20/17	5.58 hours	0.102	1.30	Rainfall	Infiltration/inflow. Station at rated capacity.
384	501 Bismark Dr.	01/19/17	01/20/17	15 hours	0.2	1.30	Rainfall	Est. 200 GPM

---

# Monthly Overflow Report

Date Range: January, 2017

---

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
106	Vandiver PS	01/19/17	01/20/17	2.42 hours	0.008	0.28	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	01/19/17	01/20/17	3.33 hours	0.536	1.26	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	01/19/17	01/20/17	5 hours	0.1	1.26	Rainfall	Infiltration/inflow. Station at rated capacity.

# Monthly Overflow Report

Date Range: January, 2017

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	11501024	01/22/17	01/22/17	4.5 hours	0.00001	0.15	Grit/Debris	932 Rodney Dr - Cleaned Line
114	Davidson Branch PS	01/19/17	01/20/17	16.25 hours	1.351	1.38	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	01/19/17	01/20/17	5 hours	0.02	1.55	Rainfall	Infiltration/inflow. Station at rated capacity.
347	3300 Briley Park Blvd. S.	01/19/17	01/20/17	18 hours	0.03	1.33	Rainfall	3300 Briley Park Blvd S - Est. 25 GPM