

# Monthly Overflow Report

Date Range: February, 2017

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	10404051	02/01/17	02/01/17	1 hours	0.0001		Grease	124 Acklen Park Dr - Cleaned Line
000	08115103	02/07/17	02/07/17	4 hours	0.0001	0.40	Grit/Debris	1911 Heiman St - Cleaned Line
000	17515008	02/08/17	02/09/17	14 hours	0.001	0.13	Line Break	1717 Heil Quaker Blvd - Repaired Line
000	15110002	02/09/17	02/10/17	4 hours	0.001		Grease	7301 Old Nottingham Rd - Cleaned Line
000	09315038	02/16/17	02/16/17	2 hours	0.0001		Grit/Debris	84 University Ct - Cleaned Line
000	01215005	02/23/17	02/23/17	7.5 hours	0.001		Force Main	1554 Springfield Hwy - Repaired Line
000	09216202	02/27/17	02/27/17	2 hours	0.00001	0.07	Grit/Debris	819 18th Ave S - Cleaned Line
161	Longhunter Chase SPS	02/10/17	02/10/17	1.25 hours	0.01	0.00	Other/not listed	Excess water from blockage removal upstream. Station at capacity

---

# Monthly Overflow Report

Date Range: February, 2017

---

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	04309068	02/05/17	02/05/17	0.5 hours	0.001		Grit/Debris	500 Dupont Ave - Cleaned Line

# Monthly Overflow Report

Date Range: February, 2017

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	03213036	02/01/17	02/01/17	1 hours	0.0001		Roots	4379 Summertime Dr - Cleaned Line
000	03901005	02/11/17	02/11/17	1 hours	0.0001		Force Main	4575 Dry Fork Rd - Repaired Line
000	05815039	02/11/17	02/11/17	2.5 hours	0.0001		Grease	4216 Hallmark Rd - Cleaned Line
000	03905002	02/15/17	02/16/17	11.5 hours	0.0001	0.29	Force Main	4575 Dry Fork Rd - Repaired Line
000	03901005	02/25/17	02/25/17	1 hours	0.001		Force Main	4575 Dry Fork Rd - Repaired Line