

Monthly Overflow Report

Date Range: March, 2017

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	11805033	03/03/17	03/03/17	1 hours	0.001		Grit/Debris	1000 Clayton Ave - Cleaned Line
000	11913062	03/07/17	03/07/17	2 hours	0.00001	0.79	Grit/Debris	3023 Nolensville Pk - Cleaned Line
000	14808058	03/11/17	03/11/17	1 hours	0.0001	0.15	Grease	860 Richards Rd - Cleaned Line
000	08311078	03/12/17	03/12/17	1 hours	0.00001		Grit/Debris	2408 Brittany Dr - Cleaned Line
000	08306074	03/12/17	03/12/17	1.5 hours	0.00001		Grit/Debris	198 Manchester Dr - Cleaned Line
000	10412019	03/15/17	03/15/17	6.5 hours	0.001		Grit/Debris	1901 15th Ave S - Cleaned Line
000	14812054	03/18/17	03/18/17	1 hours	0.00001	0.12	Grit/Debris	117 Dowdy Ct - Cleaned Line
000	14909023	03/18/17	03/18/17	3 hours	0.0001	0.09	Grease	4700 Apollo Dr - Cleaned Line
000	01215005	03/18/17	03/18/17	5 hours	0.001	0.24	Force Main	1120 Springfield Hwy - Repaired Line (contractor hit)
000	13316098	03/23/17	03/23/17	1 hours	0.001		Grit/Debris	100 Tanglewood Ct - Cleaned Line
000	01215005	03/25/17	03/25/17	7 hours	0.001		Force Main	1120 Springfield Hwy - Repaired Line (contractor hit)
000	08103012	03/26/17	03/26/17	3 hours	0.001	0.14	Grit/Debris	1805 Hughes St - Cleaned Line
134	Riverside Drive PS	03/09/17	03/09/17	0.5 hours	0.01	0.95	Power Related	Power failure

Monthly Overflow Report

Date Range: March, 2017

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	----------------	----------	----------------	---------

Sanitary Sewer Overflows

000	05315021	03/02/17	03/02/17	9 hours	0.001		Grit/Debris	118 Riner Ct - Cleaned Line
-----	----------	----------	----------	---------	-------	--	-------------	-----------------------------

Monthly Overflow Report

Date Range: March, 2017

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

000	15901007	03/03/17	03/03/17	12 hours	0.001		Line Break	27 Park Meadows - Bypass pump & repair
000	14513062	03/30/17	03/30/17	2 hours	0.0001	0.14	Roots	1623 Otter Creek Rd - Cleaned Line