

Monthly Overflow Report

Date Range: June, 2017

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	07404074	06/02/17	06/02/17	2.5 hours	0.001		Grit/Debris	735 Linden Green - Cleaned Line
000	10401099	06/06/17	06/08/17	54 hours	0.0001	0.28	Roots	364 Normandy Dr - Cleaned Line
000	14814037	06/07/17	06/07/17	1.5 hours	0.0001		Grease	4825 Gillespie Dr - Cleaned Line
000	09306299	06/12/17	06/12/17	0.5 hours	0.0005		Grit/Debris	121 4th Ave S - Cleaned Line
000	07109006	06/13/17	06/13/17	1.5 hours	0.0025	0.06	Grit/Debris	1500 Lock Rd - Contractor repaired pump
000	10401097	06/23/17	06/23/17	2 hours	0.0001	0.30	Roots	344 Normandy Cir - Cleaned Line
000	16203080	06/28/17	06/28/17	1.5 hours	0.0001		Roots	4947 Karen Ray Dr - Cleaned Line
000	11805033	06/29/17	06/30/17	19.5 hours	0.001		Grit/Debris	3021 Lealand Ln - Cleaned Line
000	14708011	06/30/17	07/01/17	3.5 hours	0.00005		Rags	3737 Faulkner Dr - Cleaned Line
102	Smith Springs PS	06/18/17	06/19/17	9 hours	0.652	2.22	Rainfall	Infiltration/inflow. Station at rated capacity. EQ full.
134	Riverside Drive PS	06/15/17	06/15/17	1 hours	0.05	1.09	Power Related	Power failure
140	28th Avenue PS / Centennial	06/16/17	06/16/17	2.83 hours	0.228	0.90	Force Main	Repair 48" FM at Rosa Parks and Athens Way.
179	Fairway Center PS	06/16/17	06/16/17	9 hours	4.5	0.90	Force Main	28th avenue 48 inch force main repair

Monthly Overflow Report

Date Range: June, 2017

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05303017	06/17/17	06/17/17	2 hours	0.001		Grit/Debris	1502 Bryan St - Cleaned Line