

Monthly Overflow Report

Date Range: July, 2017

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	07210036	07/03/17	07/03/17	6.5 hours	0.00001	0.36	Line Break	1118 Litton Ave - Repaired Line
000	08603046	07/06/17	07/06/17	1 hours	0.00001	1.55	Grit/Debris	925 Moleah Ct - Cleaned Line
000	10616017	07/13/17	07/13/17	1.5 hours	0.0001		Grease	314 Philfre Ct - Cleaned Line
000	14701058	07/17/17	07/17/17	2 hours	0.00001		Grit/Debris	366 Binkley Dr - Cleaned Line
000	11909117	07/18/17	07/18/17	1.5 hours	0.00001		Grit/Debris	230 Thompson Ln - Cleaned Line
000	09203044	07/27/17	07/27/17	2 hours	0.0001		Grit/Debris	2202 Albion St - Cleaned Line
000	09303042	07/27/17	07/27/17	2 hours	0.00001		Grit/Debris	2202 Albion St - Cleaned Line

Monthly Overflow Report

Date Range: July, 2017

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	00714006	07/05/17		Unknown		0.60	Force Main	2200 Kayla Dr (sewer valve) - Repaired FM
000	01215005	07/20/17	07/20/17	1 hours	0.00001		Force Main	112 East End Rd - Repaired Force Main

Monthly Overflow Report

Date Range: July, 2017

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	14303026	07/25/17	07/25/17	9 hours	0.001	1.44	Roots	11 Vaughns Gap Rd - Cleaned Line
114	Davidson Branch PS	07/03/17	07/03/17	3.92 hours	0.184	0.34	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	07/15/17	07/15/17	0.42 hours	0.001	0.63	Rainfall	Infiltration/inflow. Station at rated capacity.