

Monthly Overflow Report

Date Range: August, 2017

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	16206114	08/02/17	08/02/17	2 hours	0.00001		Grease	221 Sterry Ct - Cleaned Line
000	14812074	08/11/17	08/11/17	19.5 hours	0.00001		Roots	888 Irma Ct - Cleaned Line
130	Brown's Creek PS	08/15/17	08/15/17	0.33 hours	0.025		0.53	Power Related Power fail on both electrical feeds.
130	Brown's Creek PS	08/31/17	09/01/17	9 hours	3.679	6.70	Rainfall	Infiltration/inflow. Station at rated capacity.
134	Riverside Drive PS	08/22/17	08/22/17	0.5 hours	0.01	1.55	Power Related	Power failure
134	Riverside Drive PS	08/31/17	09/01/17	28 hours	0.5	7.97	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	08/31/17	09/01/17	19.17 hours	11.286	8.75	Rainfall	Infiltration/inflow. Station at rated capacity.
155	Woodland Point PS #1	08/22/17	08/23/17	13 hours	0.2	0.25	Other/not listed	Operator error. Alarm not communicated to response crew.
222	Barker Road	08/31/17	09/02/17	38.92 hours	4.002	5.06	Rainfall	Infiltration/inflow. EQ station operating correctly.
226	Cowan St. Relief Bleeder	08/31/17	09/02/17	31 hours	4.291	6.94	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: August, 2017

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	01215005	08/01/17	08/02/17	16 hours	0.0001		Force Main	2200 Kayla Dr - Repaired Force Main
000	00714002	08/02/17	08/02/17	0.5 hours	0.00025		Force Main	1526 Springfield Hwy - Repaired Force Main
000	01215005	08/12/17	08/12/17	1.5 hours	0.00001		Force Main	2204 Kayla Ct - Repaired Force Main
106	Vandiver PS	08/31/17	09/01/17	20 hours	1.812	5.59	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	08/31/17	09/01/17	16.08 hours	2.013	7.18	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	08/31/17	09/02/17	39 hours	2.211	7.18	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: August, 2017

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	06011008	08/27/17	08/27/17	0.5 hours	0.0001		Grit/Debris	2816 Surf Dr - Cleaned Line
000	05911036	08/31/17	09/01/17	12 hours	0.001	9.23	Rainfall	3824 Cravath Dr
107	West Park PS	08/31/17	09/01/17	16.33 hours	3.448	5.59	Rainfall	Infiltration/inflow. EQ full.
114	Davidson Branch PS	08/07/17	08/07/17	0.83 hours	0.007	1.82	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	08/31/17	09/01/17	26.5 hours	2.218	5.59	Rainfall	Infiltration/inflow. Station at rated capacity.
136	River Drive PS	08/31/17	09/01/17	7.67 hours	0.27	8.75	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	08/31/17	09/01/17	24 hours	0.1	7.07	Rainfall	Infiltration/inflow. Station at rated capacity.
217	Basswood Ave.	08/31/17	09/01/17	23.92 hours	1.872	5.59	Rainfall	Infiltration/inflow. Station at rated capacity.