

Monthly Overflow Report

Date Range: September, 2017

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05414038	09/01/17	09/02/17	9.5 hours	0.001	5.59	Force Main	209 Rising Sun Ln - Repaired Force Main
000	11907146	09/01/17	09/02/17	29 hours	0.52	5.83	Rainfall	0 Old Glenrose Ave - Est 300 GPM
000	07309066	09/01/17	09/02/17	29 hours	0.17	6.94	Rainfall	2301 Cooper Terr - Est 100 GPM
000	11907049	09/01/17	09/02/17	29 hours	0.03	5.83	Rainfall	765 Old Glenrose - Est 20 GPM
000	11907147	09/01/17	09/02/17	21 hours	0.25	5.83	Rainfall	0 Old Glenrose Ave - Est 200 GPM
000	11907143	09/01/17	09/02/17	21 hours	0.03	5.83	Rainfall	747 Old Glenrose Ave - Est 20 GPM
000	13316045	09/07/17	09/07/17	3 hours	0.001		Roots	295 Garry Dr - Cleaned Line
000	10514002	09/10/17	09/10/17	3.5 hours	0.00001		Grit/Debris	838 Glen Ave - Cleaned Line
000	10701006	09/19/17	09/19/17	2 hours	0.0001	0.74	Grit/Debris	1811 Elm Hill Pk - Cleaned Line
000	15001017	09/29/17	09/29/17	1 hours	0.001		Line Break	2908 Mossdale Dr - Repaired Line
102	Smith Springs PS	09/01/17	09/01/17	17.83 hours	1.314	4.87	Rainfall	Infiltration/inflow. Station at rated capacity. EQ Full.
124	Williamson Ferry PS	09/01/17	09/01/17	0.83 hours	0.018	6.94	Rainfall	Infiltration/inflow. Station at rated capacity.
134	Riverside Drive PS	09/07/17	09/07/17	0.5 hours	0.02	0.00	Power Related	Power failure.
179	Fairway Center PS	09/01/17	09/02/17	27 hours	1	7.52	Rainfall	Infiltration/inflow. Station at rated capacity.
184	Munn Rd PS	09/01/17	09/01/17	6.5 hours	0.2	4.85	Rainfall	Infiltration/inflow. Station at rated capacity.
188	South Oak Hill PS	09/01/17	09/01/17	6 hours	0.5	4.72	Rainfall	Infiltration/inflow. Station at rated capacity.
374	Foster Ave	09/01/17	09/02/17	29 hours	0.35	5.83	Rainfall	2803 Foster Ave - Est 200 GPM
384	501 Bismark Dr.	09/01/17	09/02/17	32 hours	0.96	6.70	Rainfall	501 Bismark Dr - Est 500 GPM

Monthly Overflow Report

Date Range: September, 2017

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04309042	09/01/17	09/02/17	27 hours	0.08	7.18	Rainfall	510 N Dupont Ave - Est 50 GPM
000	03413034	09/01/17	09/02/17	28 hours	0.34	7.18	Rainfall	1442 Gallatin Pk - Est 200 GPM
109	Dry Creek PS	09/01/17	09/02/07	15 hours	6.089	7.18	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	09/01/17	09/01/17	14 hours	0.3	6.76	Rainfall	Infiltration/inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	09/01/17	09/01/17	2 hours	0.01	6.76	Rainfall	Infiltration/inflow. Station at rated capacity.
303	N. Dupont Avenue	09/01/17	09/02/17	27 hours	0.16	7.18	Rainfall	504 N Dupont Ave - Est 100 GPM

Monthly Overflow Report

Date Range: September, 2017

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05911027	09/01/17	09/02/17	29 hours	0.09	9.23	Rainfall	701 Rowan Dr - Est 50 GPM
000	06001013	09/01/17	09/02/17	29 hours	0.52	9.23	Rainfall	3258 Brick Church Pk - Est 300 GPM
000	09004005	09/01/17	09/02/17	17 hours	0.05	5.59	Rainfall	6601 Centennial Blvd - Est 50 GPM
000	05911028	09/01/17	09/02/17	29 hours	0.09	9.23	Rainfall	709 Rowan Dr - Est 50 GPM
000	06001011	09/01/17	09/02/17	29 hours	0.52	9.23	Rainfall	3258 Brick Church Pk - Est 300 GPM
000	05911029	09/01/17	09/02/17	29 hours	0.03	9.23	Rainfall	717 Rowan Dr - Est 20 GPM
000	05910048	09/01/17	09/02/17	29 hours	0.52	9.23	Rainfall	748 Rowan Dr - Est 300 GPM
000	05010033	09/02/17	09/02/17	10 hours	0.01	9.23	Rainfall	3414 Brick Church Pk - Est 20 GPM
101	Bordeaux Hospital PS	09/01/17	09/01/17	6.25 hours	0.1	8.66	Rainfall	Infiltration/inflow. Station at rated capacity.
126	Cleeces Ferry PS	09/01/17	09/01/17	6 hours	0.2	5.46	Rainfall	Infiltration/inflow. Station at rated capacity.
128	Bordeaux Hills PS	09/01/17	09/01/17	14.5 hours	0.1	8.66	Rainfall	Infiltration/inflow. Station at rated capacity.
194	Germantown PS	09/01/17	09/01/17	3 hours	0.01	9.17	Rainfall	Infiltration/inflow. Station at rated capacity.
346	3438 Briley Park Blvd. N.	09/01/17	09/02/17	38 hours	0.46	9.23	Rainfall	3438 Briley Park Blvd - Est 200 GPM
347	3300 Briley Park Blvd. S.	09/01/17	09/02/17	38 hours	0.46	9.23	Rainfall	3300 Briley Park Blvd S - Est 200 GPM