

# Monthly Overflow Report

Date Range: November, 2017

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	11909113	11/07/17	11/08/17	27 hours	0.81	3.72	Rainfall	2803 Foster Ave (Est 500 GPM)
000	11913092	11/07/17	11/07/17	5 hours	0.006	3.72	Rainfall	2932 Louise Dr (Est 20 GPM)
000	16510001	11/07/17	11/07/17	2 hours	0.001	3.56	Rainfall	3959 Pin Hook Rd
000	16213018	11/07/17	11/08/17	32 hours	0.001	4.02	Rainfall	452 Cedarvalley Dr
000	Hillview PS	11/07/17	11/07/17	6 hours	0.1	5.79	Rainfall	Infiltration/inflow. Station at rated capacity. Hillview Sewer
000	13607014	11/07/17	11/08/17	23 hours	0.028	3.56	Rainfall	177 Timber Ridge Dr (Est 20 GPM)
000	16213007	11/07/17	11/07/17	8 hours	0.001	4.02	Rainfall	452 Cedarvalley Dr
000	16112063	11/14/17	11/15/17	24 hours	0.001		Line Break	0 Swiss Ave - Repaired Line (svc line blocking main)
000	13413028	11/16/17	11/16/17	1 hours	0.001		Grease	209 Paragon Mills Rd - Cleaned Line
000	13413029	11/16/17	11/16/17	1 hours	0.001		Grease	209 Paragon Mills Rd - Cleaned Line
000	10704055	11/17/17	11/17/17	2 hours	0.001		Roots	2530 Perimeter Place Dr - Cleaned Line
000	08104099	11/17/17	11/17/17	1.5 hours	0.00001		Grit/Debris	100 French Landing Dr - Cleaned Line
102	Smith Springs PS	11/07/17	11/07/17	21.83 hours	2.039	3.56	Rainfall	Infiltration/inflow. Station at rated capacity. EQ full.
125	Hopedale PS	11/07/17	11/07/17	2.5 hours	0.02	4.02	Rainfall	Infiltration/inflow. Station at rated capacity.
131	Hurricane Creek PS	11/07/17	11/07/17	15 hours	1	5.76	Rainfall	Infiltration/inflow. Station at rated capacity.
134	Riverside Drive PS	11/07/17	11/07/17	13 hours	0.2	2.42	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	11/07/17	11/07/17	18.25 hours	5.574	2.42	Rainfall	Infiltration/inflow. Station at rated capacity.
158	Farmingham Woods PS	11/07/17	11/07/17	5 hours	0.15	3.05	Rainfall	Infiltration/inflow. Station at rated capacity.
159	Summerfield SPS	11/07/17	11/07/17	10 hours	0.1	5.76	Rainfall	Infiltration/inflow. Station at rated capacity.
161	Longhunter Chase SPS	11/07/17	11/08/17	24 hours	1	5.76	Rainfall	Infiltration/inflow. Station at rated capacity.
176	Dodson Chapel PS	11/21/17	11/21/17	0.75 hours	0.135	0.00	Power Related	Automatic transfer switch failure
181	South Shore SPS	11/07/17	11/07/17	16 hours	0.1	5.76	Rainfall	Infiltration/inflow. Station at rated capacity.
187	Peppertree PS	11/07/17	11/07/17	12.5 hours	0.15	5.76	Rainfall	Infiltration/inflow. Station at rated capacity.
188	South Oak Hill PS	11/06/17	11/07/17	11.5 hours	0.7	5.79	Rainfall	Infiltration/inflow. Station at rated capacity.

Thursday, December 14, 2017

Page 1 of 4

# Monthly Overflow Report

Date Range: November, 2017

197	Brentwood Villa P.S.	11/07/17	11/07/17	3.75 hours	0.02	5.79	Rainfall	Infiltration/inflow. Station at rated capacity.
222	Barker Road	11/07/17	11/08/17	19.5 hours	1.476	3.05	Rainfall	Infiltration/inflow. Station at rated capacity. EQ full.
384	501 Bismark Dr.	11/07/17	11/08/17	34.5 hours	1	3.05	Rainfall	501 Bismark Dr (Est 500 GPM)

# Monthly Overflow Report

Date Range: November, 2017

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	04309074	11/10/17	11/10/17	1 hours	0.00001		Line Break	430 Cumberland Ave - Repaired Line (broken by contractor)
000	04302023	11/18/17	11/18/17	4 hours	0.00001	0.33	Roots	616 Mayview Dr - Cleaned Line
000	01215005	11/02/17	11/03/17	28 hours	0.000025		Force Main	2208 Kayla Dr - Repaired FM
000	00714040	11/27/17	11/28/17	29 hours	0.0001		Force Main	1900 Tinnin Rd - Repaired Force Main
106	Vandiver PS	11/07/17	11/07/17	1.25 hours	0.006	1.57	Rainfall	Infiltration/inflow. Station at rated capacity.
109	Dry Creek PS	11/07/17	11/07/17	0.08 hours	0.001	1.58	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	11/07/17	11/07/17	4.58 hours	0.661	1.58	Rainfall	Infiltration/inflow. Station at rated capacity.

# Monthly Overflow Report

Date Range: November, 2017

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	11613023	11/07/17	11/07/17	12 hours	0.001	3.60	Rainfall	5109 Boxcroft Pl
000	09115063	11/07/17	11/07/17	0.5 hours	0.00001	2.89	Grit/Debris	5201 Nevada Ave - Cleaned Line
000	09004005	11/07/17	11/07/17	9.5 hours	0.0057	2.89	Rainfall	6601 Centennial Blvd (Est 10 GPM)
000	06007017	11/17/17	11/17/17	3 hours	0.00001		Grease	2921 Rich Acres Dr - Cleaned Line
107	West Park PS	11/07/17	11/07/17	13.25 hours	3.22	2.89	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	11/07/17	11/07/17	22.58 hours	2.443	2.89	Rainfall	Infiltration/inflow. Station at rated capacity.
126	Cleeces Ferry PS	11/06/17	11/07/17	10 hours	0.2	2.89	Rainfall	Infiltration/inflow. Station at rated capacity.
128	Bordeaux Hills PS	11/07/17	11/07/17	7 hours	0.05	2.42	Rainfall	Infiltration/inflow. Station at rated capacity.
137	Harpeth Trace II PS	11/07/17	11/07/17	1 hours	0.01	5.79	Rainfall	Infiltration/inflow. Station at rated capacity.
138	Sunliner PS	11/06/17	11/07/17	5 hours	0.2	2.89	Rainfall	Infiltration/inflow. Station at rated capacity.
217	Basswood Ave.	11/07/17	11/07/17	17.92 hours	1.001	2.89	Rainfall	516 Basswood Ave