

Monthly Overflow Report

Date Range: December, 2017

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	06105014	12/01/17	12/01/17	0.5 hours	0.0001		Grease	700 Maple PI - Cleaned Line
000	11802041	12/04/17	12/04/17	3 hours	0.00001		Grit/Debris	2501 Franklin Pk - Cleaned Line
000	00714006	12/05/17	12/05/17	3 hours	0.00001	0.60	Force Main	2200 Kayla Dr - Repaired Force Main
000	16013009	12/06/17	12/06/17	2 hours	0.0001		Grit/Debris	5566 Franklin Pike Cir - Cleaned Line
000	09211074	12/07/17	12/07/17	1 hours	0.0001		Grit/Debris	340 23rd Ave N - Cleaned Line
000	07404011	12/09/17	12/09/17	3 hours	0.00001		Roots	123 Jacksonian Dr - Cleaned Line
000	09212098	12/11/17	12/11/17	2 hours	0.0001		Grit/Debris	1625 Broadway - Cleaned Line
000	15004039	12/13/17	12/13/17	1 hours	0.00001		Grit/Debris	1105 Scenic Lake Ct - Cleaned Line
000	08201001	12/18/17	12/19/17	24 hours	0.001	0.13	Line Break	1600 3rd Ave N - Repaired Line
000	09213041	12/20/17	12/20/17	1 hours	0.0001	1.50	Grit/Debris	3500 Charlotte Ave - Cleaned Line
000	11712035	12/21/17	12/21/17	1 hours	0.0001		Grit/Debris	1024 Woodmont Blvd - Cleaned Line
000	09510045	12/23/17	12/24/17	34 hours	0.001	2.50	Rainfall	2128 Sanborn Dr
000	08316011	12/23/17	12/23/17	4.5 hours	0.001	2.50	Rainfall	2665 Barclay Dr
000	10705028	12/23/17	12/24/18	24 hours	0.001	2.50	Rainfall	710 Elissa Dr
000	09316102	12/23/17	12/23/17	0.25 hours	0.00001	2.68	Grit/Debris	60 Maury St - Cleaned Line
102	Smith Springs PS	12/23/17	12/23/17	17.42 hours	1.935	2.75	Rainfall	Infiltration/inflow. Station at rated capacity. EQ Full.
103	McCroy Creek PS	12/23/17	12/23/17	2.75 hours	0.038	2.59	Rainfall	Infiltration/inflow. Station at rated capacity.
124	Williamson Ferry PS	12/23/17	12/24/17	20.34 hours	0.416	2.96	Rainfall	Infiltration/inflow. Station at rated capacity.
130	Brown's Creek PS	12/23/17	12/24/17	22.42 hours	0.238	2.59	Rainfall	Infiltration/inflow. Station at rated capacity.
134	Riverside Drive PS	12/22/17	12/23/17	24 hours	0.5	3.08	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	12/23/17	12/24/17	32 hours	4.467	3.08	Rainfall	Infiltration/inflow. Station at rated capacity.
158	Farmingham Woods PS	12/23/17	12/23/17	9 hours	0.3	2.58	Rainfall	Infiltration/inflow. Station at rated capacity.
183	Mill Creek PS	12/23/17	12/24/17	20 hours	0.2	2.59	Rainfall	Infiltration/inflow. Station at rated capacity.
188	South Oak Hill PS	12/23/17	12/23/17	8.5 hours	0.5	3.67	Rainfall	Infiltration/inflow. Station at rated capacity.
222	Barker Road	12/22/17	12/25/17	47.42 hours	3.336	2.59	Rainfall	Infiltration/inflow. Station at rated capacity.
226	Cowan St. Relief Bleeder	12/23/17	12/23/17	11.83 hours	1.364	2.96	Rainfall	Infiltration/inflow. Station at rated capacity.

Thursday, January 11, 2018

Page 1 of 3

Monthly Overflow Report

Date Range: December, 2017

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04312001	12/10/17	12/10/17	2.5 hours	0.0001		Grit/Debris	151 Rio Vista Dr - Cleaned Line
000	04306061	12/28/17	12/28/17	2 hours	0.0001		Grit/Debris	222 Becklea Dr - Cleaned Line
000	01215005	12/02/17	12/02/17	6 hours	0.00001		Force Main	2224 Kayla Dr - Repaired Force Main
106	Vandiver PS	12/22/17	12/23/17	20.33 hours	2.167	3.79	Rainfall	Infiltration/inflow. Station at rated capacity.
109	Dry Creek PS	12/23/17	12/23/17	8.75 hours	7.738	3.43	Rainfall	Infiltration/inflow. Station operating correctly.
110	Loves Branch PS	12/22/17	12/23/17	10.5 hours	1.107	3.43	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	12/22/17	12/23/17	12.42 hours	2.018	3.43	Rainfall	Infiltration/inflow. Station at rated capacity.
123	Lakewood PS	12/23/17	12/23/17	6 hours	0.1	3.75	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	12/23/17	12/23/17	17 hours	0.4	3.08	Rainfall	Infiltration/inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	12/23/17	12/23/17	6.5 hours	0.05	3.38	Rainfall	Infiltration/inflow. Station at rated capacity.
150	Hidden Acres PS	12/23/17	12/23/17	10 hours	1	3.38	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: December, 2017

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	07007062	12/16/17	12/16/17	3 hours	0.00001		Grit/Debris	1005 Alice St - Contractor removed plug
000	14505043	12/20/17	12/20/17	1.5 hours	0.0001	0.90	Grit/Debris	1770 Tyne Blvd - Cleaned Line
000	05911027	12/23/17	12/24/17	20.5 hours	0.001	3.64	Rainfall	701 Rowan Dr
000	06001009	12/23/17	12/24/17	14 hours	0.001	3.64	Rainfall	3258 Brick Church Pk
101	Bordeaux Hospital PS	12/23/17	12/23/17	5 hours	0.1	3.08	Rainfall	Infiltration/inflow. Station at rated capacity.
107	West Park PS	12/23/17	12/24/17	25 hours	5.595	2.57	Controller	Duty Station at rated capacity. EQ station controller failure.
114	Davidson Branch PS	12/20/17	12/20/17	8.5 hours	0.623	1.71	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	12/22/17	12/23/17	23.5 hours	1.948	2.57	Rainfall	Infiltration/inflow. Station at rated capacity.
126	Cleeces Ferry PS	12/23/17	12/23/17	5 hours	0.1	1.73	Rainfall	Infiltration/inflow. Station at rated capacity.
128	Bordeaux Hills PS	12/23/17	12/23/17	11 hours	0.1	3.08	Rainfall	Infiltration/inflow. Station at rated capacity.
136	River Drive PS	12/23/17	12/23/17	3.33 hours	0.037	3.08	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	12/22/17	12/23/17	12 hours	0.05	3.33	Rainfall	Infiltration/inflow. Station at rated capacity.
217	Basswood Ave.	12/23/17	12/24/17	19.5 hours	1.009	2.57	Rainfall	516 Basswood Ave