

Monthly Overflow Report

Date Range: April, 2018

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	13214031	04/05/18	04/06/18	32 hours	0.001	0.19	Line Break	4628 Churchwood Dr - Repaired Line
000	10513150	04/10/18	04/10/18	3.5 hours	0.001		Grit/Debris	2301 10th Ave S - Cleaned Line
000	17214003	04/24/18	04/24/18	1.5 hours	0.001	2.27	Grit/Debris	608 Mt Pisgah Ct - Cleaned Line
102	Smith Springs PS	04/23/18	04/23/18	1.17 hours	0.049	2.66	Rainfall	Infiltration/inflow. EQ full.
130	Browns Creek PS	04/23/18	04/24/18	27.75 hours	0.41	2.52	Rainfall	Infiltration/inflow. Station at rated capacity.
134	Riverside Drive PS	04/15/18	04/15/18	17 hours	0.3	1.94	Rainfall	Infiltration/inflow. Station at rated capacity.
134	Riverside Drive PS	04/22/18	04/22/18	31.75 hours	0.5	2.55	Rainfall	Infiltration/inflow. Station at rated capacity.
158	Farmingham Woods PS	04/15/18	04/16/18	19 hours	0.6	2.08	Rainfall	Infiltration/inflow. Station at rated capacity.
158	Farmingham Woods PS	04/23/18	04/23/18	0.75 hours	0.02	2.80	Rainfall	Infiltration/inflow. Station at rated capacity.
161	Longhunter Chase SPS	04/15/18	04/15/18	14 hours	0.6	2.32	Rainfall	Infiltration/inflow. Station at rated capacity.
161	Longhunter Chase SPS	04/23/18	04/23/18	16 hours	0.6	2.46	Rainfall	Infiltration/inflow. Station at rated capacity.
183	Mill Creek PS	04/23/18	04/24/18	23 hours	0.2	3.32	Rainfall	Infiltration/inflow. Station at rated capacity.
222	149 Barker Road	04/15/18	04/15/18	7.5 hours	0.139	2.08	Rainfall	Infiltration/inflow. Station at rated capacity.
222	149 Barker Road	04/22/18	04/25/18	48.67 hours	3.103	3.44	Rainfall	Infiltration/inflow. Station at rated capacity.
226	Cowan St. Relief Bleeder	04/23/18	04/24/18	12 hours	0.466	2.41	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: April, 2018

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	04410012	04/08/18	04/09/18	17.5 hours	0.001		Grit/Debris	1406 Donelson Ave - Cleaned Line
106	Vandiver PS	04/23/18	04/24/18	12.92 hours	1.339	4.78	Rainfall	Infiltration/inflow. Station at rated capacity.
109	Dry Creek PS	04/16/18	04/16/18	0.08 hours	0.01	0.69	Rainfall	Infiltration/inflow. Station at rated capacity.
109	Dry Creek PS	04/23/18	04/24/18	3.83 hours	0.527	4.15	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	04/23/18	04/23/18	2.83 hours	0.057	3.97	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	04/22/18	04/24/18	14.59 hours	0.313	4.15	Rainfall	Infiltration/inflow. Station at rated capacity.
123	Lakewood PS	04/23/18	04/23/18	3 hours	0.05	5.75	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	04/23/18	04/23/18	8 hours	0.2	3.97	Rainfall	Infiltration/inflow. Station at rated capacity.
150	Hidden Acres PS	04/23/18	04/23/18	7.5 hours	0.7	3.97	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: April, 2018

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	10408036	04/08/18	04/08/18	3 hours	0.00001		Grit/Debris	1800 21st Ave S alley - Cleaned Line
000	14306002	04/11/18	04/11/18	2.5 hours	0.001		Roots	0 Harpeth Trace Dr - Cleaned Line
000	14306001	04/11/18	04/11/18	2.5 hours	0.001		Roots	0 Harpeth Trace Dr - Cleaned Line
000	05911027	04/23/18	04/24/18	24 hours	0.001	2.80	Rainfall	701 Rowan Dr
114	Davidson Branch PS	04/15/18	04/15/18	15.08 hours	0.586	1.72	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	04/22/18	04/23/18	22.34 hours	1.384	2.10	Rainfall	Infiltration/inflow. Station at rated capacity.
128	Bordeaux Hills PS	04/23/18	04/23/18	0.75 hours	0.004	2.55	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	04/22/18	04/23/18	16.5 hours	0.05	2.77	Rainfall	Infiltration/inflow. Station at rated capacity.
172	Hillview	04/15/18	04/15/18	7 hours	0.15	1.64	Rainfall	Infiltration/inflow. Station at rated capacity.
172	Hillview	04/23/18	04/24/18	33.25 hours	0.6	2.67	Rainfall	Infiltration/inflow. Station at rated capacity.