

Monthly Overflow Report

Date Range: May, 2018

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09705016	05/01/18	05/02/18	23 hours	0.001		Force Main	3616 Central Pk - Repaired Force Main
000	10501013	05/05/18	05/05/18	3 hours	0.001	0.91	Grit/Debris	1008 Southside Ct - Cleaned Line
000	12001098	05/07/18	05/08/18	21 hours	0.00001	0.04	Grit/Debris	722 Winthorne Dr - Cleaned Line
000	11703105	05/12/18	05/12/18	3 hours	0.00001		Grit/Debris	2118 Sharondale Dr - Cleaned Line
000	09501048	05/13/18	05/13/18	4.5 hours	0.001		Grit/Debris	201 Lisa Ln - Cleaned Line
000	Baronswood Dr PS	05/15/18	05/15/18	2 hours	0.01	0.00	Other/not listed	Operator error. Crews not notified of power failure.
000	WMN56G005	05/24/18	05/24/18	4 hours	0.001		Grease	1547 Pumpkin Ridge Ct - Cleaned Line
134	Riverside Drive PS	05/18/18	05/18/18	0.75 hours	0.01	1.66	Rainfall	Infiltration/inflow. Station at rated capacity.
134	Riverside Drive PS	05/20/18	05/21/18	24.25 hours	0.4	1.90	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: May, 2018

Dry Creek WWTP NPDES# TN 0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	01215005	05/21/18	05/21/18	10 hours	0.001	1.25		Force Main 1314 Springfield Hwy - Repaired FM

Monthly Overflow Report

Date Range: May, 2018

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	14306032	05/24/18	05/24/18	5.5 hours	0.001		Roots	0 Harpeth Trace Dr - Cleaned Line
145	Joelton PS	05/20/18	05/20/18	2 hours	0.006	2.12	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	05/22/18	05/22/18	1.45 hours	0.004	1.41	Rainfall	Infiltration/inflow. Station at rated capacity.