

# Monthly Overflow Report

Date Range: July, 2018

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	06302022	07/09/18	07/09/18	0.5 hours	0.0001		Grit/Debris	0 Pawnee Tr - Cleaned Line
000	16401001	07/28/18	07/28/18	5 hours	0.0001		Grit/Debris	3035 Hamilton Church Rd - Cleaned Line
000	15004030	07/31/18	07/31/18	2.5 hours	0.0001		Line Break	3520 Shakertown Rd - Repaired Line
161	Longhunter Chase SPS	07/15/18	07/15/18	1.5 hours	0.06	2.91	Rainfall	Infiltration/inflow. Station at rated capacity.

---

# Monthly Overflow Report

Date Range: July, 2018

---

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
150	Hidden Acres PS	07/25/18	07/25/18	2 hours	0.2	0.00	Mechanical	Station not pumping at rated capacity.

---

# Monthly Overflow Report

Date Range: July, 2018

---

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<i>Sanitary Sewer Overflows</i>								
000	11612021	07/18/18	07/19/18	23.5 hours	0.001		Grit/Debris	3903 Abbott Martin Rd - Cleaned Line
000	10302027	07/21/18	07/21/18	4 hours	0.00001		Grit/Debris	5701 Maudina Ave - Cleaned Line