

Monthly Overflow Report

Date Range: September, 2018

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	10713073	09/06/18	09/06/18	2 hours	0.0001	0.35	Grit/Debris	945 Patricia Dr - Cleaned Line
000	08303028	09/06/18	09/06/18	1.5 hours	0.0001	0.35	Grit/Debris	440 Gentry Dr - Cleaned Line
000	16303012	09/10/18	09/10/18	2.5 hours	0.001		Grit/Debris	660 Bell Rd - Cleaned Line
000	09516059	09/13/18	09/13/18	2.5 hours	0.0001		Grit/Debris	2500 Perimeter Place Dr - Cleaned Line
000	15004039	09/13/18	09/13/18	0.5 hours	0.00001		Excessive Flow	1105 Scenic Lake Ct - MNPS private pump station
000	08102061	09/14/18	09/14/18	4.5 hours	0.001		Grit/Debris	2233 24th Ave N - Cleaned Line
000	18101036	09/17/18	09/17/18	1.5 hours	0.001		Grit/Debris	6412 Nolensville Pk - Cleaned Line
000	16303009	09/19/18	09/19/18	4 hours	0.0001		Roots	660 Bell Rd - Cleaned Line
000	15004038	09/19/18	09/19/18	0.5 hours	0.00001		Excessive Flow	4125 Philhall Pky - MNPS private pump station
000	15004039	09/19/18	09/19/18	0.5 hours	0.00001		Excessive Flow	1101 Scenic Lake Ct - MNPS private pump station
000	08101014	09/21/18	09/22/18	25 hours	0.001	0.52	Force Main	1830 River Dr - Repaired FM
187	Peppertree PS	09/22/18	09/23/18	3 hours	0.03	3.48	Rainfall	High inflow due to construction site with broken pipe.
187	Peppertree PS	09/23/18	09/26/18	50 hours	5	5.53	Rainfall	High inflow due to construction site with broken pipe.
222	149 Barker Road	09/27/18	09/27/18	2.42 hours	0.034	1.18	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: September, 2018

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
---	---------------	------------	----------	----------	-------------	----------	----------------	---------

Sanitary Sewer Overflows

000	04312035	09/03/18	09/03/18	5.5 hours	0.0001		Grease	218 Rio Vista Dr - Cleaned Line
110	Loves Branch PS	09/14/18	09/14/18	1.33 hours	0.021		Force Main	Force main break. Station shut down for repair.

Monthly Overflow Report

Date Range: September, 2018

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	03209025	09/30/18	09/30/18	7 hours	0.0001		Roots	4428 Indian Summer Dr - Cleaned Line