

Monthly Overflow Report

Date Range: October, 2018

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	15004039	10/01/18	10/01/18	0.5 hours	0.00001	0.03	Other/not listed	1105 Scenic Lake Ct - MNPS pvt pump station repair
000	14905050	10/03/18	10/03/18	3 hours	0.00001		Grit/Debris	4909 Barclay Square Dr - Cleaned Line
000	16410027	10/03/18	10/03/18	3.5 hours	0.00001		Grit/Debris	4505 Sandpiper Ln - Cleaned Line
134	Riverside Drive PS	10/15/18	10/16/18	22.25 hours	0.4	4.44	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	10/15/18	10/15/18	11 hours	3.616	4.42	Rainfall	Infiltration/inflow. Station at rated capacity.
179	Fairway Center PS	10/15/18	10/15/18	1.5 hours	0.03	3.84	Rainfall	Infiltration/inflow. Station at rated capacity.
222	149 Barker Road	10/15/18	10/15/18	6.75 hours	0.105	1.94	Rainfall	Infiltration/inflow. Station at rated capacity.
226	Cowan St. Relief Bleeder	10/15/18	10/15/18	5.67 hours	0.591	4.04	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: October, 2018

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
106	Vandiver PS	10/15/18	10/15/18	13.42 hours	1.573	3.94	Rainfall	Infiltration/inflow. Station at rated capacity.
109	Dry Creek PS	10/15/18	10/15/18	6.5 hours	0.941	3.98	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	10/15/18	10/15/18	5.83 hours	0.712	3.98	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	10/15/18	10/15/18	7 hours	0.15	3.98	Rainfall	Infiltration/inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	10/15/18	10/15/18	4.5 hours	0.03	3.98	Rainfall	Infiltration/inflow. Station at rated capacity.
150	Hidden Acres PS	10/15/18	10/15/18	10.2 hours	0.9	3.98	Rainfall	Infiltration/inflow. Station at rated capacity.
169	Lakemeade PS #2	10/15/18	10/15/18	8.5 hours	0.4	3.11	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: October, 2018

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05911027	10/15/18	10/15/18	6 hours	0.001	4.24	Rainfall	701 Rowan Dr
000	05911028	10/15/18	10/15/18	6 hours	0.001	4.24	Rainfall	709 Rowan Dr
101	Bordeaux Hospital PS	10/15/18	10/15/18	1.25 hours	0.015	4.42	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	10/15/18	10/15/18	15.08 hours	1.513	3.78	Rainfall	Infiltration/inflow. Station at rated capacity.
126	Cleeces Ferry PS	10/15/18	10/15/18	2.5 hours	0.05	3.78	Rainfall	Infiltration/inflow. Station at rated capacity.
128	Bordeaux Hills PS	10/15/18	10/16/18	29 hours	0.15	4.44	Rainfall	Infiltration/inflow. Station at rated capacity.
136	River Drive PS	10/15/18	10/16/18	19.16 hours	0.594	4.42	Rainfall	Infiltration/inflow. Station at rated capacity.
138	Sunliner PS	10/15/18	10/15/18	3.25 hours	0.15	3.78	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	10/15/18	10/15/18	13.4 hours	0.05	4.91	Rainfall	Infiltration/inflow. Station at rated capacity.
217	Basswood Ave.	10/15/18	10/15/18	5 hours	0.262	3.78	Rainfall	516 Basswood Ave