

Monthly Overflow Report

Date Range: November, 2018

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	09413023	11/01/18	11/02/18	10 hours	0.001	0.23	Line Break	711 Lebanon Pk - Repaired Line
000	13302047	11/08/18	11/08/18	4.5 hours	0.001		Grease	180 McCall St - Cleaned Line
000	10612019	11/11/18	11/11/18	0.5 hours	0.001		Grit/Debris	895 Murfreesboro Pk - Cleaned Line
000	09203078	11/26/18	11/26/18	1.5 hours	0.00001		Grit/Debris	2214 Morena St - Cleaned Line
000	09302095	11/30/18	11/30/18	6 hours	0.001	0.44	Grit/Debris	214 2nd Ave N - Cleaned Sewer Fitting #093-02-024 in Bank St
134	Riverside Drive PS	11/05/18	11/06/18	8.5 hours	0.15	2.32	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	11/06/18	11/06/18	12.25 hours	2.949	2.32	Rainfall	Infiltration/inflow. Station at rated capacity.
159	Summerfield SPS	11/17/18	11/17/18	2 hours	0.02	0.00	Controller	Level sensor and backup PLC failed.
183	Mill Creek PS	11/15/18	11/15/18	0.5 hours	0.05	0.00	Electrical	Lost incoming power due to failed breaker.
222	149 Barker Road	11/06/18	11/06/18	4.92 hours	0.08	1.89	Rainfall	Infiltration/inflow. Station at rated capacity.
226	Cowan St. Relief Bleeder	11/05/18	11/06/18	3.09 hours	0.269	2.34	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: November, 2018

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	05302066	11/21/18	11/21/18	4 hours	0.001		Grit/Debris	102 Hurst Dr - Cleaned Line
106	Vandiver PS	11/05/18	11/06/18	7.58 hours	0.485	2.31	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	11/05/18	11/06/18	4.25 hours	0.343	2.38	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	11/06/18	11/06/18	6.5 hours	0.15	2.38	Rainfall	Infiltration/inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	11/06/18	11/06/18	1.3 hours	0.01	2.38	Rainfall	Infiltration/inflow. Station at rated capacity.
150	Hidden Acres PS	11/06/18	11/06/18	2.3 hours	0.2	2.38	Rainfall	Infiltration/inflow. Station at rated capacity.
169	Lakemeade PS #2	11/06/18	11/06/18	11 hours	0.4	2.38	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: November, 2018

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	07015021	11/01/18	11/05/18	96 hours	0.001		Force Main	2245 Rosa L Parks Blvd - Repaired FM
000	05911028	11/06/18	11/06/18	4 hours	0.001	2.58	Rainfall	709 Rowan Dr
114	Davidson Branch PS	11/06/18	11/06/18	11.67 hours	1	2.02	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	11/14/18	11/15/18	9.58 hours	0.527	1.00	Rainfall	Infiltration/inflow. Station at rated capacity.
128	Bordeaux Hills PS	11/06/18	11/06/18	5.5 hours	0.03	2.32	Rainfall	Infiltration/inflow. Station at rated capacity.
136	River Drive PS	11/06/18	11/06/18	3.83 hours	0.054	2.32	Rainfall	Infiltration/inflow. Station at rated capacity.
138	Sunliner PS	11/05/18	11/06/18	2.5 hours	0.1	2.02	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	11/05/18	11/06/18	5 hours	0.02	3.32	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	11/14/18	11/15/18	2 hours	0.01	1.14	Rainfall	Infiltration/inflow. Station at rated capacity.
217	Basswood Ave.	11/06/18	11/06/18	1.08 hours	0.007	2.02	Rainfall	516 Basswood Ave