

# Monthly Overflow Report

Date Range: December, 2018

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	09310147	12/03/18	12/03/18	2 hours	0.001		Grit/Debris	200 4th Ave S - Cleaned Line
000	09304026	12/04/18	12/09/18	126 hours	0.00001	0.91	Line Break	603 S 9th St - Repaired Line
000	15011059	12/13/18	12/13/18	2 hours	0.0001	0.03	Grease	3456 New Towne Rd - Cleaned Line
000	WLS052K123	12/27/18	12/27/18	2 hours	0.001	0.66	Grit/Debris	4845 Catskill Dr - Cleaned Line
000	11908016	12/31/18	01/02/19	36 hours	0.5	2.78	Rainfall	431 E Thompson Ln
130	Browns Creek PS	12/31/18	12/31/18	2.17 hours	6.332	2.44	Rainfall	Infiltration/inflow. Station at rated capacity.
134	Riverside Drive PS	12/31/18	01/01/19	20.8 hours	0.5	2.86	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	12/31/18	12/31/18	18 hours	4.529	2.53	Rainfall	Infiltration/inflow. Station at rated capacity.
183	Mill Creek PS	12/31/18	01/02/19	46.5 hours	0.5	2.89	Rainfall	Infiltration/inflow. Station at rated capacity.
188	South Oak Hill PS	12/31/18	12/31/18	15.4 hours	1	2.59	Rainfall	Infiltration/inflow. Station at rated capacity.
222	149 Barker Road	12/31/18	01/05/19	117.67 hours	7.386	5.10	Rainfall	Infiltration/inflow. Station at rated capacity.

# Monthly Overflow Report

Date Range: December, 2018

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	04309103	12/22/18	12/23/18	4.5 hours	0.001	0.44	Grease	246 Cumberland Ave - Cleaned Line
000	04411010	12/26/18	12/26/18	3.5 hours	0.0001		Grit/Debris	509 Jones St - Cleaned Line
106	Vandiver PS	12/31/18	01/01/19	18.42 hours	1.311	2.94	Rainfall	Infiltration/inflow. Station at rated capacity.
109	Dry Creek PS	12/30/18	01/04/19	4.08 hours	0.024	3.47	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	12/31/18	12/31/18	10.92 hours	0.423	2.84	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	12/31/18	01/02/18	54.58 hours	2.671	3.12	Rainfall	Infiltration/inflow. Station at rated capacity.
123	Lakewood PS	12/31/18	12/31/18	8.9 hours	0.2	2.94	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	12/31/18	01/01/19	16.9 hours	0.5	2.81	Rainfall	Infiltration/inflow. Station at rated capacity.
169	Lakemeade PS #2	12/31/18	01/02/19	42.25 hours	2	3.29	Rainfall	Infiltration/inflow. Station at rated capacity.

# Monthly Overflow Report

Date Range: December, 2018

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	07912002	12/27/18	12/28/18	17 hours	0.001	0.62	Roots	7021 Westbelt Dr - Cleaned Line
000	12915024	12/28/18	12/28/18	4.5 hours	0.001	0.60	Roots	903 Glenmary Ct - Cleaned Line
107	West Park PS	12/31/18	12/31/18	7.17 hours	0.558	2.57	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	12/31/18	01/01/19	26 hours	1.48	2.57	Rainfall	Infiltration/inflow. Station at rated capacity.
126	Cleeces Ferry PS	12/31/18	12/31/18	3.2 hours	0.1	2.57	Rainfall	Infiltration/inflow. Station at rated capacity.
128	Bordeaux Hills PS	12/31/18	01/01/19	22.5 hours	0.15	2.86	Rainfall	Infiltration/inflow. Station at rated capacity.
172	Hillview	12/31/18	01/02/19	53 hours	1	2.96	Rainfall	Infiltration/inflow. Station at rated capacity.
217	Basswood Ave.	12/31/18	12/31/18	6.25 hours	0.07	2.57	Rainfall	516 Basswood Ave