

# Monthly Overflow Report

Date Range: January, 2019

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	09202032	01/01/19	01/01/19	2 hours	0.001		Grit/Debris	1030 28th Ave N alley - Cleaned Line
000	14701055	01/02/19	01/02/19	1 hours	0.0001	0.49	Grit/Debris	343 Lynn Dr - Cleaned Line
000	09208134	01/02/19	01/02/19	1 hours	0.001		Grit/Debris	1401 Charlotte Ave - Cleaned Line
000	15012019	01/09/19	01/10/19	24 hours	0.0001		Force Main	5013 Mooregate Dr - Repaired FM
000	13413023	01/10/19	01/10/19	2 hours	0.0001		Grease	361 Harding Pl - Cleaned Line
000	09413023	01/17/19	01/17/19	2.5 hours	0.001	0.43	Rags	710 Calhoun Ave - Removed rags from pump line
000	WLS52K123	01/17/19	01/17/19	1 hours	0.001	0.51	Grit/Debris	4845 Catskill Dr
000	09413023	01/21/19	01/21/19	4 hours	0.001		Line Break	710 Calhoun Ave - Bypass pump failure
134	Riverside Drive PS	01/19/19	01/19/19	12 hours	0.2	1.59	Rainfall	Infiltration/inflow. Station at rated capacity.
140	28th Avenue PS / Centennial	01/19/19	01/19/19	2.08 hours	0.033	1.52	Rainfall	Infiltration/inflow. Station at rated capacity.
188	South Oak Hill PS	01/19/19	01/19/19	11 hours	0.6	1.94	Rainfall	Infiltration/inflow. Station at rated capacity.
222	149 Barker Road	01/19/19	01/22/19	76.58 hours	1.684	1.85	Rainfall	Infiltration/inflow. Station at rated capacity.
222	149 Barker Road	01/23/19	01/24/19	12.25 hours	0.146	1.21	Rainfall	Infiltration/inflow. Station at rated capacity.

# Monthly Overflow Report

Date Range: January, 2019

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
106	Vandiver PS	01/19/19	01/19/19	11.08 hours	0.293	1.86	Rainfall	Infiltration/inflow. Station at rated capacity.
109	Dry Creek PS	01/19/19	01/21/19	6.66 hours	0.504	1.77	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	01/19/19	01/19/19	3.25 hours	0.018	1.77	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	01/19/19	01/20/19	20.67 hours	2.448	1.77	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	01/23/19	01/24/19	8.92 hours	1.29	1.07	Rainfall	Infiltration/inflow. Station at rated capacity.
117	Neely's Bend PS	01/01/19	01/02/19	36.75 hours	1.411	2.65	Rainfall	Infiltration/inflow. Station at rated capacity.
123	Lakewood PS	01/19/19	01/19/19	4.5 hours	0.07	1.89	Rainfall	Infiltration/inflow. Station at rated capacity.
127	Madison Heights PS	01/19/19	01/19/19	4 hours	0.073	1.81	Rainfall	Infiltration/inflow. Station at rated capacity.
169	Lakemeade PS #2	01/19/19	01/20/19	34 hours	1	1.66	Rainfall	Infiltration/inflow. Station at rated capacity.
169	Lakemeade PS #2	01/24/19	01/24/19	3 hours	0.1	1.94	Rainfall	Infiltration/inflow. Station at rated capacity.

# Monthly Overflow Report

Date Range: January, 2019

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
<b>Sanitary Sewer Overflows</b>								
000	09004005	01/02/19	01/03/19	21 hours	0.001	0.35	Rainfall	6601 Centennial Blvd
000	11616040	01/19/19	01/20/19	15 hours	0.0001	1.85	Rainfall	4012 Wallace Ln
000	11612076	01/20/19	01/20/19	9 hours	0.0001	1.85	Rainfall	3504 Abbott Martin Rd
000	10406048	01/29/19	01/29/19	0.5 hours	0.0001		Grit/Debris	107 32nd Ave S - Cleaned Line
107	West Park PS	01/19/19	01/19/19	2 hours	0.101	1.44	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	01/19/19	01/20/19	19 hours	1.312	1.44	Rainfall	Infiltration/inflow. Station at rated capacity.
114	Davidson Branch PS	01/23/19	01/24/19	7.17 hours	0.253	0.85	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	01/19/19	01/19/19	10 hours	0.03	1.67	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	01/23/19	01/23/19	1.5 hours	0.005	1.02	Rainfall	Infiltration/inflow. Station at rated capacity.
172	Hillview	01/03/19	01/04/19	20 hours	0.5	0.90	Rainfall	Infiltration/inflow. Station at rated capacity.
172	Hillview	01/04/19	01/05/19	33 hours	0.5	0.39	Rainfall	Infiltration/inflow. Station at rated capacity.
172	Hillview	01/19/19	01/21/19	55 hours	0.9	1.94	Rainfall	Infiltration/inflow. Station at rated capacity.
172	Hillview	01/23/19	01/25/19	32.75 hours	0.5	1.08	Rainfall	Infiltration/inflow. Station at rated capacity.