

Monthly Overflow Report

Date Range: April, 2020

Central WWTP NPDES# TN 0020575

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	13306061	04/04/20	04/04/20	3 hours	0.0001		Grit/Debris	3601 Sabre Dr - Cleaned Line
000	WMN058A016	04/17/20	04/17/20	4 hours	0.001	0.09	Grit/Debris	0 Rocky Fork Rd - Cleaned Line
000	16307009	04/27/20	04/28/20	21 hours	0.001		Roots	1 Hickory Club Dr - Cleaned Line
000	09308017	04/27/20	04/27/20	2 hours	0.00001		Grit/Debris	S 6th St - Cleaned Line
000	13110135	04/30/20	04/30/20	0.5 hours	0.00001		Roots	821 Cherry Laurel Ct - Cleaned Line
102	Smith Springs PS	04/12/20	04/13/20	12.92 hours	0.293	2.57	Rainfall	Infiltration/inflow. Eqs full.
103	McCrary Creek PS	04/12/20	04/13/20	7.5 hours	0.289	2.86	Rainfall	Infiltration/inflow. Station at rated capacity.
130	Browns Creek PS	04/13/20	04/13/20	1 hours	1.034	2.66	Rainfall	Infiltration/inflow. Station at rated capacity.
131	Hurricane Creek PS	04/12/20	04/12/20	23 hours	1.4	2.52	Rainfall	Infiltration/inflow. Station at rated capacity.
134	Riverside Drive PS	04/12/20	04/13/20	15.25 hours	0.25	3.19	Rainfall	Infiltration/inflow. Station at rated capacity.
188	South Oak Hill PS	04/12/20	04/12/20	6.8 hours	0.4	2.41	Rainfall	Infiltration/inflow. Station at rated capacity.
189	Langford Farms PS	04/12/20	04/12/20	2.5 hours	0.03	2.52	Rainfall	Infiltration/inflow. Station at rated capacity.
384	501 Bismark Dr.	04/13/20	04/14/20	26 hours	0.8	2.84	Rainfall	501 Bismark Dr - Est 500 GPM

Monthly Overflow Report

Date Range: April, 2020

Dry Creek WWTP NPDES# TN0020648

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
106	Vandiver PS	04/12/20	04/12/20	5.17 hours	0.222	2.92	Rainfall	Infiltration/inflow. Station at rated capacity.
110	Loves Branch PS	04/12/20	04/13/20	2.59 hours	0.199	2.97	Rainfall	Infiltration/inflow. Station at rated capacity.
112	Gibson Creek PS	04/12/20	04/12/20	6.42 hours	0.913	2.97	Rainfall	Infiltration/inflow. Station at rated capacity.
123	Lakewood PS	04/12/20	04/12/20	1 hours	0.02	2.63	Rainfall	Infiltration/inflow. Station at rated capacity.
132	Berwick Trail PS / Center St.	04/24/20	04/24/20	0.5 hours	0.01	0.00	Force Main	Station shut down to fix broken force main.
150	Hidden Acres PS	04/12/20	04/12/20	2 hours	0.2	2.67	Rainfall	Infiltration/inflow. Station at rated capacity.

Monthly Overflow Report

Date Range: April, 2020

Whites Creek WWTP NPDES# TN 0024970

#	Overflow Name	Start Date	End Date	Duration	Volume (mg)	Rainfall	Overflow Cause	Remarks
Sanitary Sewer Overflows								
000	11616040	04/12/20	04/13/20	24 hours	0.0001	3.17	Rainfall	4012 Wallace Ln
000	05911027	04/13/20	04/13/20	3 hours	0.001	3.12	Rainfall	701 Rowan Dr
000	10402010	04/14/20	04/14/20	2 hours	0.0001		Grit/Debris	217 Burns Ave - Cleaned Line
000	11510021	04/17/20	04/17/20	4 hours	0.0001		Grit/Debris	6520 Cornwall Dr - Cleaned Line
114	Davidson Branch PS	04/12/20	04/13/20	30.41 hours	1.274	2.92	Rainfall	Infiltration/inflow. Station at rated capacity.
138	Sunliner PS	04/12/20	04/12/20	1.1 hours	0.04	2.35	Rainfall	Infiltration/inflow. Station at rated capacity.
145	Joelton PS	04/12/20	04/13/20	14.2 hours	0.04	3.12	Rainfall	Infiltration/inflow. Station operating normally.